# Hartsdale and Scarsdale Station Improvements

100% RFC Submission Contract #: 1000106733

# **O** Scarsdale Station



Metro-North Railroad




# 100% RFC Submission AUGUST 3, 2021

## DRAWING LIST

#### **STRUCTURAL**

CEN			511	CUCTURAL	
	IERAL SCD-G-000	COVER SHEET	48	SCD-S-101	STATION FOUNDATION PLAN
2	SCD-G-101	DRAWING LIST	49	SCD-S-102	STATION PLATFORM PLAN
3	SCD-G-201	GENERAL NOTES	50	SCD-S-103	STATION OVERPASS LEVEL PART PLAN
4	SCD-G-202	GENERAL NOTES	51	SCD-S-104	STATION ROOF PART PLAN
-			52	SCD-S-301	ELEVATOR W1 ELEVATIONS
5	SCD-G-203 SCD-G-301	LEGEND & ABBREVIATIONS	53	SCD-S-801	FOUNDATION SECTIONS & DETAILS I
6	SCD-G-301 SCD-G-302	CODE COMPLIANCE - GENERAL ADA CLEARANCES, FLOOR SPACES & MANEUVERING	54	SCD-S-802	FOUNDATION SECTIONS & DETAILS II
7	000 0002	REQUIREMENTS	55	SCD-S-810	TYPICAL ELEVATOR STEEL DETAILS 1 OF 3
8	SCD-G-303	SITE PLAN	56	SCD-S-811	TYPICAL ELEVATOR STEEL DETAILS 2 OF 3
CIVI			57	SCD-S-812	TYPICAL ELEVATOR STEEL DETAILS 3 OF 3
	<u>-</u>		58	SCD-S-820	MISCELLANEOUS DETAILS
9	SCD-C-100	EXISTING STATION SITE PLAN		SCD-3-020 SCD-J-100	OVERPASS AND STAIRS JACKING PLAN
10	SCD-C-101	CIVIL PLAN	59		
10A	SCD-C-101A	CIVIL PLAN	60	SCD-J-100A	OVERPASS AND STAIRS JACKING SEQUENCE
11	SCD-C-102	STAGING AREAS	61	SCD-J-101	OVERPASS - JACKING ELEVATIONS AND SECTION
12	SCD-C-103	CIVIL DETAILS	62	SCD-J-102	OVERPASS - TIMBER AND CONCRETE MAT - PLANS AND DETAILS
ARC	HITECTURAL		63	SCD-J-103	OVERPASS - TEMPORARY STRUCTURE 1 - SECTION AND DETAILS
10			64	SCD-J-104	OVERPASS - OUTBOUND - TEMPORARY STRUCTURE 1 - SECTIONS
13	SCD-AG-001	GENERAL NOTES	65	SCD-J-105	OVERPASS - INBOUND - TEMP. STRUCTURE 2 AND PLATFORM REMOVAL PLAN
14	SCD-AG-002	GENERAL NOTES	66	SCD-J-106	OVERPASS - INBOUND - TEMPORARY STRUCTURE 2 - SECTIONS
15	SCD-AD-101	STATION PLATFORM LEVEL DEMO PLAN STATION OVERPASS LEVEL DEMO PLAN	67	SCD-J-107	OVERPASS - INBOUND - TEMPORARY STRUCTURE 3 - SECTION
16 17	SCD-AD-111 SCD-AD-611		68	SCD-J-108	WEST STAIR - TEMP. STRUCTURES 4, 5, AND 6 - SECTIONS
17 18	SCD-AD-011 SCD-A-010	STATION DEMO ELEVATION AND SECTION STATION SITE PLAN	69	SCD-J-109	WEST STAIR - PROP. STRUCTURES 4, 5, AND 6 - SECTIONS
10	SCD-A-010 SCD-A-101	STATION PLATFORM LEVEL PLAN	70	SCD-J-110	MISCELLANEOUS SECTIONS AND DETAILS - SHEET 1 OF 4
20	SCD-A-101 SCD-A-111	STATION OVERPASS LEVEL PLAN	71	SCD-J-111	MISCELLANEOUS SECTIONS AND DETAILS - SHEET 2 OF 4
20	SCD-A-111 SCD-A-201	STATION OVER ASSIEVEET LAN STATION NORTH AND SOUTH ELEVATIONS	72	SCD-J-112	MISCELLANEOUS SECTIONS AND DETAILS - SHEET 3 OF 4
22	SCD-A-202	STATION EAST ELEVATION	73	SCD-J-113	MISCELLANEOUS SECTIONS AND DETAILS - SHEET 4 OF 4
23	SCD-A-301	STATION LONGITUDINAL SECTION			
24	SCD-A-302	STATION CROSS SECTIONS	ELE	CTRICAL	
25	SCD-A-401	ENLARGED PLATFORM PLAN	74	SCD-E-001	ELECTRICAL GENERAL NOTES
26	SCD-A-411	ENLARGED OVERPASS PLAN 1 OF 2	75	SCD-E-002	ELECTRICAL SYMBOL LIST AND ABBREVIATIONS
27	SCD-A-412	ENLARGED OVERPASS PLAN 2 OF 2	76	SCD-ED-101	ELECTRICAL DEMOLITION POWER PLAN - PLATFORM LEVEL
28	SCD-A-501	ENLARGED ELEVATOR W1 PLAN	77	SCD-ED-102	ELECTRICAL DEMOLITION POWER PLAN - OVERPASS LEVEL
29	SCD-A-502	ENLARGED ELEVATOR W1 ELEVATIONS	78	SCD-E-101	ELECTRICAL POWER PLAN PLATFORM PLAN
30	SCD-A-503	ENLARGED ELEVATOR W1 SECTIONS	79	SCD-E-102	ELECTRICAL POWER PLAN OVERPASS LEVEL
31	SCD-A-601	ENLARGED ELEVATOR MACHINE	80	SCD-E-201	ELECTRICAL OVERPASS LEVEL - SECTION DETAIL
		ROOM AND COMM ROOM DRAWINGS	81	SCD-E-301	ELECTRIC SERVICE ENLARGED PLAN
32	SCD-A-701	STATION PLATFORM LEVEL REFLECTED CEILING PLAN	82	SCD-E-302	ELECTRICAL EMR & ELEVATOR PIT ENLARGED PLANS
33	SCD-A-711	STATION OVERPASS LEVEL REFLECTED CEILING PLAN	83	SCD-E-401	EXISTING ONE LINE DIAGRAM
34 25	SCD-A-801	OVERPASS SECTION DETAILS 1 OF 2	84	SCD-E-402	PROPOSED ONE LINE DIAGRAM
35 36	SCD-A-802 SCD-A-803	OVERPASS SECTION DETAILS 2 OF 2 WALL SECTION AND MISCELLANEOUS DETAILS 1 OF 2	85	SCD-E-403	ELECTRICAL PANEL SCHEDULES
36 37	SCD-A-803 SCD-A-804	WALL SECTION AND MISCELLANEOUS DETAILS 1 OF 2 WALL SECTION AND MISCELLANEOUS DETAILS 2 OF 2	86	SCD-E-501	ELECTRICAL GROUNDING AND LIGHTNING PROTECTION PLAN
38	SCD-A-804 SCD-A-805	DOOR SCHEDULE AND DETAILS	87	SCD-E-502	ELECTRICAL DETAILS
39	SCD-A-803 SCD-A-811	ELEVATOR ENCLOSURE DETAILS 1 OF 4	LIGH	ITING	
40	SCD-A-811 SCD-A-812	ELEVATOR ENCLOSURE DETAILS 2 OF 4	00		
40	SCD-A-813	ELEVATOR ENCLOSURE DETAILS 3 OF 4	88	SCD-LD-101	ELECTRICAL LIGHTING DEMOLITION PLAN - OVERPASS LEVEL
42	SCD-A-813	ELEVATOR ENCLOSURE DETAILS 4 OF 4	89	SCD-L-101	ELECTRICAL LIGHTING PLAN - PLATFORM LEVEL ELECTRICAL LIGHTING PLAN - OVERPASS LEVEL
43	SCD-A-815	ELEVATOR CAB DETAILS	90	SCD-L-102	ELECTRICAL LIGHTING PLAN - UVERPASS LEVEL
л л		ELEVATOR MACHINE ROOM PLAN AND SECTION			
44	SCD-A-816	DETAILS			
45	SCD-A-901	STATION SIGNAGE SCHEDULE AND DETAILS			
46	SCD-A-902	STATION PLATFORM LEVEL SIGNAGE PLAN			
47	SCD-A-911	STATION OVERPASS LEVEL SIGNAGE PLAN & FURNITURE/FIXTURE PLAN			



#### COMMUNICATION

91	SCD-ES-001	COMMUNICATION GENERAL NOTES
92	SCD-ES-002	COMMUNICATION GENERAL NOTES
93	SCD-ES-003	COMMUNICATION ONE LINE DIAGRA
94	SCD-ES-100	PLATFORM LEVEL COMMUNICATION
95	SCD-ES-101	OVERPASS LEVEL COMMUNICATION
96	SCD-ES-102	COMMUNICATION OVERPASS ELEV
97	SCD-ES-200	PLATFORM LEVEL COMMUNICATION
98	SCD-ES-201	OVERPASS LEVEL COMMUNICATION
99	SCD-ES-202	COMMUNICATION OVERPASS ELEV
ME	CHANICAL	
100	SCD-M-001	SYMBOLS, LEGEND, ABBREVIATIO
101	SCD-M-002	DETAILS & SCHEDULES
102	SCD-M-101	MECHANICAL PLATFORM PART PL
FIR	E ALARM	
103	SCD-FA-001	FIRE ALARM SYSTEM GENERAL N
104	SCD-FA-002	FIRE ALARM SYSTEM RISER DIAG
105	SCD-FA-101	FIRE ALARM PLAN - PLATFORM LE
106	SCD-FA-102	FIRE ALARM PLAN - OVERPASS L

#### ARCHITECTURAL STANDARDS DRAWINGS

A3-174 LEF	NING BAR - PLAN	IS, ELEVATIO
	NCH - PLANS, ELE	

109	STD-P-001	SYMBOLS, LEGEND, ABBRE
110	STD-P-101	PLATFORM PART PLAN
111	STD-P-501	SCHEDULES
112	STD-P-601	DETAILS

CONFORMED			
	DRWN	CHKD	APPVD
D $D$ $T$ $T$ $T$ $O$ $T$ $O$ $T$			





REVISION

ES, LEGEND, AND ABBREVIATIONS DWG. 1 OF 2

ES, LEGEND, AND ABBREVIATIONS DWG. 2 OF 2 RAM

ON CONDUIT REMOVAL LAYOUT PLAN ION CONDUIT REMOVAL LAYOUT PLAN EVATION SOUTH VIEW REMOVAL ON CONDUIT FINAL LAYOUT PLAN ION CONDUIT FINAL LAYOUT PLAN EVATION SOUTH VIEW FINAL

IONS & GENERAL NOTES

PLAN

NOTES, SYMBOL LIST, & ABBREVIATION LIST

AGRAM & SEQUENCE OF OPERATION LEVEL LEVEL

DETAILS ONS & DETAILS

REVIATIONS, AND GENERAL NOTES

	100% RFC SU	BMISSI	ON	
	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733		
Railroad	IMPROVEMENTS	SCALE	DATE <b>08/03/2021</b>	
	DRAWING LIST	DRAWING NO.		
		SCD-G	i-101	
	SCARSDALE STATION	SHEET <b>2</b> O	F 112	

## GENERAL NOTES

#### GENERAL REQUIREMENTS:

- REFER TO THE 'STATION SITE PLAN' SHEET FOR A GENERAL DESCRIPTION OF THE WORK TO BE DONE. ALL DRAWINGS WERE USED IN CONJUNCTION WITH THE SPECIFICATIONS IN DETERMINING THE FULL PROJECT 22. SCOPE. REFER TO SPECIFICATION SECTION 011100 SUMMARY OF WORK.
- THE WORK OF THIS CONTRACT IS TO TAKE PLACE IN AND AROUND AN OPERATIONAL RAILROAD, PRIVATE 23. DEVELOPMENT AND PARKING FACILITIES. THE CONTRACTOR SHALL PROPERLY SECURE ALL AREAS UNDER CONSTRUCTION TO PROTECT THE SAFETY OF THE GENERAL PUBLIC. WORK AREAS SHALL BE FENCED AND DELINEATED, INCLUDING APPROPRIATE DANGER AND CAUTIONARY SIGNAGE AS APPROVED BY METRO-NORTH 24. RAILROAD (MNR). THE SITE IS TO BE PROPERLY SECURED WITH TEMPORARY FENCING AT THE END OF EACH SHIFT, AS APPROVED BY MNR.
- THE CONTRACTOR SHALL TAKE EVERY PRECAUTION TO CONDUCT HIS OPERATIONS IN A MANNER NOT TO CAUSE DISRUPTION IN THE USE OF ADJOINING PROPERTIES, FACILITIES & UTILITIES. THE CONTRACTOR SHALL MAINTAIN SAFE, CLEAN AND UNRESTRICTED ACCESS TO ALL PUBLIC AND PRIVATE PROPERTIES AT ALL TIMES, AND INSTALL TEMPORARY FENCING, BARRICADES, AND PAVEMENT MARKINGS/STRIPING AND SIGNAGE AS REQUIRED.
- THE CONTRACTOR IS DIRECTED TO COOPERATE WITH MNR'S REPRESENTATIVE AND ALL OTHER CONTRACTORS 25. PERFORMING WORK ON THIS JOB SITE DURING THE PERFORMANCE OF THIS CONTRACT
- IT IS THE CONTRACTOR'S RESPONSIBILITY TO EXAMINE ALL PLAN SHEETS AND SPECIFICATIONS, AND COORDINATE WORK WITH ALL OTHER CONTRACTORS AND CONTRACTS AT THE SITE.
- THE CONTRACTOR SHALL FIELD VERIFY ALL EXISTING CONDITIONS AND DIMENSIONS PRIOR TO BEGINNING WORK AND SHALL REPORT ALL DISCREPANCIES TO THE ENGINEER PRIOR TO BEGINNING WORK.
- ALL NECESSARY PERMITS ARE TO BE SECURED BY THE CONTRACTOR PRIOR TO ANY WORK COMMENCING. INCLUDING BUT NOT LIMITED TO, ANY WHICH MAY BE NECESSARY TO WORK IN AND ADJACENT TO PUBLIC STREETS, TO CONSTRUCT CONSTRUCTION DRIVEWAYS FOR SITE ACCESS, TO MAKE CONNECTIONS TO EXISTING 27. SANITARY, STORM AND WATER FACILITIES, AND TO OBTAIN ENVIRONMENTAL PERMITS, AS WELL AS ANY OTHERS REQUIRED.
- EXCAVATED SOIL FROM MNR PROPERTY TO BE STOCK PILED AND RE-USED ON MNR PROPERTY. ALL EXCAVATED SOIL ON NON MNR PROPERTY SHALL NOT TO BE REUSED
- UNCLASSIFIED EXCAVATION INCLUDES, BUT IS NOT LIMITED TO, EXCAVATION REQUIRED FOR NEW MANHOLES, 28. 9 INLETS OR DRAINAGE PIPES. ALL VOIDS CREATED BY THE REMOVAL OF EXISTING STORM DRAINS AND SUBSURFACE STRUCTURES WILL BE BACKFILLED WITH SUITABLE UNCLASSIFIED EXCAVATION MATERIAL AS DIRECTED BY THE ENGINEER. IF NO SUITABLE UNCLASSIFIED EXCAVATION MATERIAL IS AVAILABLE IN THE OPINION OF THE ENGINEER, THE CONTRACTOR WILL PROVIDE SATISFACTORY SOIL MATERIAL MEETING THE 29. REQUIREMENTS OF THE SPECIFICATIONS FOR USE AS BACKFILL. ALL EXCAVATION WILL COMPLY WITH N.Y.S. INDUSTRIAL CODE 53 AND OSHA REQUIREMENTS.
- 10. THE MNR REPRESENTATIVE RESERVES THE RIGHT TO EXAMINE ANY WORK DONE ON THIS PROJECT AT ANY TIME TO DETERMINE THE CONFORMANCE WITH THE REQUIREMENTS OF THE PROJECT CONTRACT DOCUMENTS, AS INTENDED AND INTERPRETED BY THE ENGINEER
- 30. RESTORE SITE FEATURES DESTROYED OR MOVED TO PRE-CONSTRUCTION LOCATION AND USE. THIS SHALL 11. INCLUDE FULL DEPTH ASPHALT PAVEMENT, CONCRETE SIDEWALK AND CURB REPLACEMENT, INCLUDING PLACEMENT, GRADING AND COMPACTION OF AGGREGATE SUBBASE, PLACEMENT OF ASHPALT CONCRETE BINDER AND TOP COURSES, CONSTRUCTION OF CONCRETE WALKS AND CURBING, AND LANDSCAPING.
- 12. ALL WORK WILL BE DONE IN STRICT COMPLIANCE WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES, 31. METRO NORTH STANDARDS, ORDINANCES, RULES AND REGULATIONS, AS THEY MAY APPLY.
- 13 CONTRACTOR IS RESPONSIBLE FOR ALL SHORING DETAILS AND SITE SPECIFIC DETAILS. THESE DOCUMENTS, IN ADDITION TO A SITE PLAN, SHALL BE SUBMITTED TO MNR FOR APPROVAL.
- 14. HORIZONTAL DATUM IS REFERENCED TO THE NEW YORK STATE PLANE COORDINATE SYSTEM VERTICAL DATUM IS REFERENCED TO THE NORTH AMERICAN VERTICAL DATUM OF 1980
- EXISTING UTILITIES SHOWN ON THESE DRAWINGS HAVE BEEN DETERMINED BY STANDARD SURVEYING METHODS 15. AND AVAILABLE RECORDS THE LOCATIONS SHOWN FOR THESE UTILITIES ARE APPROXIMATE AND MAY BE INCOMPLETE. THE CONTRACTOR WAS RESPONSIBLE FOR VERIFYING UTILITIES, SURVEY, AND OBTAINING ANY PERMITS REQUIRED.
- 16. THE CONTRACTOR TO SUBMIT A DETAILED CONSTRUCTION STAGING PLAN TO THE ENGINEER FOR APPROVAL PRIOR TO THE START OF WORK THE CONTRACTOR OBTAINED ANY PERMITS FOR THE WORK
- 17. THE CONTRACTOR TO SUBMIT A DETAILERS WORKPLAN FOR METRO-NORTH RAILROAD APPROVAL. SHOWING A DETAILED WORK SCHEDULE AND ALL EQUIPMENT TO BE USED ON METRO-NORTH'S RIGHT-OF-WAY. PRIOR TO WORK AT THAT ACTVITY.
- 18. THE CONTRACTOR TO PROTECT FROM DAMAGE ALL MONUMENTS. SURVEY POINTS, AND BENCH MARKS NOT DESIGNATED FOR REMOVAL AND SHALL ESTABLISH OFFSET POINTS AS REQUIRED FOR HIS OR HER WORK.
- THE DIMENSIONS SHOWN ON THE PLANS MAY VARY FROM THE ACTUAL EXISTING DIMENSIONS IN THE FIELD. THE 19. CONTRACTOR, PRIOR TO COMMENCEMENT OF WORK, SHALL TAKE EXACT MEASUREMENTS TO VERIFY ALL DIMENSIONS SHOWN ON THE PLANS AS WELL AS OBTAIN OTHER NECESSARY DIMENSIONS FOR THE PURPOSE OF PREPARING SHOP AND OTHER WORKING DRAWINGS. SHOP DRAWINGS AND ANY OTHER DRAWINGS PREPARED BY THE CONTRACTOR WILL BE PREPARED UNDER DIRECT SUPERVISION OF A LICENSED PROFESSIONAL ENGINEER IN NYS, AND SHALL INCLUDE A STATEMENT CERTIFYING THAT THOSE DRAWINGS HAVE BEEN PREPARED IN ACCORDANCE WITH THE FIELD-MEASURED DIMENSIONS. IT IS THE CONTRACTOR'S RESPONSIBILITY TO OBTAIN THE SERVICES OF A SURVEYOR, LICENSED IN THE STATE OF NEW YORK, TO VERIFY THE INFORMATION PRESENTED IN THESE CONTRACT DOCUMENTS, AND TO COMPLETE THE REQUIRE CONSTRUCTION LAYOUTS.

VERIFY ALL DIMENSIONS AND JOB CONDITIONS PRIOR TO STARTING WORK AND REPORTED TO THE ENGINEER 20. ANY DISCREPANCIES OR COMMISSION WHICH WOULD INTERFERE WITH SATISFACTORY COMPLETION OF WORK.

#### DIMENSIONS SHOW ON FLOOR PLANS ARE TYPICALLY TO CENTER LINE OF COLUMNS OR FACE OF STUDS, 21 CONCRETE MASONRY UNLESS NOTED OTHERWISE

DESIGNED	050										CONFORMED			
	SED	MININGE NE WINN												
DDAWM		MOONTE												
DRAWN	TJB													
CHECKED		S. AMERIA SE												
	SED		NO.	DATE		DRWN	CHKD	APPVD	NO.	DATE		DRWN	CHKD	APPVD
		PD 6215												
APPROVED	JSH	TOFESSIONA			REVISION						REVISION			
	3011													

26.

32.

34.

35.

#### GENERAL REQUIREMENTS CONT'D

DO NOT SCALE DRAWINGS. WRITTEN DIMENSIONS GOVERN PARTITION LOCATIONS, DIMENSIONS AND TYPES. IN CASE OF CONFLICT, NOTIFY ENGINEER FOR WRITTEN CLARIFICATIONS PRIOR TO PROCEEDING W/CONSTRUCTION. CONSTRUCTION PLAN BY ENGINEER SUPERCEDES OTHER PLANS

DIMENSIONS SHOWN AS "VIF" WERE VERIFIED IN THE FIELD BY LAYING OUT THE PARTITIONS. NOTIFIED ENGINEER OF ANY DISCREPANCY IN DIMENSIONS PRIOR TO PROCEEDING WITH THE WORK IN THE AREA

THE CONTRACTOR IS INFORMED THAT, DUE TO THE NATURE OF RECONSTRUCTION PROJECTS, THE EXACT EXTENT OF RECONSTRUCTION WORK CANNOT ALWAYS BE ACCURATELY DETERMINED PRIOR TO THE COMMENCEMENT OF WORK. THESE CONTRACT DOCUMENTS HAVE BEEN PREPARED BASED ON FIELD INSPECTION AND OTHER INFORMATION AVAILABLE AT THE TIME. ACTUAL FIELD CONDITIONS MAY REQUIRE MODIFICATIONS TO CONSTRUCTION DETAILS. THE CONTRACTOR SHALL SUBMIT DETAILS OF ANY CONDITION THAT VARIES FROM THE CONTRACT DOCUMENTS IMMEDIATELY AFTER DISCOVERY AND AWAIT DIRECTION FROM METRO-NORTH RAILROAD BEFORE PROCEEDING WITH THE WORK

A RAILROAD FLAGMAN IS REQUIRED ON DUTY AT THE JOB SITE AT ALL TIMES WHILE CONSTRUCTION WORK IS BEING PERFORMED AND/OR WHEN THE ENGINEER OR THE RAILROAD DEEMS IT NECESSARY. THE FLAGMAN AND THE NUMBER OF FLAGMAN TO BE PROVIDED AND DETERMINED BY METRO-NORTH RAILROAD

THE CLOSING OF RAILROAD STATION FACILITIES TO COMMUTERS AND/OR THE STOPPING OF TRAIN OPERATIONS DURING CONSTRUCTION WILL NOT BE PERMITTED UNLESS NOTED IN THESE CONTRACT DOCUMENTS THE CONTRACTOR SCHEDULED AND PERFORMED THE WORK IN AN APPROVED MANNER THAT DID NOT INTERFERE WITH TRAIN OPERATIONS AND/OR COMMUTERS USE OF THE STATION PLATFORMS, WALKWAYS, ELEVATORS AND PARKING AREA DURING ALL PHASES OF WORK.

ACCESS TO THE WORK SITE AND STORAGE OF MATERIALS AND EQUIPMENT ON THE STATION PREMISES OR AS SHOWN IN THE DESIGNATED STAGING AREAS MUST BE APPROVED BY THE ENGINEER, ANY DAMAGE (CAUSED BY THE CONTRACTOR OR EMPLOYEES DURING CONSTRUCTION, ACCESS, STORAGE OF MATERIALS AND EQUIPMENT, AND/OR REMOVAL OF FENCES, PAVEMENT, ETC.) MUST BE RESTORED TO IT'S ORIGINAL CONDITION AT NO ADDITIONAL COST TO METRO-NORTH RAILROAD

THE CONTRACTOR SHALL MAINTAIN ADJACENT STREETS, STATION AREA, STAGING AREA, TRACK ACCESS AREA CLEAN OF DIRT AND DEBRIS AND WILL BE RESPONSIBLE FOR ALL MAINTENANCE AND CLEANING OF THESE AREAS DURING THE COURSE OF THE PROJECT.

METRO-NORTH RAILROAD REQUIRES ALL PERSONNEL WORKING ON THEIR PROPERTY TO HAVE A METRO-NORTH PHOTO IDENTIFICATION, METRO-NORTH RAILROAD WILL ARRANGE TO HAVE THE IDENTIFICATION CARDS MADE AT THE BEGINNING OF THE CONTRACT AND THROUGHOUT THE DURATION OF THE CONTRACT. THE CONTRACTOR IS MADE AWARE THAT THE PHOTOS FOR THE IDENTIFICATION CARDS ARE TAKEN AT 420 LEXINGTON AVENUE. NEW YORK, NY. PHOTO ID IS REQUIRED OF SUPERINTENDENTS AND FIELD ENGINEERS, AND ALL JOURNEYMEN/ WOMEN.

ALL WORK SHALL FOLLOW ESTABLISHED WORKING POINTS, AS OUTLINED ON DRAWINGS. CONTRACTOR TO VERIFY WORKING POINTS & COORDINATE W/ ALL DISCIPLINE DRAWINGS PRIOR TO ANY DEMOLITION & NEW WORK. ANY DISCREPANCIES SHALL BE BROUGHT UP TO THE ENGINEER & METRO-NORTH FOR REVIEW. REFER TO STRUCTURAL DRAWINGS FOR ALL WORK STARTING POINTS.

CONTRACTOR SHALL PROVIDE PHASING PLAN & SCHEDULE TO ENCOMPASS ALL DEMOLITION & NEW WORK. PHASING PLAN SHALL INCLUDE CONTRACTOR'S MEAN & METHODS FOR ALL DEMOLITIONS & NEW WORK, ESTABLISHING SAFE WORKING CONDITIONS & NOT IMPEDE ON NORMAL STATION OPERATIONS, INCLUDING PASSENGER STATION ACCESS. CONTRACTOR'S PHASING PLAN SHALL BE SUBMITTED TO METRO-NORTH FOR REVIEW AND APPROVAL PRIOR TO WORK COMMENCING.

CONTRACTOR SHALL TAKE REASONABLE CARE TO MAINTAIN A SAFE AND SECURE WORK AREA AT ALL TIMES THROUGH THE USE OF, AMONG OTHER ITEMS, SAFETY EQUIPMENT AND FALL PROTECTION.

33. THE DRAWINGS INDICATE A SPECIFIC DESIGN INTENT. THIS INTENT IS NOT SUBJECT TO SUBSTITUTION WHERE SPECIFIC MATERIALS ARE IDENTIFIED AND ARCHITECTURAL STYLES SHOWN, UNLESS APPROVED OTHERWISE.

NOT ALL MATERIALS DEPICTED ON ALL LEGEND ARE USED IN THE DRAWINGS. WHERE A SPECIFIC CONDITION WAS DETAILED. IT WAS UNDERSTOOD THAT ALL LIKE OR SIMILAR CONDITIONS ARE THE SAME UNLESS SPECIFICALLY NOTED OR DETAILED OTHERWISE

CONTRACTOR RESPONSIBLE FOR ALL TEMPORARY PROTECTION & TEMPORARY BRACING THROUGHOUT THE EXTENTS OF THE SCOPE OF WORK. THIS SHALL BE DOCUMENTED BY THE CONTRACTOR & PROVIDED TO METRO-NORTH FOR REVIEW & APPROVAL.

#### UTILITIES

- THE WORK.

PRIOR TO THE START OF ANY EXCAVATIONS ON MNR PROPERTY THE CONTRACTOR TO FOLLOW RESTRICTIONS IN SPECIFICATION 011400 AND 021219.

- AND INVERTS.
- REGARDING CONFINED SPACE ENTRY.

#### CONCRETE

- OTHERWISE NOTED (UON)
- CONCRETE IS PLACED.
- SHALL LAP BE LESS THAN 12".
- 6. GROUT SHALL BE 5,000 PSI, NON-SHRINK TYPE, UON.

- A TEMPLATE.
- 10. FOR CONCRETE FINISH, SEE TECHNICAL PROVISIONS.
- BE CUT SHALL BE HOOKED AT OPENING.





1. THE CONTRACTOR SHALL MAINTAIN ALL EXISTING UTILITIES AND SERVICES THROUGHOUT THE EXECUTION OF

2. PRIOR TO THE START OF ANY EXCAVATION ON NON MNR PROPERTY, THE CONTRACTOR SHALL VERIFY THE LOCATION OF EXISTING UNDERGROUND UTILITIES WITHIN THE AREA OF THE WORK. THE CONTRACTOR SHALL CONTACT THE "UNDERGROUND FACILITIES PROTECTIVE ORGANIZATION" AT 1-800-962-7962 AND ANY OTHER AFFECTED UTILITY COMPANIES FOR UTILITY MARK-OUT PRIOR TO THE COMMENCEMENT OF THE WORK.

THE CONTRACTOR SHALL CONDUCT EXPLORATORY TEST PITS AS MAY BE REQUIRED TO DETERMINE, OR VERIFY UNDERGROUND CONDITIONS AND UTILITY LOCATIONS.

MARK-OUT ALL UTILITIES, COORDINATE WITH ALL UTILITY OWNERS FOR ALL REMOVAL AND DISCONNECTION WORK, IF ANY, INCLUDING RELOCATION OF EXISTING UTILITIES AND ASSOCIATED OVERHEAD UTILITY LINES. THIS WORK SHALL BE COMPLETED PRIOR TO THE COMMENCEMENT OF ANY EXCAVATION OR DEMOLITION WORK. THE CONTRACTOR SHALL COORDINATE ALL WORK WITH AND OBTAIN ALL NECESSARY PERMITS OR APPROVALS FROM APPROPRIATE UTILITY COMPANIES, GOVERNMENT AGENCIES AND MNR.

5. WHERE CONSTRUCTION CROSSES OR IS ADJACENT TO EXISTING UTILITY LINES OR IS WITHIN A 10 FT RADIUS OF AN EXISTING ELECTRICAL SERVICE LINE, THE CONTRACTOR SHALL CAREFULLY HAND EXCAVATE SO AS TO LOCATE, MARK AND PROTECT THE UTILITY LINES AGAINST DISTURBANCE OR DAMAGE BY PROVIDING ADEQUATE SUPPORT AND PROTECTION AS APPROVED BY THE UTILITY OWNER AND MNR.

EXERCISE CAUTION IN THE AREA OF THE EXISTING UTILITIES, ALL UTILITY LOCATIONS SHOWN ON THE DRAWINGS ARE APPROXIMATE ONLY, BASED ON AVAILABLE INFORMATION. THE CONTRACTOR SHALL ASSUME ALL RESPONSIBILITY FOR DETERMINING THE EXACT LOCATIONS OF ALL UTILITIES OF THE RAILROAD, LOCAL MUNICIPALITIES, UTILITY COMPANIES AND PRIVATE OWNERS. THE CONTRACTOR SHALL TAKE ALLPRECAUTIONS, INCLUDING DIGGING TEST PITS AND USING HAND EXCAVATION; AND SHALL BE RESPONSIBLE FOR THE PROTECTION OF ALL UTILITIES DURING ALL CONSTRUCTION OPERATIONS, THE CONTRACTOR SHALL BE RESPONSIBLE FOR IMMEDIATE RESTORATION TO SERVICE AND FACILITATE DAMAGE REPAIR SHOULD ANY SERVICE INTERRUPTIONS OCCUR AS A RESULT OF THE CONTRACTOR'S OPERATIONS.

THE CONTRACTOR SHALL RECORD MEASUREMENTS TO ALL UTILITY CONNECTIONS AND PROVIDE MARKED-UP AS-BUILT PLANS FOR ALL UTILITIES SHOWING TIES TO CONNECTIONS, BENDS, VALVES, LENGTHS OF LINES,

8. ALL CONFINED SPACE ENTRIES WILL BE MADE IN STRICT ACCORDANCE WITH OSHA REGULATIONS

1. ALL CONCRETE SHALL HAVE A 28 DAY MINIMUM COMPRESSIVE STRENGTH OF f'c = 4,000 PSI, UNLESS

2. ALL STEEL REINFORCEMENT BARS SHALL BE DEFORMED, ASTM A615, GRADE 60, GALVANIZED IN ACCORDANCE WITH ASTM A767, EXCEPT WHEN PERFORMING REPAIRS TO EXISTING CONSTRUCTION WHERE EPOXY REINFORCING WAS USED OR UNLESS NOTED OTHERWISE

3. DRAIN PIPES, PIPE SLEEVES, ELECTRICAL CONDUITS AND EMBEDDED PARTS SHALL BE IN POSITION BEFORE

4. ALL SPLICES IN REINFORCEMENTS SHALL COMPLY WITH THE REQUIREMENTS OF ACI 318-14, BUT IN NO CASE

5. SHIFT OR BEND REINFORCING TO CLEAR ANCHOR BOLTS, DRAINS, PIPE SLEEVES AND EMBEDDED PARTS.

7. EXPANSION AND CONTROL JOINTS IN CONCRETE STRUCTURES OTHER THAN DESCRIBED IN THESE DOCUMENTS WILL NOT BE PERMITTED UNLESS APPROVED BY THE DESIGN ENGINEER.

EXPOSED CONCRETE CORNERS SHALL BE CHAMFERED 3/4". UNLESS NOTED OTHERWISE.

9. ANCHOR BOLTS SHALL BE LOCATED AND SET PLUMB TO WITHIN 1/16" AND HELD RIGIDLY IN PLACE BY MEANS OF

11. ADDITIONAL REINFORCEMENT SHALL BE PROVIDED ALL AROUND OPENINGS AT LEAST 12" IN ANY DIRECTION. THE MINIMUM AREA OF STEEL EACH FACE SHALL BE EQUAL TO THE AREA OF THE CUT BARS. EXISTING BARS TO

	100% RFC SU	BMISSI	ON	
	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733		
Railroad		SCALE	DATE <b>08/03/2021</b>	
	GENERAL NOTES	DRAWING NO.		
		SCD-G	-201	
	SCARSDALE STATION	SHEET <b>3</b> O	F <b>112</b>	

## **GENERAL NOTES:**

#### STRUCTURAL STEEL

- REFER TO PROJECT SPECIFICATIONS FOR STRUCTURAL STEEL REQUIREMENTS FOR THE VARIOUS DESIGN ELEMENTS (SECTIONS 051000, 053000, 053110, 055000 & 055200).
- 2. ALL STRUCTURAL BOLTS SHALL BE IN CONFORMANCE WITH ASTM A325, TYPE 1 SC, UON. ALL CONNECTIONS SHALL BE DETAILED AS SHOP WELDED AND FIELD BOLTED CONNECTIONS, UON ON THE CONTRACT DRAWINGS. STRUCTURAL BOLTS SHALL HAVE A MINIMUM SIZE OF 3/4" DIAMETER, UON. THE END CONNECTION USED SHALL BE BASED ON THE END REACTION INDICATED FOR THE BEAM SIZE AND THE SPAN PROVIDED IN THE CURRENT AISC MANUAL, PART 2 "UNIFORM LOAD CONSTANTS FOR BEAMS LATERALLY SUPPORTED", OR THE LEAST NUMBER OF BOLTS, WITH A MINIMUM OF 2 BOLTS IN THE STANDARD CONNECTION, WHICHEVER PROVIDES THE LARGEST CONNECTION.
- STRUCTURAL STEEL WIDE FLANGE BEAM TO BEAM CONNECTIONS SHALL BE SHOP ASSEMBLED, USING DOUBLE CLIP ANGLES, TO FORM A LARGER UNIT FOR SHIPPING AND ERECTION; UON. FIELD WELDING SHALL BE MINIMIZED. EXCEPT WHERE SHOWN ON THE CONTRACT DRAWINGS.
- DESIGN, FABRICATION AND ERECTION OF STRUCTURAL STEEL SHALL BE IN ACCORDANCE WITH THE AISC SPECIFICATIONS, AREMA SPECIFICATIONS AND THE CONTRACT DRAWINGS. THE FABRICATOR SHALL BE AN AISC CERTIFIED FABRICATOR (SIMPLE BUILDINGS).
- SIZES AND LOCATIONS OF PIPE SLEEVES, CONDUITS AND OTHER OPENINGS IN SLABS OR FLOORS NOT SHOWN ON THE STRUCTURAL DRAWINGS SHALL BE ESTABLISHED BY FILED VERIFICATION AND IN CONJUNCTION WITH THE DESIGN DRAWINGS OF THE OTHER DISCIPLINES.
- WHERE FIELD WELDING IS INDICATED, THE SHOP COAT OF PAINT SHALL BE OMITTED FOR A DISTANCE OF 3 INCHES BACK FROM THE WELDED EDGE. FIELD WELDING SHOULD MINIMIZED TO LOCATIONS WHERE SPECIFIED ON THE CONTRACT PLANS ONLY.
- GROUT UNDER BASE PLATES SHALL BE 1 INCH MINIMUM. UON.
- THE CONTRACTOR SHALL PROVIDE TEMPORARY BRACING FOR ERECTION, IF REQUIRED. AND AS DIRECTED BY RESIDENT ENGINEER AND OR MNR REPRESENTATIVE AS REQUIRED AT NO ADDITIONAL COST TO MNR.
- DIMENSIONS AND LOCATIONS OF STRUCTURAL MEMBERS AND EMBEDDED ITEMS REQUIRED FOR PENETRATIONS AND SUPPORT SHALL BE COORDINATED AND VERIFIED WITH EQUIPMENT MANUFACTURERS AND APPROVED SHOP DRAWINGS PRIOR TO ERECTION.
- 10. STRUCTURAL STEEL SURFACES, INCLUDING BOLTS AND WELDS, SHALL BE GIVEN ONE COAT OF PRIMER IN ACCORDANCE WITH THE PROCEDURES AS SPECIFIED IN THE AISC MANUAL AND THE CONTRACT DOCUMENTS. PRIMER TO BE APPLIED ONLY AFTER CONNECTION IS COMPLETED, UNLESS NOTED OTHERWISE.
- 11. IF REAMING THE HOLES EXCEED TOLERANCES REQUIRED BY THE AISC MANUAL, THE CONTRACTOR SHALL PREPARE THE HOLE FOR THE NEXT LARGER DIAMETER BOLT AND INSTALL A LARGER DIAMETER BOLT AT THAT LOCATION, AT NO ADDITIONAL COST TO MNR. ALL EFFECTED HOLES TO BE SUBSEQUENCE PRIMED AND PAINTED
- 12. BOLTS SHALL NOT BE REUSED. BOLTS AND UNPAINTED STEEL IN A JOINT SHALL BE PAINTED WITH PRIMER IMMEDIATELY AFTER A CONNECTION IS ACCEPTED
- 13. WHERE FILLET WELD SIZES ARE NOT SHOWN ON CONTRACT DRAWINGS, MINIMUM SIZE OF FILLET WELD SHALL BE PROVIDED AS PER AISC SPECIFICATIONS.
- 14. ALL ACCESSORIES SUCH AS SLAB BOLSTERS, CHAIRS AND SPACERS IN CONTACT WITH EXPOSED SURFACES SHALL HAVE PLASTIC COATED TIPS.
- 15. ALL ANCHOR BOLTS SHALL BE 316 STAINLESS STEEL CONFORMING TO ASTM A320 UNLESS NOTED OTHERWISE.

#### STEEL DECK

- 1. STEEL DECK SHALL CONFORM TO THE "SPECIFICATION FOR DESIGN OF COLD-FORMED STEEL STRUCTURAL MEMBERS (AISI)": "SPECIFICATION FOR STRUCTURAL STEEL BUILDINGS (AISC 360-16)": "STRUCTURAL WELDING CODE - STEEL (AWS D1.3-10)", AND THE "MANUAL OF CONSTRUCTION WITHS TEEL DECKS (STEEL DECK INSTITUTE)".
- 2. STEEL DECK PANELS SHALL BE FORMED STEEL SHEETS CONFORMING TO ASTM A653, GRADE 40 SS, WITH A MINIMUM YIELD POINT OF 40,000 PSI (GALVANIZED G90 COATING). STEEL DECK SHALL BE PLACED SO AS TO BE CONTINUOUS OVER A MINIMUM OF THREE SPANS UNLESS NOTED OTHERWISE ON THE CONTRACT DOCUMENTS.
- 3. STEEL DECK SHALL BE ERECTED AND FASTENED IN ACCORDANCE WITH THE APPROVED STEEL DECK ERECTION LAYOUTS. AND ALL THE APPLICABLE RECOMMENDATIONS OF THE STEEL DECK INSTITUTE MANUAL OF CONSTRUCTION WITH STEEL DECK.
- 4. STEEL DECK SHALL BE CONNECTED TO THE SUPPORTING STEEL BY ARC PUDDLE WELDS AT LEAST <sup>3</sup>/<sub>4</sub> INCH IN DIAMETER, OR ELONGATED, HAVING AN EQUAL PERIMETER. UNLESS OTHERWISE APPROVED AND NOTED. SEE SPECIFICATION FOR REQUIRED MINIMUM SPACING.
- 5. WELDING OF STEEL DECK SHALL PENETRATE ALL LAYERS OF DECK MATERIAL AT END LAPS AND SIDE JOINTS AND HAVE GOOD FUSION TO THE SUPPORTING STEEL MEMBERS
- 6. ALL OPENINGS LARGER THAN 6" THROUGH STEEL ROOF DECK SHALL BE FRAMED WITH STEEL SUPPORT MEMBERS AS SHOWN ON THE CONTRACTOR DOCUMENTS. ACTUAL SIZE AND LOCATION OF OPENINGS SHALL BE COORDAINTED WITH ALL OTHER TRADES.
- 7. STEEL DECK AND ITS ANCHORAGE SHALL BE CAPABLE OF WITHSTANDING A MINIMUM NEW UPLIFHT FORCE OF 15 PSF WITHOUT CONSIDERING DEAD LOADS.

DESIGNED	SED	OF NEW MAN										CONFORMED				
DRAWN	TJB	S S B D C														
CHECKED	SED	10000000 SHE	NO.	DATE			DRWN	СНКД	APPVD	NO.	DATE		DRWN	CHKD	APPVD	- 22 - Ne
APPROVED	JSH	ROFESSIONAL			F	REVISION						REVISIO	N			

#### STEEL DECK CONT'D

- STEEL DECK SHALL BE GALVANIZED ON ALL SURFACES AND PAINTED ON EXPOSED SURFACES. UNLESS NOTED OTHERWISE.
- COMPOSITE DECKS SHALL BE GALVANIZED ON BOTH SIDES, AND PAINTED ON THE BOTTOM SIDE ONLY. 9
- DECK DEFLECTION: DEFLECTION OF THE DECK SHALL NOT EXCEED 1/240 OF THE SPAN OR 1 INCH. 10. WHIEVER IS LESS UNDER THE UNIFORML DISTRIBUTED DESIGN LIVE LOAD. SPANS ARE TO BE CONSIDERED AND MEASURED FROM CENTER TO CENTER OF SUPPORTS.

#### DEMOLITION:

- DEMOLITION AND SITE CLEARING INCLUDES BUT IS NOT LIMITED TO THE REMOVAL OF TREES, BRUSH, ROOTS, DEBRIS, VEGETATION, POLES, VAULTS, FOOTINGS, UTILITIES, PAVEMENT, FENCES AND ALL OTHER ITEMS REQUIRED TO CONSTRUCT THE CONTRACT WORK AS SHOWN ON THE PLANS. AND AS DIRECTED BY RESIDENT ENGINEER AND OR MNR REPRESENTATIVE AS REQUIRED AT NO ADDITIONAL COST TO MNR.
- 2. DO NOT ALLOW DEMOLISHED OR REMOVED MATERIALS TO DROP, FALL OR IMPACT AGAINST STRUCTURES TO REMAIN OR FOUL RAILROAD TRACKS. PROTECT ALL STRUCTURES TO REMAIN FROM DAMAGE OF ANY KIND.
- 3. REMOVE ALL DEMOLISHED MATERIAL PROMPTLY FROM THE SITE. ASPHALT SHALL BE SAW CUT WITH SUITABLE POWER-DRIVEN EQUIPMENT, AND PRE-CUT WITH A POWER SAW.
- 4. THE CONTRACTOR IS TO PROVIDE ALL TEMPORARY SIGNAGE DURING CONSTRUCTION AS SHOWN ON THE CONTRACT STAGING PLANS AND AS DIRECTED BY MNR. COORDINATION WITH THE VILLAGE AND OR TOWNS AND PARKING AUTHORITIES REQUIRED ADVANCE NOTICE.

#### PROTECTION OF WORK, PROPERTY AND PERSONNEL:

- THE CONTRACTOR SHALL PROVIDE BARRIERS TO KEEP PEDESTRIAN AREAS AND TRACK AREAS CLEAN AND FREE FROM CONSTRUCTION DEBRIS AT ALL TIMES: PROVIDE DUMPSTERS FOR DEBRIS REMOVAL. THE WORK AREA SHALL BE CLEANED AT THE END OF EACH WORK DAY.
- 2. ALL CONTRACTOR AND SUBCONTRACTOR PERSONNEL ARE REQUIRED TO ATTEND A SAFETY ORIENTATION GIVEN BY MNR (REFER TO SPECIFICATION SECTION 013529). PROOF OF ATTENDANCE AT THIS SAFETY TRAINING SHALL BE CONSPICUOUSLY DISPLAYED AT ALL TIMES WHILE ON MNR PROPERTY. THE CONTRACTOR IS ADVISED THAT CERTAIN ACTIVITIES WILL REQUIRE MNR PROTECTIVE PERSONNEL OR TRACK OUTAGES. REFER TO ARTICLE 1.22 FOR ADDITIONAL INFORMATION CONCERNING REQUIREMENTS FOR WORK WITHIN OR ADJACENT TO THE MNR RIGHT-OF-WAY.
- THE CONTRACTOR SHALL FURNISH AND INSTALL SCAFFOLDING FOR USE AS A SHIELD AND A WORK 3. PLATFORM FOR THE WORK AS SHOWN IN THE CONTRACT DRAWINGS. PRIOR TO INSTALLATION, SUBMIT TO MNR FOR APPROVAL, A SCAFFOLD/SHIELD DESIGN SIGNED AND SEALED BY A NY STATE PROFESSIONAL ENGINEER IN ACCORDANCE WITH MNR REQUIREMENTS.
- THE CONTRACTOR SHALL FURNISH TEMPORARY BARRIERS, WHICH ARE TO BE SOLID WALL, RIGID, FIXED, TRACK SHIELDING SAFETY STRUCTURES. THESE BARRIERS ARE TO BE CONSTRUCTED ALONG ALL LENGTHS SHOWN ON THE CONTRACT DRAWINGS ALONG THE WORK ZONE TO PROTECT TRAINS AGAINST INTERFERENCE AND TO PROTECT PEDESTRIANS AND WORKERS FROM FOULING THE TRACKS. INCLUDING FOULING FROM FALLING TOOLS, MATERIALS AND OTHER OBJECTS DURING CONSTRUCTION PRIOR TO INSTALLATION. A WORK ZONE PROTECTION DESIGN PLAN SIGNED AND SEALED BY NY STATE PROFESSIONAL ENGINEER IN ACCORDANCE WITH RAILROAD REQUIREMENTS; MUST BE SUBMITTED TO MNR FOR APPROVAL.
- 5. ALL WORK WITHIN 15 FEET OF THE CENTERLINE OF TRACKS WILL REQUIRE AT LEAST ONE MNR FLAGMAN. USE OF EQUIPMENT THAT MAY FALL WITHIN THIS THRESHOLD. OR ANY OTHER CONDTION. CIRCUMSTANCE OR SITUATION THAT MAY PRESENT. IN THE OPINION OF A QUALIFIED RAILROAD EMPLOYEE, DANGER TO THE SAFE MOVEMENT OF TRAINS WILL ALSO REQUIRE AT LEAST ONE MNR FLAGMAN.
- PRIOR TO ANY EXCAVATION, INSTALLATION OF SHEETING, SHORING OR ANY OTHER WORK WITHIN THE RAILROAD RIGHT-OF-WAY, A WORK PLAN INCLUDING DRAWINGS AND PROCEDURE OF WORK MUST BE SUBMITTED TO AND APPROVED BY MNR. AND AN SOE (SUPPORT OF EXCAVATION PLAN) THAT IS PE STAMPED AND COOPER E-80 REQUIREMENT WITH 6 WEEKS ADVANCED NOTICE.
- THE CONTRACTOR WILL PROTECT EXISTING SURVEYING AND PROPERTY LINE MARKINGS/MONUMENTS. ANY EXISTING SURVEY MARKER THAT IS DISTURBED OR DESTROYED, AS JUDGED BY THE ENGINEER OR MNR. WILL BE REPLACED AT THE CONTRACTOR'S EXPENSE UNDER THE SUPERVISION OF A NY STATE LICENSED LAND SURVEYOR.

#### CONCRETE MASONRY

- REFER TO THE SPECIFICATIONS AND TO THE ARCHITECTURAL DRAWINGS FOR TYPE AND GRADES OF MATERAISL REQUIRED AND FOR LOCATIONS OF CMU WALLS.
- 2. ALL MASONRY WORK SHALL CONFORM TO THE LATEST EDITIONS OF THE NATIONAL CONCRETE MASONRY ASSOCIATION (NCMA), OF THE BRICK INSTITUE OF AMERICA (BIA) SPECIFICATIONS, AND ACI 530/530.1 BUILDING CODE REQUIREMENT AND SPECIFICATIONS FOR MASONRY STRUCTURAS, AS APPLICABLE.
- ALL CONCRETE MASONRY UNITS (CMU) SHALL CONFORM TO ASTM C90, GRADE N-1, WITH AN INDIVIDUAL 3. COMPRESSIVE STRENGTH OF 3750 PSI, WITH F'M=2500 PSI.
- 4. MORTAR FOR BLOCK WALLS SHALL BE TYPE M OR S, CONFORMING TO ASTM C270.





- 2500 PSI AT 28 DAYS.
- NOTED OTHERWISE.

- 10.

11. VERTICAL CELLS CONTAINING REINFORCEMENT AND GROUT SHALL FORM A CONTINUOUS CAVITY, FREE OF JOINT MORTAR DROPPINGS.

BELOW.

#### CONCRETE MASONRY CONT'D

GROUT FOR BLOCK WALLS SHALL CONFORM TO ASTM C476, WITH A COMPRESSIVE STRENGTH OF

ALL CONCRETE MASONRY UNITS SHALL BE BRACED DURING CONSTRUCTION UNTIL PERMANENT RESTRAINTS HAVE BEEN INSTALLED.

REINFORCING STEEL: FY=60 KSI, ASTM A615. REINFORCING STEEL SHALL BE GALVANIZED UNLESS

REINFORCE AND GROUT CMU WALLS IN LIFTS NOT TO EXCEED 4 FEET HIGH.

PROVIDE BOND BEAMS AT A VERTICAL SPACING NOT TO EXCEED 8 FEET ON CENTER AND WHERE NEEDED TO ACT AS A LINTEL IN ALL REINFORCED CMU WALLS AND WHERE INDICATED FOR NON-REINFORCED CMU WALLS AS SHOWN IN THE ARCHITECTURAL DRAWINGS, AND IN ACCORDANCE WITH THE SPECIFICATIONS, UNLESS OTHERWISE NOTED ON THE DRAWINGS.

BUILD NEW CMU WALLS INTEGRALLY WHEN THEY INTERSECT.

12. LIFTS OF GROUT SHALL BE KEYED IN 3 INCHES INTO THE PREVIOUS COURSES OF MASONRY

	10070111000	DIVINUU		
	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733		
Railroad	IMPROVEMENTS GENERAL NOTES	SCALE	DATE <b>08/03/2021</b>	
	GENERAL NOTES	DRAWING NO.		
		SCD-G	-202	
	SCARSDALE STATION	SHEET <b>4</b> O.	F 112	

100% REC SURMISSION

## ARCHITECTURAL LINEWORK


BUILDING LINE	_//////////////////////////////////////
IRON FENCE	oo
PLATFORM HANDRAIL	<u>D</u> D
CHAIN LINK FENCE	XX
CURB LINE	
DEMOLITION	
CONTOUR LINE (MAJOR)	103
CONTOUR LINE (MINOR)	
CENTER LINE	
RIGHT-OF-WAY LINE	
PROPERTY LINE	
PROPERTY OUTBOUND	
HEDGE ROW	
WOODS LINE	
APPROX BRIDGE EDGE	• • • • • • • • • • • • • • • • • • •
TREE & TRUNK DIAMETER	(DECIDUOUS) (DECIDUOUS)

## UTILITY SYMBOLS:

00	DOUBLE POST SIGN	
$\overline{\mathbf{O}}$	TRAFFIC SIGN	XFX
•	GENERAL SIGN	- L PS
$\square^{PM}$	PARKING METER	
$\circ^{cc}$	COAL CHUTE	
ΓF	FIRE CALL BOX	
TB	TRAFFIC CONTROL BOX	
MB	HOUSE MAIL BOX	
Μ	POSTAL MAIL BOX	
T	PAY PHONE BOOTH	
🖂 EB	ELECTRIC BOX	
O FILL	OIL FILL	
O FILL ⊕	OIL FILL MONUMENT	
_		
$\pm$	MONUMENT STANDPIPE OR	
∀	MONUMENT STANDPIPE OR SPRINKLER	
∀	MONUMENT STANDPIPE OR SPRINKLER FIRE HYDRANT	
⊕ ₪	MONUMENT STANDPIPE OR SPRINKLER FIRE HYDRANT UNKNOWN BOX	
	MONUMENT STANDPIPE OR SPRINKLER FIRE HYDRANT UNKNOWN BOX UNKNOWN GRATE	
	MONUMENT STANDPIPE OR SPRINKLER FIRE HYDRANT UNKNOWN BOX UNKNOWN GRATE UNKNOWN VAULT	
	MONUMENT STANDPIPE OR SPRINKLER FIRE HYDRANT UNKNOWN BOX UNKNOWN GRATE UNKNOWN VAULT OIL VENT BOX	

## **REFERENCE SYMBOLS**


ΧХ



MAIN PLATFORM BENT NUMBER

## MATERIAL PATTERNS

BRICK	
CONCRETE BLOCK	
CONCRETE	
GRANITE AND LIMESTONE	
CAULKING	
WOOD BLOCKING	



			ABBRE	VIATIONS:								
STREET LIGHT W/ PEDESTRIAN SIGNAL STREET LIGHT W/ TRAFFIC SIGNAL	(E)       ELECTRICAL M         (F)       NYFD MH         (G)       GAS MH         (S)       SANITARY MH         (D)       STORM MH         (SI)       SUBWAY MH         (T)       TELEPHONE M         (U)       UNKNOWN MH         (W)       WATER MH         (W)       ROUND DRAIN         (W)       ROUND DRAIN         (W)       SQUARE DRAIN         (W)       CO         (CO       <	MH 1 LET LET N IN	AAB. AcT Ac.F.L. Ac.MAS. A.D. A.Dr. ADJ. A.F.F. A.F.G. ALUM. APP'D. APPROX. ARCH. ASSEM. AUX. & Z @BB.C. BD. B.E.S. B.L. BLD'G. BLK. BM. B.O. 	CONCRETE CONVECTOR CLASSROOM CAST STONE	CASE E     SADDLE     K	H.C. HDCP HGT. H.K.E. H.M. HORIZ. H.P. H.R. HR. HR. H&V I.D. IG. INV. INSUL. J.S.C. KP. L. LAB. LAV. L.G. LKR. L.P. L.S. LT. L.W.C.B. M./ MTL. MA.	GAUGE GALVANIZED GLAZED BLOCK GENERAL CONTRACTOR GLAZED DISPLAY BOARD GALVANIZED IRON GLASS GRILLE GRADE ELEVATION GRANITE GLAZED TILE GAS VALVE GYPSUM WALL BOARD HIGH HUNG CEILING HANDICAPPED HEIGHT HEAVY KITCHEN EQUIPMENT HOLLOW METAL HORIZONTAL HIGH POINT HAND RAIL HOUR HEATING & VENTILATION INSIDE DIAMETER INTERIOR WIRE MESH GUARD INVERT INSULATION JANITOR'S SINK CLOSET KICKPLATE LEADER LABORATORY LAVATORY LEGAL GRADE LOCKER LOW POINT LOUDSPEAKER LIGHT LIGHTWEIGHT CONCRETE BL METAL METAL METAL	S T	R.       F         RAIL'G.       F         RAD.       F         R.C.O.       F         REC.       F         REINF.       F         RET.       F         REV.       F         RM.       F         R.M.S.       F         R.O.       F         RUB.       F         R.P.Z.       F         S.       SAD.         SAN. SB.       SECT.         SH./SHELV'G.       SHT.         SIM.       SECT.         SH./SHELV'G.       SHT.         SIM.       SECT.         ST.       ST.         ST.       ST.         ST.       ST.         STD.       STL.         STD.DET.       STOR.         STU.       ST.         ST.       SO.         T.       T.A.O.         T.B.O.       T         TEL.       TERR.         T.F. / T.O.F.       T         T.L.       T.O.         T.L.       T.O.         T.L.       T.O.         T.L.       T.O.         T.L.       <	ROOF DRAIN RECESS REINFORCEMEN RETAINING REVEAL ROOM RAISED MARBLE ROUGH OPENIN RUBBER REDUCED PRESS SINK SADDLE SPRAY APPLIED SANITARY SECU SECTION SHELVING SHEET SIMILAR SLEEVE SPACE SPACE SPACE SPACE SPACE SPACE SPACE STANDARD STEEL STANDARD STEEL STANDARD STEEL STANDARD STEEL STANDARD STEEL STANDARD DET STORY SQUARE YARD SOLDIER TOILET TYPE "A" OPENI TOP AND BOTTO TOP OF CURB TOP OF DRAIN TELEPHONE TERRAZZO TOP OF FENCE THICKNESS TRUCK KICK PL TEACHER'S LOO TRIMMED OPEN	E SADDLE G SURE ZONE P FIRE RESISTIVE M JRITY BARRIER EL AIL NG NG OM	
Image: Display black with the second sec	(OR)	KEN STONE GRAVEL T JLATION SHED OD	C.T. CU.FT. DBL. DEP. DEPT. DET. D.F. DIA. DIM. DISP. CAB. DN. DR. DWG. E E E.B.P. E.G. E.J./ EXP. JT. EL./ELEV. ELEC. ENCL. ENT. EQ. EQUIP. ERD. EXP. EXIST. F F. F. F. E.R. F.L. F.L. F. E.R. F. E.R. F. E.R. F. E.R. F. E.R. F. E.R. F. E.R. F. E.R. F. E.R. F. E.R. F. E.R. F. E.R. F. E.R. F. E.R. F. F. F. F. F. F. F. F. F. F. F. F. F.	CERAMIC TILE CUBIC FEET DOUBLE DEPRESSED DEPARTMENT DETAIL DRINKING FOUNTAIN DIAMETER DIMENSION DISPENSER DISPLAY CABINET DOWN DOOR DRAWING EXPOSED BLOCK PAINTED ESTABLISHED GRADE EXPANSION JOINT ELEVATION ELECTRIC ENCLOSURE ENTRANCE EQUAL EQUIPMENT EMERGENCY ROOF DRAIN EXPANSION EXISTING FIXED FLUID-APPLIED PROTECTED MEMBRANE ROOFING FURED CEILING FLUSH CONCRETE CURB FLOOR DRAIN FIRE EXTINGUISHER RECESS FIRE HYDRANT FINISH FLOOR FLASHING FLUSH MARBLE SADDLE FOUNDATION FIRE PROOF SELF CLOSING FRAME FLOOR SINK FIRE STANDPIPE FLUSH TREAD FOOTING	N O P Q	MAG. MAR. MAT. MAX. M.C. M.C.R. M.&C. CAB. MECH. M.F. M.H. MIN. M.O. MOV. M.S. N.D. N.I.C. NO. NOM. N.T.S. O.A.I. O.C. O.D. OF.D. OP'G. P. PART. PART. PAV. P&D PERF. PLAT. P.L.V. PRES. PT. C.B. P.L. / PROP. LINE Q.T.	MAGAZINE MARBLE MATERIAL MAXIMUM MATERIAL CABINET MATERIAL CABINET RECESS MATERIAL & CHART CABINET MECHANICAL METAL FURRING MANHOLE MINIMUM MASONRY OPENING MOVABLE METAL STRIP NOMINAL DIAMETER NOT IN CONTRACT NUMBER NOMINAL NOT TO SCALE OUTSIDE AIR INTAKE ON CENTER OUTSIDE DIAMETER OVERFLOW DRAIN OPENING PAINT PARTITION PAVEMENT PLUMBING AND DRAINAGE PERFORATED PLATFORM PLASTIC LAMINATED VENEE PRESENT PAINTED CONCRETE BLOCK PROPERTY LINE	U V	TR.         T.S.         T.V.S.         T.W. / T.O.W.         T.Y.O.         TYP.         U.         U.O.N.         V. /VIN.         V.C.T.         VERT.         VERT.         VERT.         VERT.         VERT.         VERT.         VERT.         VERT.         VEST.         V.I.T.         V.W.C.         W.H.         WAINS.         W.C.         WD.         W.F.         W.H.         W.M.G.         W.P.         WT.         W.V.	WEEPHOLE WROUGHT IRC WIRE MESH WIRE MESH GU WATERPROOF WEIGHT WELDED WIRE WATER VALVE	SADDLE NG WISE NOTED ITION TILE ATED TREOUS TILE VERING TR DR) WIDE FLANGE N JARD ING FABRIC	ON
	DRWN CHKD	APPVD	225 PARK AVENUE SOUTH, NEW YORK, NY 10003	V Jears	420 Le	<b>ro-Nor</b> exington Ave ork, NY 100		HARTSDALE AND S IMPROVEMENTS			CONTRACT NO. 1000106733 SCALE DRAWING NO.	DATE 08/03/202

REVISION

021 LEGEND & ABBREVIATIONS DRAWING NO. SCD-G-203 SCARSDALE STATION SHEET **5** OF **112** 

MNR - SCARSDALE TRAIN STATION CONSTRUCTION				
CODE DATA: GENERAL REQUIREMENTS				

I. CONSTRUCTION CODES

- BUILDING CODE 2015 NEW YORK STATE BUILDING CODE (IBC 2015) W/ 2017 SUPPLEMENTS
- 2015 NEW YORK STATE EXISTING BUILDING CODE (IEBC 2015) FIRE/LIFE SAFETY CODE 2018 NEW YORK STATE FIRE CODE (IFC 2015)
- ACCESSIBILITY CODE
- 2010 NEW YORK STATE ADA 2010 ADA STANDARDS FOR ACCESSIBLE DESIGN (ADAAG 2004) DEPARTMENT OF TRANSPORTATION ADA STANDARDS FOR
- TRANSPORTATION FACILITIES
- ENERGY CODE 2016 NEW YORK STATE ENERGY CONSERVATION CONSTRUCTION CODE (2015 IECC/ASHRAE 90)
- MECHANICAL CODE
- 2018 INTERNATIONAL MECHANICAL CODE (IMC 2018) ELECTRICAL CODE
- NATIONAL ELECTRIC CODE 2017 (NFPA 70)
- ELEVATOR CODE\* ASME A17.1 SAFETY CODE FOR ELEVATORS AND ESCALATORS (2013)

II. REFERENCES

- ASCE 7 MINIMUM DESIGN LOADS and ASSOCIATED DESIGN CRITERIA for BUILDINGS AND OTHER STRUCTURES
- ASCE 24 FLOOD RESISTANT DESIGN AND CONSTRUCTION
- FEMA GUIDELINES AND STANDARDS POLICY FLOOD RISK ANALYSIS
- AND MAPPING USACE DESIGN MANUAL

III. STANDARDS

- MNR STATION DESIGN STANDARDS and GUIDELINES, 2018
- MNR SIGNAGE MANUAL CURRENT VERSION
- MNR CODE COMPLIANCE MANUAL
- IV. REGULATIONS
- FEDERAL RAILROAD ADMINISTRATION (FRA) REGULATIONS OCCUPATIONAL SAFETY AND HEALTH (OSHA) REGULATIONS

\*REFER TO VERTICAL TRANSPORTATION NOTES – ELEVATOR REQUIREMENTS

MNR – SCARSDALE TRAIN STATION CONSTRUCTION CODE DATA - CODE REVIEW - 2015 NYS BUILDING CODE

	USE AND OCCUPA			
SECTION	TITLE	REQUIRED	PROVIDED	NOTES
303	ASSEMBLY GROUP A	A-3	A-3	-
SECTION	TITLE	REQUIRED	PROVIDED	ONS NOTES
	TITLE BUILDING	REQUIRED AS PER		
SECTION	TITLE BUILDING HEIGHT AND	REQUIRED AS PER TABLE 504.3,	PROVIDED	
SECTION	TITLE BUILDING	REQUIRED AS PER	PROVIDED	

	HEIGHT AND NUMBER OF STORIES (ALLOWABLE)	TABLE 504.3, HEIGHT = 55 FT		
SECTION	TITLE	REQUIRED	PROVIDED	NOTES
504	BUILDING	AS PER	2 STORIES	-
	HEIGHT AND	TABLE 504.4,		
	NUMBER OF	STORIES		
	STORIES	= 2 STORIES		

SECTION	TITLE	REQUIRED	PROVIDE	NOTES
004				
601	GENERAL			-
		601, TYPE IIB	NON-	
		NON-	COMBUST	
		COMBUSTIBLE	IBLE	
		PRIMARY	0	-
		STRUCTURE = 0	-	
		BEARING WALL ,	0	-
		EXT = 0		
		BEARING WALL,	0	-
		INT = 0		
		NON-BEARING		SEE TABLE
		EXT WALLS		602
		NON-BEARING INT	0	-
		WALLS = 0		
		FLOOR CONSTR =	0	-
		0		
		ROOF CONSTR = 0	0	-
SECTION	TITLE	REQUIRED	PROVIDE	NOTES
			D	
602	CONSTRUCTION	AS PER TABLE	FIRE	-
	CLASSIFICATION	602, FIRE	RESISTAN	
		RESISTANCE	CE	
		RATING FOR TYPE	RATING =	
		IIB = 0	0	
	SEPARATION	DISTANCES - SEE TA	ABLE 602	
		X < 5 1	1	ELEVATOR
				MACHINE
				ROOM
		5 < X <10 1	N/A	
		10 < X < 30 0	0	ELEVATOR
				HOISTWAY
		X > 300 0	N/A	

CHAPTER 7 - FI	RE AND SMOKE F	PROTECTIONFE	ATURES	
SECTION	TITLE	REQUIRED	PROVIDED	NOTES
705.2	PROJECTIONS	AS PER TABLE 705.2	N/A	-
707.3.1	FIRE RATING, SHAFT ENCLOSURE	AS PER 713.4, FIRE RESISTANCE RATING FOR LESS THAN 4 STOREIS = 1	N/A	-
707.4	EXTERIOR WALL, SHAFT ENCLOSURE	AS PER 704, FIRE RESISTANCE RATING FOR LESS THAN 4 STOREIS = 1	0	-
CHAPTER 8 - IN	NTERIOR FINISHE	s		
SECTION		REQUIRED	PROVIDED	NOTES
803	WALL AND CEILING FINISHES	AS PER 803.1, ASTM E84 or UL	COMPLY	-
CHAPTER 9 - FI	RE PROTECTION	SYSTEMS		
SECTION	TITLE	REQUIRED	PROVIDED	NOTES
903.2.1.3	AUTOMATIC SPRINKLER SYSTEM - GROUP A-3			-
		IF > 12,000 SF	NOT REQUIRED	-
		IF > 300 OCCUPANTS	NOT REQUIRED	-
		IF FIRE AREA OTHER THAN DISCHARGE LEVEL	NOT REQUIRED	-
903.3.1.1.1	AUTOMATIC SPRINKLER EXEMPTION	-	-	FIRE DETCETION SYSTEM, AS PER 907.2
907.2.1	MANUAL FIRE ALARM BOXES	-	-	REQUIRED
CHAPTER 10 - I		SS		
SECTION	TITLE	REQUIRED	PROVIDED	NOTES
1009.3	ACCESSIBLE	STAIR WIDTH	-	EXISTING

SECTION	TITLE	REQUIRED	PROVIDED	NOTES
1009.3	ACCESSIBLE MEANS OF EGRESS REQUIRED - STAIRS	STAIR WIDTH = 48 IN. MIN	-	EXISTING CONDITION N/A
1009.4	ACCESSIBLE MEANS OF EGRESS REQUIRED - ELEVATORS	STAIR WIDTH = 44 IN. MIN	-	EXISTING
1011.3	HEADROOM (STAIRWAYS)	STAIR HEADROOM = 80 IN.MIN.	-	EXISTING
1011.5.2	RISER HEIGHT/TREAD DEPTH (STAIRWAYS)	R = 7 IN MAX / 4 IN MIN T = 11 IN MIN	-	EXISTING
1011.5.4	DIMENSIONAL UNIFORMITY (STAIRWAYS)	.375 PER FLIGHT	-	EXISTING
1011.6	LANDING (STAIRWAYS)	MATCH STAIR WIDTH AND DEPTH, NOT EXCEED 48 IN	-	EXISTING
1011.7.1	WALKING SURFACE (STAIRWAYS)	1:48 MAX SLOPE	-	EXISTING
1011.8	VERTICAL RISE BETWEEN LEVELS (STAIRWAYS)	12 FT MAX	-	EXISTING
1011.11	HANDRAILS (STAIRWAYS)	COMPLY WITH SECTION 1014	-	EXISTING
1014	HANDRAILS (STAIRWAYS)	HEIGHT 34IN – 38 IN / FULLY CONTINUOUS / EXTENSIONS (TOP/BOTTOM) 12 IN/12 IN	-	EXISTING

#### CHAPTER 13 - ENERGY EFFICIENCY

ENERGY REQUIREMENTS 2016 NYS ECC (2015 IECC/ASHRAE 90)

CHAPTER 4 - COMMERICAL ENERGY EFFICIENCY AS PER SECTIONS C401 & C402 BUILDING ENVELOPE REQUIREMENTS

		i			1		1	1	i	1	<b>—</b>
DESIGNED	SED	OF NE WE									-
DRAWN	TJB	PHEL MOST									-
GUEGHED	150	S HOLE									
CHECKED	SED	960159 V	NO.	DATE		DRWN	CHKD	APPVD	NO.	DATE	
APPROVED	JSH	PROFESSIONAL CONTINUES			REVISION						

HAPTER 24 - G	LASS AND	GLAZ	ING

SECTION	TITLE	REQUIRED	PROVIDED	NOTES	
2409.2	GLASS IN	LAMINATED,	COMPLY	-	
	ELEVATOR	CONFORMING			
	HOISTWAY	TO ANSI Z97.1			
	ENCLOSURES	OR CPSC			
		16CRF PART			
		1201			
<u>CHAPTER 30 - C</u>	ONVEYING DEV			1	
SECTION	TITLE	REQUIRED	PROVIDED	NOTES	
3005.4	MACHINE	FIRE RATING	1 HR	-	
	ROOMS	NOT LESS			
		THAN THE			
		HOISTWAY			
		(MIN. 1 HR)			
3005.6	PLUMBING	NOT	N/A	-	
	SYSTEMS	PERMITTED			
		IN EMR			
N/A	SMOKE	NO LOUVERS	N/A	-	
	VENTING	REQUIRED -			
		N/A			
*REFER TO ASME A17.1         SAFETY CODE FOR ELEVATORS AND ESCALATORS					

2015 NYS EXISTING BUILDING CODE

(2013)

CLASSIFICATION OF WORK	
LEVEL 1 ALTERATION:	REMOVAL AND REPLACEMENT OR COVERING OF EXISTING MATERIALS, ELEMENTS, EQUIPMENT OR FIXTURES USING NEW MATERIALS, ELEMENTS, EQUIPMENT, OR FIXTURES THAT SERVE THE SAME PURPOSE
ADDITIONS TO EXISTING BUILDINGS:	EXTENSION OF INCREASE IN FLOOR AREA, NUMBER OF STORIES, OR HEIGHT OF A BUILDINGS OR STRUCTURE
HISTORICAL BUILDINGS:	LISTED, OR CERTIFIED AS ELIGIBLE FOR LISTING, BY THE STATE HISTORIC PRESERVATION OFFICER, WORK INCLUDING REPAIR, ALTERATION, RELOCATION AND CHANGE OF OCCUPANCY

CONFORMED				
				225 PARK AVENUE SOUTH,
	DRWN	CHKD	APPVD	NEW YORK, NY 10003



#### REFERENCE


SECTION 503, CHAPTER 7

SECTION 507, CHAPTER 11

SECTION 508, CHAPTER 12

	100% RFC SU	BMISSI	ON
	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733	
Railroad		SCALE	DATE <b>08/03/2021</b>
	CODE COMPLIANCE -	DRAWING NO.	
	GENERAL	SCD-G	-301
	SCARSDALE STATION	SHEET 6 O.	F 112

#### WHEELCHAIR TURNINGSPACES:



## WHEELCHAIR CLEAR FLOOR SPACES:

## INTERNATIONAL SYMBOL OF ACCESSIBILITY:


CONFORMED					
					Motro Nor
					(MA) Metro-Nor
				225 PARK AVENUE SOUTH,	420 Lexington Aven
					New York, NY 1001
	DRWN	CHKD	APPVD	NEW YORK, NY 10003	
REVISION					









	100% RFC SU	BMISSI	ON
	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733	
Railroad		SCALE	DATE <b>08/03/2021</b>
	ADA CLEARANCES, FLOOR SPACES & MANEUVERING	DRAWING NO.	200
	REQUIREMENTS scarsdale station	SCD-G	F 112




54'53"W O'				
S51° 54' 53"W 68.000' S1° 36' 43.72"W 51.148' N8° 41' 14"E 68.290' L=72.645, R=423.863 $\Delta=9.8198$	BRONX	RIVER		
$ \begin{array}{c} N13^{\circ} 052^{\circ}54^{\circ}2W_{23}"E \\ 14.480^{\circ}7.380' \\ L=84.289, R=80.000 \\ \Delta=60.3675 \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \$	100 180° 48' 37.38"W 1.468', V <sup>8°</sup> 58; 1918/1° 01' 50"W			
197.960'	42:000 2.500' 752' 31.650' 72 40"W S0: 17' 23 62"Will 50' 40"55 22 24	3.000' 43.576' 1' 14.85"W LOT 260.124'		
LOT 500 N8 40' 14"E 260.940' SECK 6 LOT 3 N8 40' 14"E 151.982' M8 40' 14"E 61.000' M8 40' 14"E 151.982' OT 50' N8' 58' 10"F 12.500' N81' 19' 46"E N8' 40' 14"E 151.982' N8' 58' 10"F 151.980' N8' 58' 10"F 151.980'	0.1	LOT. 523.500' LOT 7.1	500 N65' 07' 02"E 150.793'	
EAST	PARKWAY			
N8° 47' 09.70"E BLOCK 5 482.020'		BLOCK 5		
SPENCER ER			CR/	
			100% RFC SL	
CONFORMED	$STV_{100}$	Metro-North Railroad	TITLE HARTSDALE AND SCARSDALE STATION IMPROVEMENTS	CONTRACT         NO.           1000106733         DATE           SCALE         DATE
DRWN CHKD APPVD	AVENUE SOUTH, RK, NY 10003	420 Lexington Avenue New York, NY 10017	SITE PLAN	N.T.S.         08/03/2021           DRAWING NO.         000000000000000000000000000000000000
REVISION			SCARSDALE STATION	<b>SCD-G-303</b> SHEET <b>8</b> OF <b>112</b>



		MNR PLATFORM MNR PLATFORM STATION INBOUND TRACK (TO NEW YORK)		
	EAST PKWY			
1 EXIST 1"=20'	<u>NG STATION SITE PLAN</u>		LEGEND PROPERTY LINE 100% RFC SU	IBMISSION
CONFORMED IN INTERPORTED	225 PARK AVENUE SOUTH, NEW YORK, NY 10003	Metro-North Railroad 420 Lexington Avenue New York, NY 10017	TITLE HARTSDALE AND SCARSDALE STATION IMPROVEMENTS EXISTING STATION SITE PLAN SCARSDALE STATION	CONTRACT NO.         1000106733         SCALE       DATE         1/32" = 1'-0"       08/03/2021         DRAWING NO.       SCD-C-100         SHEET 9       OF 112











	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733				
Railroad	IMPROVEMENTS	SCALE AS NOTED	DATE <b>08/03/2021</b>			
	CIVIL PLAN	DRAWING NO.				
		SCD-C-101				
	SCARSDALE STATION	SHEET <b>10</b> 0.	F <b>112</b>			




	``														
	/ /														
	/								```	y g			JNTY		
												PROF	PERTY	,	
/															*
										LAG			Ì		
										ARSE OPE					
	[?e]				Ĵ	R						e.L.	Č.	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	
											Am				
														///	
					-										
											•	<u> </u>		•	
* 9	L]	L1	.6	L1		L1		n 89	[J]		[I]			MN	IR RO
										][_					
							VILLA	AGE (	) DF		1	× / /	×	*	× /
<u> </u>			<u> </u>	2 A B D			SCAF PRO								
							ġ.				<u> </u>	Mh	<u> </u>	<u> </u>	
DESIGNED	JS	annun an	NEW												
DRAWN CHECKED	CJ	NICH TO NOT	o start												
APPROVED	JS MM	PROFES	15.5. EH	NO.	DATE			REV	ISIC		DRWN	CHKD	APPVD	NO.	DATE





#### NOTES:


- 1. PROVIDE FENCE OR BARRICADE TO PREVENT UNAUTHORIZED ACCESS













♦ STV	100
225 PARK AVENUE SOUTH, NEW YORK, NY 10003	Jeans

	DRWN	CHKD	APPVD
$D T U I \cap U$			

## GENERAL ARCHITECTURAL NOTES

- ALL WORK INCLUDED IN THIS CONTRACT SHALL CONFORM TO ALL MUNICIPAL. STATE. NATIONAL AND OTHER CODES. REGULATIONS AND RESTRICTIONS WHICH APPLY TO THIS PROJECT INCLUDING THE FEDERAL "AMERICANS WITH DISABILITIES ACT" (ADA).
- 2. ALL WORK SHALL BE OF HIGH QUALITY, PERFORMED IN A NEAT WORKMANLIKE MANNER. EXECUTED IN ACCORDANCE WITH THE BEST ACCEPTED TRADE PRACTICES AND AS PER MANUFACTURER'S RECOMMENDATIONS AND WARRANTY REQUIREMENTS.
- ALL WORK SHALL FOLLOW ESTABLISHED WORKING POINT, AS OUTLINED ON DRAWINGS, GC TO VERIFY WORKING POINTS AND COORDINATE WITH ALL DISCIPLINE DRAWINGS PRIOR TO ANY DEMOLITION AND NEW WORK. ANY DISCREPANCIES SHALL BE BROUGHT UP TO ENGINEER AND METRO NORTH RAILROAD FOR REVIEW. REFER TO STRUCTURAL DWGS FOR ALL WORK STARTING POINTS.
- 4. GC SHALL PROVIDE PHASING PLAN AND SCHEDULE TO ENCOMPASS ALL DEMOLITION AND NEW WORK. PHASING PLAN SHALL INCLUDE GC'S MEANS AND METHODS FOR ALL DEMOLITION AND NEW WORK, ESTABLISHING SAFE WORKING CONDITIONS AND NOT IMPEDE ON NORMAL STATION OPERATIONS. INCLUDING PASSENGER STATION ACCESS. GC'S PHASING PLAN SHALL BE SUBMITTED TO METRO NORTH RAILROAD FOR REVIEW AND APPROVAL PRIOR TO WORK COMMENCING.
- ALL INDICATED ELEMENTS ARE "NEW" UNLESS OTHERWISE INDICATED BY SUCH 5 TERMINOLOGY AS "EXISTING", "TEMPORARY", "ABANDONED", "REFURBISHED", ETC.
- ALL MATERIALS AND WORK REQUIRED SHALL BE NEW UNLESS OTHERWISE NOTED.
- 7. THE WORDS "REMOVE", "REMOVAL", "DISCARD", "DISPOSE OF" SHALL INCLUDE THE COMPLETE REMOVAL AND LEGAL DISPOSAL OF THE INDICATED MATERIAL OR EQUIPMENT OFF THE SITE BY CONTRACTOR. EXCEPT WHERE SUCH MATERIAL OR EQUIPMENT IS INDICATED OR DIRECTED BY METRO NORTH RAILROAD TO BE SALVAGED OR STORED FOR RE-INSTALLATION. ALL REQUIRED STORAGE AND PROTECTION SHALL BE AT CONTRACTOR'S EXPENSE. CONTRACTOR TO COORDINATE POTENTIAL FOR SALVAGING DEMOLITION MATERIAL WITH METRO NORTH RAILROAD.
- THE CONTRACTOR SHALL PROTECT AND PRESERVE ALL EXISTING ITEMS TO REMAIN, ALL 8 WORK FROM HAND-OVER OR PRECEDING CONTRACTS, OWNER FURNISHED EQUIPMENT AND FIXTURES: AND REPAIR OR REPLACE ANY ITEMS DAMAGED DURING THE COURSE OF THE WORK TO THE SATISFACTION AND APPROVAL OF METRO NORTH RAILROAD.
- 9. ANY DAMAGE TO INSTALLED FINISHES OR EQUIPMENT CAUSED BY THE WORK OF THE CONTRACTOR SHALL BE REPLACED AND REINSTALLED BY THE CONTRACTOR TO THE SATISFACTION AND APPROVAL OF METRO NORTH RAILROAD.
- 10. THE CONTRACTOR SHALL PATCH ALL AREAS AFFECTED OR EXPOSED BY REMOVALS WORK TO MATCH EXISTING AND/OR ADJACENT SURFACES TO THE APPROVAL OF METRO NORTH RAILROAD. PATCHING OF ALL AREAS AFFECTED SHALL ALSO MAINTAIN THE ASSEMBLY AND/OR SYSTEM INTEGRITY AND PERFORMANCE OF THE ORIGINAL CONSTRUCTION.
- 11. ALL FIRE-RATED DOORS AND PENETRATIONS THROUGH FLOOR. WALL AND/OR CEILINGS SHALL COMPLY TO APPLICABLE CODE REQUIREMENTS OF (TEMPERATURE) T-RATINGS AND UL-LISTED THROUGH PENETRATION FIRE STOP SYSTEM ASSEMBLIES.
- 12. ALL FIRE-RATED PARTITIONS/WALLS SHALL EXTEND TO THE UNDERSIDE OF THE STRUCTURAL FLOOR. BEAM OR ROOF SLAB – UNLESS NOTED OTHERWISE: AND SHALL BE FIRE-STOPPED TO SAME HOURLY RATING. ALL PENETRATIONS SHALL BE SEALED AND PROTECTED IN ORDER TO MAINTAIN THE INTEGRITY OF THE FIRE-RATED PARTITIONS/WALLS.
- 13. THE CONTRACTOR SHALL NOTIFY ENGINEER OF ANY AND ALL DISCREPANCIES BETWEEN EXISTING CONDITIONS, INCLUDING INSTALLED WORK AND THE CONTRACT DOCUMENTS BEFORE PROCEEDING WITH THAT PORTION OF THE WORK. FAILURE TO NOTIFY ENGINEER WILL NOT RELIEVE THE CONTRACTOR OF RESPONSIBILITY TO PERFORM THE WORK AS INTENDED BY THE CONTRACT DOCUMENTS.

- 14. THE CONTRACTOR SHALL CORRECT ANY AND ALL WORK ARISING FROM DISCREPANCIES IN THE CONTRACT DOCUMENTS AND TO THE COORDINATING ALL WORK AMONG THE VARIOUS TRADES.
- 15. WHERE THERE ARE DISCREPANCIES IN THE CONTRACT DRAWINGS BETWEEN DISCIPLINES OR WHERE WORK IS SHOWN ON THE DRAWINGS FOR ONE DISCIPLINE BUT NOT ANOTHER. THE CONTRACTOR SHALL PERFORM THE MOST COMPLETE AND STRINGENT REQUIREMENT SHOWN AND AS DIRECTED BY METRO NORTH RAILROAD. METRO NORTH RAILROAD SHALL BE NOTIFIED OF ALL SUCH DISCREPANCIES BEFORE COMMENCING THE WORK.
- 16. THE CONTRACTOR SHALL BE RESPONSIBLE FOR AND SHALL CHECK AND VERIFY ALL DIMENSIONS AND JOB CONDITIONS IN THE FIELD. THE CONTRACTOR SHALL NOTIFY ENGINEER OF ANY DISCREPANCIES PRIOR TO COMMENCING CONSTRUCTION, SUBMITTING SURVEY FILES, SUBMITTING OF SHOP DRAWINGS, PLACING ORDERS, AND/OR FABRICATING EQUIPMENT DURING THE COURSE OF THE CONTRACT
- 17. DO NOT SCALE DRAWINGS. FOLLOW WRITTEN DIMENSIONS ONLY FOR CONSTRUCTION. DIMENSIONS SHOWN ARE NORMALLY GIVEN TO:
  - A. COLUMN OR GRID CENTER LINES
  - B. FACES OF EXPOSED CONCRETE SURFACES
  - AND/OR ARCHITECTURAL FINISHED WALLS. FLOORING AND CEILINGS

  - C. FINISH FACE OF PARTITIONS, EXPOSED CMU WALLS, FURRING (AS NOTED), D. MINIMUM VERTICAL OR HORIZONTAL "HOLD" CLEARANCE REQUIREMENTS E. CENTER LINE OF TRACK
  - F. TOP OF RAIL (TOR)
  - G. ABOVE FINISH FLOOR (AFF) U.O.N.
- 18. GEOMETRIC LAYOUT INFORMATION:
  - SLABS. SEE THE STRUCTURAL DRAWINGS.
  - A. FOR LAYOUT OF STRUCTURAL WALLS, COLUMNS, BEAMS, STRUTS AND
  - LINES IN ALL ELEMENTS OF THE STATION ARE TRUE VERTICAL
  - B. ALL HORIZONTAL DIMENSIONS SHOWN ARE TRUE HORIZONTAL C. ALL VERTICAL DIMENSIONS ARE MEASURED TRUE VERTICAL. ALL VERTICAL
  - D. ALL STRUCTURAL HORIZONTAL LINES, WALLS, OPENINGS AND SURFACES
  - SHALL BE AS INDICATED ON THE STRUCTURAL DRAWINGS.
- 19. ALL PLAN DIMENSIONS SHALL BE COORDINATED BETWEEN ALL DISCIPLINE DRAWINGS. DIMENSIONS NOT SHOWN ON ARCHITECTURAL CONTRACT DRAWINGS, REFER TO STRUCTURAL DRAWINGS.
- 20. COORDINATE WITH CIVIL, STRUCTURAL, MECHANICAL, ELECTRICAL, PLUMBING, FIRE PROTECTION, TRACTION POWER, AND COMMUNICATIONS DRAWINGS FOR THE EXTENT AND LOCATION OF ALL OPENINGS, ARCHITECTURAL FINISHES, SLEEVES, CHASES, WALL AND FLOOR SLAB PENETRATIONS, ETC. ALL PIPES AND CONDUITS PASSING THROUGH MASONRY AND/OR CONCRETE PARTITIONS/STRUCTURES SHALL BE SLEEVED.
- 21. CONTRACTOR SHALL EXAMINE CONTRACT DRAWINGS OF ALL TRADES TO VERIFY AND COORDINATE THE LOCATION OF FIXTURES, EQUIPMENT, DUCTWORK, CONDUITS, PULL-BOXES, PENCIL BOXES, ROUGH-OUTS, ROUGH OPENINGS, ACCESS PANELS AND BOXES, BUILT-INS, METRO NORTH RAILROAD-FURNISHED EQUIPMENT CONTRACTOR INSTALLED FIXTURES AND OTHER RELATED WORK FOR THE CONSTRUCTION OF THE PROJECT.
- 22. WHERE THE PROGRESS OF THE WORK INTERFERES WITH A MEANS OF EGRESS FROM AN EXISTING BUILDING OR STRUCTURE, THE CONTRACTOR SHALL PROVIDE A TEMPORARY MEANS OF EGRESS SUBJECT TO THE APPROVAL OF METRO NORTH RAILROAD AT NO COST TO THE OWNER.
- 23. REFER TO STRUCTURAL DRAWINGS FOR ALL LINTELS FOR MASONRY OPENINGS REQUIRED FOR DUCTS, GRILLES, DAMPERS, LOUVERS, ACCESS HATCHES, DOOR OPENINGS, WALL OPENINGS, COMMUNICATIONS, HVAC, MECHANICAL, ELECTRICAL, PLUMBING AND FIRE PROTECTIONS EQUIPMENT. SEE ARCHITECTURAL AND ALL RELATED ENGINEERING DRAWINGS FOR OPENING SIZES AND SPANS, LOCATIONS AND DETAILS.

DESIGNED	PL											CONFORMED				
	ΓL	OISTERED ARC	1													
DRAWN		ALCAUL N. LOTA														
	VD	* or A FF														
CHECKED																225 PARK NEW YOF
CHECKED	EC	1 Berner L	NO.	DATE			DRWN	СНКД	APPVD	NO.	DATE		DRWN	CHKD	APPVD	NEW YOF
		OF NEW YOR						-						-		
APPROVED		001202			REVIS	SION						REVISION				
	PL	012/2000				1011										

- H. METRO NORTH RAILROAD VEHICLE CAR CLEARANCE ENVELOPE

- 24. WHERE RECESSES, OFFSETS AND CHASES ARE SHOWN IN WALL PARTITIONS, THE EXACT SIZE OF THE OPENING REQUIRED SHALL BE DETERMINED BY THE INSTALLATION ITEM TO BE ACCOMMODATED. THE CONTRACTOR SHALL COORDINATE THE WORK WITH ALL OTHER TRADES.
- 25. FOR SIZE, EXTENT AND LOCATION OF OPENINGS, SLEEVES, CHASES AND OTHER PENETRATIONS (i.e. RACEWAYS, CONDUITS, MECHANICAL AND UTILITY DUCTS, PIPING, ETC. AND THROUGH WALLS AND FLOORS. SEE RELATED STRUCTUAL. MECHANICAL. ELECTRICAL, PLUMBING AND FIRE PROTECTION DRAWINGS FOR ADDITIONAL INFORMATION.
- 26. FOR LIGHTING FIXTURE TYPES, SEE ELECTRICAL LIGHTING PLANS. COORDINATE LOCATIONS WITH ARCHITECTURAL REFLECTED CEILING PLANS (RCP), MECHANICAL EQUIPMENT, FIRE ALARM, CCTV AND COMMUNICATIONS DEVICES.
- 27. PRIOR TO INSTALLATION, THE CONTRACTOR SHALL SUBMIT ALL APPROVED SHOP DRAWINGS, COORDINATION SHOP DRAWINGS, TESTING & COMMISSIONING REPORTS, MOCK-UPS, COLORS AND FINISHES TO METRO NORTH RAILROAD FOR APPROVAL.
- 28. THE CONTRACTOR SHALL SUBMIT COORDINATED DRAWINGS OF TEMPORARY PARTITIONS AND BARRICADES WITH LOCATIONS AND DETAILS FOR THE REVIEW AND APPROVAL BY METRO NORTH RAILROAD.
- 29. THE CONTRACTOR SHALL PROVIDE ALL MOCK-UPS REQUIRED BY THE CONTRACT DOCUMENTS IN A TIMELY MANNER AND IN LOCATION(S) AS DIRECTED BY METRO NORTH RAILROAD. APPROVED MOCK-UPS CAN BE INCORPORATED INTO THE WORK BY APPROVAL OF METRO NORTH RAILROAD.
- 30. ALL STEEL ITEMS SHALL BE HOT DIPPED GALVANIZED UNLESS OTHERWISE NOTED.
- 31. ALL EMBEDMENTS AND DRILLED-IN-PLACE ANCHORS SHALL BE TYPE 316 STAINLESS STEEL – UNLESS OTHERWISE NOTED.
- 32. ALL MASONRY UNITS RECEIVING ANCHOR BOLTS, STRAPS, AND REBARS SHALL BE FILLED SOLID WTH 3,000 PSI GROUT. SEE STRUCTURAL DRAWINGS FOR ADDITIONAL INFORMATION.
- 33. PROVIDE ALL BLOCKING. SEPARATION AND ANCHORAGE AS REQUIRED FOR CODE-COMPLIANT WORK.
- 34. ALL PROPOSED WOOD COMPONENTS (INCLUDING BUT NOT LIMITED TO SHEATHING, TRIM AND BLOCKING) SHALL BE FIRE-RATED.
- 35. ALL DISSIMILAR METALS IN CONTACT WITH EACH OTHER SHALL BE ISOLATED IN A MANNER AS REQUIRED BY APPLICABLE CODE, METRO NORTH RAILROAD DESIGN GUIDELINES AND PRACTICES, AND AS APPROVED BY ENGINEER.
- 36. WHERE DISSIMILAR METALS ARE JOINED, METAL SURFACES SHALL BE ADEQUATELY SEPARATED TO PREVENT GALVANIC ACTION AND CORROSION.
- 37. THE CONTRACTOR SHALL PAINT ALL SURFACES. INCLUDING BUT NOT LIMITED TO: EXPOSED WALLS (WITH NO FINISH ASSEMBLY), EXPOSED CEILINGS (WITH NO SUSPENDED ASSEMBLY), EXPOSED STRUCTURAL COLUMNS, PIPES, CONDUIT, AND MISCELLANEOUS METALS – UNLESS OTHERWISE NOTED IN THE FINISH SCHEDULE OR AS INDICATED ON THE CONTRACT DRAWINGS.
- 38. DOORS SHALL BE INSTALLED TO ENSURE PROPER AND CLEAR DOOR SWING INTO OR OUTWARD OF THE ROOM COORDINATING THE HINGE SIDE OF DOOR ASSEMBLY WITH THE (LOW POINT) FINISH FLOOR ELEVATION AND MAKING REQUIRED ADJUSTMENT TO ACCOMMODATE DOOR SWING PATH.
- 39. ALL CMU COURSING SHALL BE CONSTRUCTED (LAID) HORIZONTALLY LEVEL. USE CONCRETE LEVELING CURB AS NECESSARY TO ENSURE MINIMUM CUT CMU COURSES. CUT CMU BASE COURSE IS NOT ACCEPTABLE.
- 40. BOND BEAM COURSES MUST BEAR ON FULL CMU COURSING. CUT CMU BEARING COURSE IS NOT ACCEPTABLE.
- 41. ALL CMU ROOM LAYOUTS ARE PERPENDICULAR (90-DEGREES) IN PLAN AT CORNERS OR TEE-INTERSECTION – UNLESS OTHERWISE NOTED.





- 42. PROVIDE SMOOTH AND UNMARRED CONCRETE WALL SURFACES IN AREAS INDICATED IN THE CONTRACT DRAWINGS AND SPECIFICATIONS.
- 43. ALL EXPOSED AREAS OF NEW WORK SUBJECT TO FOOT TRAFFIC SHALL BE SLIP RESISTANT. REFER TO SPECIFICATIONS.
- 44. MANUFACTURER'S NAME PLATES INCLUDING TRADEMARK AND OTHER IDENTIFICATION SYMBOLS SHALL NOT BE PERMITTED ON SURFACES VISIBLE TO THE PUBLIC - UNLESS OTHERWISE NOTED.
- 45. ALL VERTICAL JOINTS IN ARCHITECTURAL FINISHES, CONCRETE, ARCHITECTURAL CLADDING AND CMU SHALL BE TRUE VERTICAL UNLESS OTHERWISE NOTED.
- 46. SEAL AND CAULK AROUND ALL PENETRATIONS. CRACKS AND CREVICES AND ANY OPENINGS CAPAPBLE OF HARBORING INSECTS AND RODENTS.
- 47. ALL FLASHING DETAILS INCLUDING THICKNESS AND FASTENERS SHALL COMPLY WITH FM-GLOBAL 1-49
- 48. ALL HAND RAILS AND GUARD RAILS, SIGN BANDS, HORIZONTAL CONCRETE JOINTS, EDGE LIGHTS AND CEILINGS SHALL RUN PARALLEL AND UNIFORMLY VERTICAL TO THE FLOOR. ALL GUARDRAIL/HANDRAIL, BOTH TEMPORARY AND PERMANENT, SHALL FOLLOW THE METRO NORTH RAILROAD STATION STANDARDS AND GUIDELINES.
- 49. ALL EXPOSED COMPONENTS FOR THE INTERIOR AND EXTERIOR OF THE ELEVATOR HOISTWAY TOWER (ENCLOSURE) AND WALKWAY EXTENSIONS SHALL BE INSTALLED FOR MINIMAL APPEARANCE, INCLUDING CONDUITS, ROOF LEADERS AND OTHER MECHANICAL AND ELECTRICAL COMPONENTS. LOCATIONS OF ALL COMPONENTS SHALL BE REVIEWED AND APPROVED BY METRO NORTH RAILROAD.
- 50. ALL ROOF DRAINAGE FROM ELEVATOR TOWER/WALKWAY EXTENSION SHALL DRAIN FROM ROOF SCUPPER TO VERTICAL LEADERS AND DISCHARGE ONTO CONCRETE SPLASH BLOCKS AT GRADE.
- 51. FIRE PROOFING OF STRUCTURAL SUPPORT/UNDERSIDE OF METAL DECK AT ELEVATOR MACHINE ROOM/COMM. ROOM AND WALKWAY EXTENSIONS.
- 52. ALL SIGNAGE AS PER METRO NORTH STATION STANDARDS AND GUIDELINES.
- 53. ALL REPLACEMENT OVERPASS/CANOPY CLAY ROOF TILE AS PER METRO NORTH STATION SPECIFICATIONS.
- 54. ANTI-GRAFFITI COATING (MASONRY) AND FILM (GLAZING) SHALL BE APPLIED AS SHOWN ON ARCH. DWGS.
- 55. PERIMETER INSULATION, INCLUDING EXTERIOR WALLS, ROOF AND CONCRETE SLAB FOUNDATION AS PER METRO NORTH RAILROAD SPECIFICATIONS.
- 56. MASONRY CONTROL JOINTS SHALL BE INSTALLED AS INDICATED ON ARCH. DWGS.
- 57. EXTERIOR MASONRY AT EMR AND COMM. ROOM: 7 3/4" X 15 3/4" X 7 3/4" AND 7 3/4" X 7 3/4" X 7 3/4", TYPICAL MORTAR JOINTS 5/8".
- 58. LOUVER QUANTITY AND LOCATIONS SHALL BE INDICATED ON MECH. DWGS.
- 59. QUANTITY OF ANCHOR POINTS AND HORIZONTAL LIFE LINE FOR THE TIE-OFFS (FALL RESISTANCE LINKED SYSTEM) SHALL COMPLY WITH OSHA 1910.140 AND METRO-NORTH DESIGN GUIDELINES. CALCULATIONS FOR FALL ARREST CONFIGURATION TO BE PROVIDED BY SELECTED VENDOR. BASIS OF DESIGN: FLEXIBLE LIFELINE SYSTEMS OR APPROVED EQUAL.

	100% RFC SU	BMISSI	ON		
	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733			
Railroad		SCALE	DATE <b>08/03/2021</b>		
	GENERAL NOTES	DRAWING NO.			
		SCD-A			
	SCARSDALE STATION	SHEET <b>13</b> O	F_112		

#### VERTICAL TRANSPORTATION NOTES (ELEVATOR EQUIPMENT):

#### **GENERAL NOTES:**

- 1. THESE NOTES ARE FOR GENERAL INFORMATION ONLY. REQUIREMENTS OF INDIVIDUAL VENDORS MAY VARY.
- 2. FIELD VERIFY ALL EXISTING DIMENSIONS.
- 3. ROUGH OPENING DIMENSIONS FOR ELEVATOR ENTRANCES APPLY ONLY IN THE CASE OF MASONRY OR CONCRETE CONSTRUCTION.
- 4. VERTICAL STRUCTURAL SUPPORT FOR RAIL BRACKETING IS PROVIDED BY HOISTWAY WALLS IN THE CASE OF REINFORCED CONCRETE HOISTWAY CONSTRUCTION.
- 5. INFORMATION IN THIS SHEET IS PROVIDED BY THE ELEVATOR CONSULTANT.

#### SUMMARY OF ELEVATORS:

SCARSDALE STATION ELEVATOR W1 4000#

@125FPM

SCARSDALE SDS = 0.29

#### ELEVATOR ELECTRICAL AND MECHANICAL REQUIREMENTS

			POWER	FEEDER F	REQUIREM	IENTS (MA		R SUPPLY	: 208-3-60)	
					ЦУГ	RO STARTING A	MDS	FUU	LOAD AMPS	HEAT F
ELEVATOR	CAPACITY		TRACTION	HYDRO						
NUMBER	(POUNDS)	SPEED (FPM)	DRIVE HP RATING	MOTOR HP	LOCKED ROTOR	SOLID STATE	WYE DELTA	RUNNING	ACCELERATING	MACHINE SPACE (BTUH PER CAR)
W-1	4000	125	N/A	50	857	464	271	155	N/A	21,
					* HEAT RELE/	ASE BASED ON 8	0 UPSTARTS/HR			

#### NOTES:

1. ELECTRIC POWER AND CURRENT ARE BASED ON THREE (3) PHASE A.C. POWER SUPPLY.

2. MAIN POWER TO BE PROVIDED AT EACH CONTROLLER THROUGH DISCONNECTING MEANS MEETING NEC REQUIREMENTS 3. MAIN POWER SUPPLY FEEDERS TO LIMIT VOLTAGE DROP TO LESS THAN 5%.

- 4. USE COPPER CONDUCTORS ONLY.
- 5. FEEDER DEMAND FACTORS (NEC SECTION 430-26 AND 620-14)=

(2) CARS= 95% (3) CARS= 90% (4) CARS= 85% (5) CARS= 82% (6) CARS= 79% (7) CARS= 77%

(8) CARS= 75% (9) CARS= 73% (10) CARS= 72% 6. MACHINE SPACE TEMPERATURE TO BE MIN. 13° C (55° F.) (10° C /50° F. IN MASS.), MAX. 32° C (90° F).

- TO BE MEASURED 1838 MM (6'-0") ABOVE FINISH FLOOR AT APPROX. CENTER OF ROOM.
- 7. RELATIVE HUMIDITY MAX. 80% NON-CONDENSING.
- 8. THE SELECTION OF MAIN POWER SUPPLY DISCONNECTING MEANS OVERCURRENT PROTECTION TO BE SIZED IN ACCORDANCE WITH THE NATIONAL ELECTRIC CODE, SECTIONS 620-51 AND 430-52.

9. PROVIDE LOCAL TELEPHONE SERVICE LINE TO EACH CAR CONTROLLER (IF APPLICABLE). 10. PROVIDE GFCI CONVENIENCE OUTLETS PIT, MACHINE ROOM AND MACHINERY SPACES. IN PIT, PROVIDE ONE NON-GFCI OUTLET FOR SUMP PUMP AND/OR OIL RETURN PUMP.

11. PROVIDE HOIST MACHINE WITH VOLTAGE TO MATCH SUPPLY VOLTAGE INDICATED, U.N.O.

12. PROVIDE 20 AMPS DEDICATED CIRCUITES FOR OIL HEATERS AND OIL COOLERS.

ADDITIONA	L POWER AND DISCONNECT REQUIREMENTS IN MACHINE ROOM						
AUXILIARY SYSTEM	SUPPLY TERMINAL	SUPPLY VOLTAGE	<u>CIRCUIT (</u>				
CAR LIGHT AND FAN WITH LOCKABLE DISCONNECT	EACH CONTROLLER	120-1-60	(15 AMP I				
INTERCOM SYSTEM (IF APPLICABLE)	AT AMPLIFIER	120-1-60	1800 WATTS				
AIR CONDITIONING AND HEATING SOURCE (IF APPLICABLE)	EACH CONTROLLER	120-1-60	(20 AMP I				
CONDENSATE EVAPORATOR UNIT FOR AIR CONDITIONING (IF APPLICABLE)	EACH CONTROLLER	120-1-60	(30 AMP I				

DESIGNED PL	STERED APO								CONFORMED				
DRAWN VD	* Church The												
CHECKED EC		NO. DATE		DRWN	CHKD	APPVD	NO.	DATE		DRWN	CHKD	APPVD	225 PARK AVENUE SOUTH, NEW YORK, NY 10003
APPROVED PL	901212021		REVISION						REVISION				

<b>RAIL REACTIONS:</b>
------------------------

#### ASME A17.1

BUILDING SUPPORTS TO RESIST HORIZONTAL FORCES WITH A TOTAL DEFLECTIONS AT SUPPORT POINT NOT IN EXCESS OF 3 mm (1/8") UNDER NORMAL CONDITIONS.


- \* THESE REACTIONS DO NOT OCCUR SIMULTANEOUSLY WITH PIT BUFFER REACTIONS
- \*\* BUILDING SUPPORTS FOR GUIDE RAIL ATTACHMENT SHALL RESIST HORIZONTAL FORCES WITH A TOTAL DEFLECTIONS NOT IN EXCESS OF 6.5 mm (1/4") BASED UPON 0.5 G (0.25 G FOR UBC ZONE 2) ACCELERATION DURING SEISMIC CONDITIONS

#### <u>IBC</u>

SEISMIC DESIGN CATEGORY ASSUMPTION BASED ON HISTORIC SEISMIC CONDITIONS FOR PROJECT AREA:

SEISMIC DESIGN CATEGORY = B OCCUPANCY CATEGORY = A-3ELEVATOR IMPORTANCE FACTOR PER ELEVATOR (Ip) = 1.0 HARTSDALE SDS = 0.289

9	0	




T CAPACITY	

#### PER CAR)

- TS (15 AMP MIN)
- PER CAR)
- PER CAR)

RAII	L FORCES MA		ON EACH GUIDE RAIL (FORCES ARE IN KIPS)
	ELEVATOR NUMBER	W1	OCCURRING ON
FORCES	CAR R1	2	CAR NORMAL FACE OF MAIN RAIL
	CAR R2	2	CAR NORMAL SIDE OF MAIN RAIL - LOADING OR RUNNING
NORMAL	CAR R3	N/A	FORCE TRANSMITTED TO PIT STRUCTURE AT CAR SAFETY APPLICATION*
ASME A17.1 EISMIC ORCES	CAR R1	2.1	CAR SEISMIC ** FACE OF MAIN RAIL
ASI A1 SEIS FOR	CAR R2	1.1	CAR SEISMIC ** SIDE OF MAIN RAIL - LOADING OR RUNNING



1.	М
	IS
2.	Pl
	М
	El
3.	AI
	D
4.	V
_	R
5.	PI
~	R
6.	PI

ITEM CAR G

## MACHINE ROOM NOTES:

1. PROVIDE 200 mm X 200 mm (8" X 8") BLOCKOUT FOR HYDRAULIC OIL LINE, AND 150 mm X 150 n 6") BLOCKOUT FOR ELECTRICAL CONDUIT FOR EACH ELEVATOR. VERIFY LOCATION WITH ELE CONTRACTOR. 2. VERIFY PATH OF OIL LINE WITH ELEVATOR CONTRACTOR. THE MACHINE ROOM AND HO SHALL BE LOCATED ON THE SAME SIDE OF AN EXPANSION JOINT. 3. PROVIDE ADEQUATE LIGHTING TO MAINTAIN MIN. 200 LUX (19 FC) ILLUMINATION AT MACHINE FLOOR.

4. COORDINATE LIGHT FIXTURES AND UTILITY OUTLETS LOCATION WITH ELEVATOR CONTRACT 5. FOR EQUIPMENT IN THE MACHINE ROOM, A CLEARANCE OF NOT LESS THAN 450 mm (18") SF PROVIDED IN THE DIRECTION(S) REQUIRED FOR MAINTENANCE, AND A CLEAR PATH OF NC THAN 450 mm (18") SHALL BE PROVIDED TO ALL COMPONENTS THAT REQUIRE MAINTENANCE 6. PROVIDE 3-PHASE MAINLINE POWER FEEDER WITH DISCONNECTING MEANS FOR EACH ELE CONTROLLER. PROVIDE 1-PHASE FEEDER WITH DISCONNECTING MEANS FOR CAR LIC VENTILATION SYSTEM AND RECEPTACLE FOR EACH ELEVATOR. THESE DISCONNECTING SHALL INCLUDE OVERCURRENT PROTECTION, SHALL BE LOCATED IN THE MACHINE ROO SHALL MEET N.E.C. REQUIREMENTS.

8. 4" CURB RECOMMENDED.

### PIT NOTES:

KEY
А
В



Metro-North 420 Lexington Avenue New York, NY 10017

#### HOISTWAY NOTES:

MINIMUM TOTAL SMOKE VENTING REQUIRED AIR 3.0 SF OR 3.5 SF OF HOISTWAY AREA (WHIC GREATER) PER ELEVATOR (IF REQUIRED).

PROVIDE HOIST BEAM TO SUPPORT 8,500 # (LB). MAKE HOIST BEAM REMOVABLE IF NECESS MEET MINIMUM CLEAR DIMENSION. VERIFY HOIST BEAM LOCATION AND LOAD REQUIREMENT LEVATOR CONTRACTOR. ALL VERTICAL DIMENSIONS THAT ARE DIMENSIONED FROM A BUILDING FLOOR ELEVATIC

MENSIONED TO THE FINISH FLOOR ELEVATION. VERTICAL OR ADDITIONAL HORIZONTAL STRUCTURAL SUPPORT FOR RAIL BRACKET REQUIRED FOR CAR FULL HEIGHT OF HOISTWAY AND BOTH SIDES OF HOISTWAY. PROVIDE ADEQUATE STRUCTURAL SUPPORT AS REQUIRED FOR BUFFER AND HYDRAULIC CY

REACTIONS. PROVIDE MINIMUM 75<sup>0</sup> BEVEL GUARD AT ANY LEDGE GREATER THAN 100 mm (4") AT REAR ( WALLS OF HOISTWAY (TYP).

7. CONTRACTOR TO SUBMIT STEEL RAIL CONNECTION DETAILS AS SHOP DRAWINGS.

#### RAIL SUPPORT TABLE

LENGTH	CLEARANCE
14'-0"	MAXIMUM SPAN
	LENGTH 14'-0"

7. LOCATE MACHINE ROOM WITHIN 40'-0" OF HOISTWAY.

9. ELEVATOR CONTRACTOR PROVIDE PERMANENT MEANS TO ACCESS UNDERSIDE OF ( REQUIRED.

10. FIRE EXTINGUISHER IS REQUIRED IN EMR.

1. PROVIDE ADEQUATE LIGHTING TO MAINTAIN MINIMUM 100 LUX (10 FC) ILLUMINATION AT PIT 2. PROVIDE PIT ACCESS LADDER, LIGHT SWITCH(ES), LIGHT(S), AND GFCI-PROTECTED OUTLET(S).

3. PROVIDE 200 mm X 200 mm (8" X 8") BLOCKOUT FOR HYDRAULIC OIL LINE, AND 150 mm X 150 X 6") BLOCKOUT FOR ELECTRICAL CONDUIT FOR EACH ELEVATOR. VERIFY LOCATION ELEVATOR CONTRACTOR.

4. VERIFY PATH OF OIL LINE WITH ELEVATOR CONTRACTOR.

5. COORDINATE LIGHT FIXTURES AND UTILITY OUTLETS LOCATION WITH ELEVATOR CONTRAC 6. PROVIDE ADEQUATE STRUCTURAL SUPPORT AS REQUIRED FOR BUFFER AND HYD CYLINDER REACTIONS.


7. PROVIDE INDIRECT PIT DRAIN OR SUMP WITH GRATING COVER LEVEL WITH PIT FLOOR. 8. REACTIONS HAVE BEEN DOUBLED FOR IMPACT.

9. REACTIONS DO NOT OCCUR SIMULTANEOUSLY

#### PIT REACTION TABLE


REACTION (FORCES IN KIPS, K)	
28.0	
14.0 EACH	

	IBMISSION					
	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733				
Railroad		SCALE	DATE <b>08/03/2021</b>			
	GENERAL NOTES	DRAWING NO.				
		SCD-AG-002				
	SCARSDALE STATION	SHEET 14 OF 112				




$\left\{ \begin{array}{c} \circ \\ \circ \end{array} \right\}$	>			
	/			°
	WORKPOINT 2 @ CORN LOCATION TO BE VIF O -EXISTING PLATFORM	IER OF EXISTING PLA F CONTRACTOR	ATFORM.	
I		ī. — I		
			Q	
	EXISTING PLATFORM		(f)	
RCIAL)				
ED RIFY ELEVATIONS	AND DIMENSIONS IN F	IELD.		
FOR OVERPASS S	STRUCTURAL SEPARAT	TION DETAILS AND JA		
	TITLE HARTSDALE AND SCAR IMPROVEMENTS		CONTRACT N 1000106733 SCALE	0.
	STATION PLATF _EVEL DEMO PL		1/8" = 1'-0" DRAWING NO	08/03/2021
	SCARSDALE STATION		SHEET 15	

	LINE ABO STAI RAIS JACH	VE R T( ED.	O OV SEE	/ERP	PASS D-J-	S TC 105 I	DВ
	 SEPA LINE HIST	ARA OF ORI	TION	i — Sitno	G	۸L	
					<u>\</u>	<u>'IC</u>	<u>\</u>



	EXISTING PLA CANOPY BELC		
EW YORK)			
	EXISTING PLA BELOW		
RCIAL)			
R OVERPASS STRU	D DIMENSIONS IN FIELD. JCTURAL SEPARATION DE <b>10</b> <i>TITLE</i> HARTSDALE AND SCARS IMPROVEMENTS	0% RFC SI	S SEQUENCE. <b>UBMISSION</b> CONTRACT NO. 1000106733 SCALE DATE 1/8" = 1'-0" 08/03/2021
	STATION OVERP LEVEL DEMO PLA SCARSDALE STATION		<i>DRAWING NO.</i> <b>SCD-AD-111</b> <i>SHEET</i> 16 <i>OF</i> 112




2. REFER TO SCD-J-100 FOR OVERPASS STRUCTURAL SEPARATION DETAILS AND JACKING SEQUENCE.

♦ STV	100
225 PARK AVENUE SOUTH, NEW YORK, NY 10003	Jeaus

CONFORMED			
	DRWN	CHKD	APPVD
RFVISION			

100% RFC SUBMISSION
---------------------

	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733		
ailroad		SCALE 1/8" = 1'-0"	DATE <b>08/03/2021</b>	
	STATION DEMO ELEVATION AND SECTION	drawing no. SCD-AD-611		
	SCARSDALE STATION		F 112	




CONFORMED			
	DRWN	CHKD	APPVD


						<	
					6	RONT BILER,	
						PILEP	<u>^</u>
ATION NTY)		0		<b></b>		·	Thy .
		0	် စြ	0			
YORK)							
SSAIC)	<u>, , , , , , , , , , , , , , , , , , , </u>					<u></u>	
				· · · _ · · ·			
		80 0 0 80 0 0 90 0 0					}
							_
							/
ELEVATIONS AND	DIMENSIONS IN	FIELD.					
OVERPASS STRUC	CTURAL SEPARA	ATION DETAIL	S AND JAC	KING SE	QUENCE	Ξ.	
NATE KNOX BOX L	OCATION WITH	LOCAL FIRE	DEPARTME	NT.			
		1000	% RFC	<u>, 611</u>	RM		
					CONTRAC	CT NO.	V
ailroad	HARTSDALE AI		LE STATION	N	1000106 SCA1	LE	DATE
	STATION S	SITE PLA	N		1/32" =		/03/2021
						)- <b>A-</b> 0'	10

SCARSDALE STATION

SHEET **18** OF **112** 




CONFORMED	DRWN	СНКД	APPVD	225 PARK AVENUE SOUTH, NEW YORK, NY 10003	Metro-North 420 Lexington Avenu New York, NY 10017	е
REVISION						




CONFORMED			
	DRWN	CHKD	APPVD
REVISION			

)  (1)  (A-411)  (A-411)  (A-411)	(°) 2 (A-201)		
     CANOPY	G PLATFORM ' BELOW		
BELOW	G PLATFORM		
Railroad	TITLE HARTSDALE AND SCARS IMPROVEMENTS STATION OVERPA LEVEL PLAN SCARSDALE STATION	DALE STATION 100 1/E ASS DRA S	MISSION         TRACT NO.         00106733         SCALE       DATE         B" = 1'-0"       08/03/2021         WING NO.       CD-A-111         CD-A-111       0F 112




3. REFER TO SCD-J-100 FOR OVERPASS STRUCTURAL SEPARATION DETAILS AND JACKING SEQUENCE

TUU FOR OVERPASS STRUCTURAL SEPARATION DETAILS AND JACKING SEQUENCE.						
100% RFC SUBMISSION						
	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733				
ailroad	IMPROVEMENTS STATION NORTH AND	SCALE 1/8" = 1'-0"	DATE <b>08/03/2021</b>			
	SOUTH ELEVATIONS	drawing no. SCD-A-201				
	SCARSDALE STATION	SHEET <b>21</b> 0.	F <b>112</b>			



NOTES: 1. CONT

TRA	CTOR TO VER	IFY ELEVATIONS IN FIELD.						
R TC	) SCD-J-100 FOF	R OVERPASS STRUCTURAL SEPA	ARATI	ON DE	ΕΤΑΙ	LS AI	ND JACKING SEQU	JENCE.
		100	%	RF	C .	Sι	JBMISSI	ЛС
		TITLE HARTSDALE AND SCARSDA	ALE S	TATIC	N		<i>CONTRACT NO.</i> <b>1000106733</b>	
ai	Iroad	IMPROVEMENTS					SCALE 1/8" = 1'-0"	DATE <b>08/03/2021</b>
		STATION EAST					DRAWING NO.	
		ELEVATION					SCD-A-	202
		SCARSDALE STATION					SHEET <b>22</b> OF	112




- WARNING STRIP AT PLATFORM EDGE. IN ADDITION, THE ENTIRE TEMPORARY PLATFORM INSTALLATION WALKING SURFACE SHALL BE MARKED WITH YELLOW WARNING STRIPES, PHOTOLUMINESCENT PAINT, AS PER METRO-NORTH RAILROAD SPECIFICATIONS.

REVISION

PL

## 100% RFC SUBMISSION

	TITLE HARTSDALE AND SCARSDALE STATION	ALE STATION CONTRACT NO. 1000106733			
ailroad		SCALE 1/8" = 1'-0"	DATE <b>08/03/2021</b>		
	STATION LONGITUDINAL SECTION	drawing no.	-301		
	SCARSDALE STATION	Sheet <b>23</b> ol	F <b>112</b>		



(A)	STATION	CROS	SS	ECT	ION	
A-101	1/8"=1'-0"	0	4'	8'	16'	

DESIGNED PL	TERED 40	8								
DRAWN VD	ALCONUL N. ZOCH									
CHECKED										
EC	10 3 36210 A	NO.	DATE			DRWN	CHKD	APPVD	NO.	DATE
APPROVED PL	902202			REV	VISION					



#### NOTES:

- 1. REFER TO CIVIL DRAWINGS FOR SCOPE OF WORK FOR DEMOLITION AND NEW WORK REGARDING PARTIAL REMOVAL OF EXISTING PLATFORM AND TEMPORARY PLATFORM INSTALLATION.
- 2. GC TO COORDINATE WITH ALL TRADES FOR ALL UTILITIES THAT WILL BE IMPACTED WITHIN AREA OF WORK PRIOR TO ANY DEMOLITION/NEW WORK.
- 3. TEMPORARY PLATFORM INSTALLATION SHALL INCLUDE, BUT NOT LIMITED TO, TRACK-SIDE TIMBER BOARD ASSEMBLY AT PERIMETER AND TRACK-SIDE TACTILE WARNING STRIP AT PLATFORM EDGE. IN ADDITION, THE ENTIRE TEMPORARY PLATFORM INSTALLATION WALKING SURFACE SHALL BE MARKED WITH YELLOW WARNING STRIPES, PHOTOLUMINESCENT PAINT, AS PER METRO-NORTH RAILROAD SPECIFICATIONS.
- 4. CONTRACTOR TO VERIFY ELEVATIONS IN FIELD.
- 5. REFER TO SCD-J-100 FOR OVERPASS STRUCTURAL SEPARATION DETAILS AND JACKING SEQUENCE.


CONFORMED				
				▲
				$\sim$
				225 P/
				NEW Y
	DRWN	CHKD	APPVD	






REVISION


	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733	
Railroad		SCALE 1/8" = 1'-0"	DATE <b>08/03/2021</b>
	STATION CROSS SECTIONS	DRAWING NO.	
	SCARSDALE STATIONSCD-A-SCARSDALE STATIONSHEET 24 OF		



REVISION

<b>#</b> 2		
PROPER	TY LINE	
·───M		
	27'-3 ½" VORKPOINT #2	
	NT 2 @ CORNER OF PLATFORM. LOCATION TO	
	PLATFORM	
EX.	ISTING PLATFORM SIGNAGE	T
EX	ISTING PLATFORM TACTILE GE	
ORK REGARDING	PARTIAL REMOVAL OF EXISTING PLAT	FORM AND TEMPORARY
D WITHIN AREA	OF WORK PRIOR TO ANY DEMOLITION/	NEW WORK.
	R BOARD ASSEMBLY AT PERIMETER AI ATION WALKING SURFACE SHALL BE M NS.	
CKING SEQUENC		SUBMISSION
ailroad	TITLE HARTSDALE AND SCARSDALE STATION IMPROVEMENTS	CONTRACT NO. <b>1000106733</b> SCALE DATE
aniuau	ENLARGED PLATFORM PLAN	1/4" = 1'-0" 08/03/2021 DRAWING NO. SCD-A-401
	SCARSDALE STATION	SCD-A-401 Sheet 25 OF 112






CONFORMED			
	DRWN	CHKD	APPVD


- 1. REFER TO SHEET SCD-J-101 FOR ADDITIONAL DETAILS AND
- 2. OVERPASS FLOOR, RAMP AND SLOPED WALKWAY TO HAVE HIGH TRAFFIC COATING AND MATCH EXISTING

0070	SUDIVI	ISSION


Railroad	IMPROVEMENTS ENLARGED OVERPASS PLAN 2 OF 2	SCALE 1/4" = 1'-0" DRAWING NO.	DATE <b>08/03/2021</b>
	SCARSDALE STATION	SCD-A-412 SHEET 27 OF 112	




CONFORMED			
	DRWN	CHKD	APPVD
REVLSION			




CONFORMED				
	DRWN	CHKD	APPVD	
REVISION				
$I \setminus L \setminus V \mid L \cup I \cup I \cup V$				




CONFORMED			
	DRWN	CHKD	APPVD
REVISION			






		; 
	I	I
	E OF EXISTING RM BELOW	
EGEND:	LIGHT FIXTURE (CEILING MTD.)	
	MOUNTED LIGHT FIXTURE (ABOVE DOOR)	
	NTED ELEV. PIT LIGHT FIXTURE	
OTE: EFER TO ELECTF	RICAL DRAWINGS FOR LIGHT FIXTURE TYPE AN	D DETAILS.
EE A-815 FOR EL	EVATOR CAB LIGHTING	
	100% RFC SU	
ailroad	TITLE HARTSDALE AND SCARSDALE STATION IMPROVEMENTS	CONTRACT NO.           1000106733           SCALE         DATE
	STATION PLATFORM LEVEL REFLECTED CEILING PLAN	1/8" = 1'-0" 08/03/2021 DRAWING NO.
	SCARSDALE STATION	<b>SCD-A-701</b> SHEET <b>32</b> OF <b>112</b>




/	E OF EXISTING	
PLATFOI	RM CANOPY BELOW	
	I	I
<b>_</b>	·	
	E OF EXISTING RM BELOW	
ſ	LEGEND:	
C	TYP. LIGHT FIXTURE	
I	NOTE:	
I	REFER TO ELECTRICAL DRAWINGS FOR LIGHT	FIXTURE TYPE& DETAILS
	100% RFC S	UBMISSION
Railroad	HARTSDALE AND SCARSDALE STATION	1000106733           SCALE         DATE
<b>Nam Gau</b>	STATION OVERPASS LEVEL	1/8" = 1'-0" 08/03/2021
	REFLECTED CEILING PLAN	DRAWING NO. SCD-A-711
	SCARSDALE STATION	SHEET <b>33</b> OF <b>112</b>





	DRWN	СНКД	APPVD	225 PARK AVENUE SOUTH, NEW YORK, NY 10003	Metro-No 420 Lexington Av New York, NY 10
D $D$ $U$ $I$ $O$ $A$ $I$					


	100% RFC SU	BMISSI	ON	
	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733		
ailroad	IMPROVEMENTS	SCALE 1/4" = 1'-0"	DATE <b>08/03/2021</b>	
	DETAILS 1 OF 2	drawing no. SCD-A-801		
	SCARSDALE STATION	SHEET <b>34</b> O.	F <b>112</b>	



	4	OV 3/4"=1'-0"		ASS ROOF SECTION DETAI	IL
CONFORMED	DRWN	CHKD	APPVD	225 PARK AVENUE SOUTH, NEW YORK, NY 10003	Metro-North Ra 420 Lexington Avenue New York, NY 10017
REVISION					










SHEET **37** OF **112** 


CONFORMED				
	DRWN	CHKD	APPVD	
REVISION				





R SCHEDU	JLE						
FRAM	ЛЕ						
FRAME		JAMB	HDWR	HEAD	SADDLE	FIRE	
TYPE	FINISH	DETAIL	SET #	DETAIL	TYPE	RATING	REMARKS
F1	PTD	J1	HW # 100	H1	S1	90 MIN	DOOR SHALL BE COMPATIBLE WITH STANDARD DOOR HARDWARE SECTION 08 70 00, FUTURE UPGRADES FOR ACCESS CONTROL HA
F1	PTD	J1	HW #	H1	S1	90 MIN	DOOR SHALL BE COMPATIBLE WITH STANDARD DOOR HARDWARE
			100				SECTION 08 70 00, FUTURE UPGRADES FOR ACCESS CONTROL HA
							DOOR SEAL AND SILL TO MEET REQUIREMENTS FOR CLEAN AGEN SYSTEM.
F2	PTD	HDWR	SET # TO			N/A	MATCH EXISTING OVERPASS DOOR/STOREFRONT AND FRAMING. A COMPATIBLE WITH STANDARD DOOR HARDWARE, AS PER MNR SP FUTURE UPGRADES FOR ACCESS CONTROL HARDWARE.
	FRAME TYPE F1 F1	TYPE FINISH F1 PTD F1 PTD	FRAME FRAME TYPEJAMB DETAILF1PTDJ1F1PTDJ1F1PTDJ1	FRAME TYPEJAMB FINISHHDWR DETAILF1PTDJ1HW # 100F1PTDJ1HW # 100F1PTDJ1HW # 100	FRAME       JAMB       HDWR       HEAD         TYPE       FINISH       JAMB       HDWR       HEAD         F1       PTD       J1       HW #       H1         100       100       100       100       100         F1       PTD       J1       HW #       H1         F2       PTD       JAMB, HEAD, SADDLE A         HDWR SET # TO MATCH	FRAME TYPEJAMB FINISHHDWR DETAILHEAD DETAILSADDLE TYPEF1PTDJ1HW # 100H1S1F1PTDJ1HW # 100H1S1F1PTDJ1HW # HUW # 100H1S1	FRAME TYPEJAMB FINISHHDWR DETAILHEAD DETAILSADDLE TYPEFIRE RATINGF1PTDJ1HW # 100H1S190 MINF1PTDJ1HW # 100H1S190 MINF1PTDJ1HW # H00H1S190 MINF1PTDJ1HW # H00H1S190 MINF1PTDJ1HW # H00H1S1N/A
































CONFORMED			
	DRWN	CHKD	APPVD
PFVISION			

				SIGN	AGE SCHEDU	ILE			
	MARK		IMAGE	COUNT		DIMENSION	MOUNTING TYP	PE NO	TES
	A001	占自	<ul> <li>★ Elevator to Track 1,</li> <li>★ to Wassaic</li> </ul>	1		9"H x 8'-8"L	WALL SURFA		
	A002	£ î	<ul> <li>▲ Elevator to Track 2,</li> <li>★ to Grand Central</li> </ul>	2		9"H x 8'-8"L	WALL SURFA		
	A003	<b>↑</b> & i	To Track 1, Wassaic 🚔 🖨	1		9"H x 5'-9"L	CEILING MOUNTED	DIRE	CTIONAL
	A004	<b>↑</b> と	To Track 2,Grand Central	1		9"H x 5'-9"L	CEILING MOUNTED	DIRE	CTIONAL
	A005		Elevator Machine Room	1		4 1/2"H x 11"L	ELEV MACHI ROOM DOO		OM ID
	A006		• • AUTHORIZED PERSONNEL ONLY	2		7 1/2"H x 11"L	WALL SURFA	VCE WA	RNING
	A007		Fire Alarm Panel	1		4 1/2"H x 11"L	ELEV MACHI ROOM DOO		RNING
	A008		Storage Room	1		4 1/2"H x 11"L	COMMUNICATI ROOM DOO		OM ID
	A009		← Exit & 🛗	1		8"H x 30"L	GUARDRAI MOUNTED		CTIONAL
	A010	-	iiiiiiiiiiiiiiiiiiiiiiiiiiiiiiiiiiii	1		8"H x 36"L	GUARDRAI MOUNTED		CTIONAL
	A011		Flashing Light & Alarm means elevator passenger needs help call 911 or (201) 327-2400 MNR Police	1		N/A	WALL SURFA	ACE WARI	NING
	1 SIGN 1/4"=1'-0"	NAGE (		COLOR BAND D BLACK)	2. ALL S	SIGNS SHALL BE N	SED FROM METRO NORTH S MOUNTED MINIMUM 7'-0" AFF DIRECTIONAL SIGNS AS DIR	F, WHERE POSSIBLE.	ORTH STANDARDS.
	E	<b>え</b>	↑↓ Elevato To Trace	:k		5			
	()	· · · · · · · · · · · · · · · · · · ·		LVITA MEDIUM ITALIC XK LETTERS ON WHITE			JS.		
DESIGNED P	3"=1'-0"		0 3" 6" 9"				CONFORMED		
DRAWN V	ALCOISTEN AND								<b>○</b> S
CHECKED E	DE CON		NO. DATE	DRWN C	CHKD APPVD	NO. DATE		DRWN CHKD APPVE	225 PARK AVENUE NEW YORK, NY 10
APPROVED P	L 902	2021	REVI.	SION			REVISION		


	Γ	
I	MOUNTING TYPE	NOTES
	WALL SURFACE	ELEVATOR SIGN. REFER TO SHEET A-812 FOR MOUNTING DETAILS.
	WALL SURFACE	ELEVATOR SIGN. REFER TO SHEET A-812 FOR MOUNTING DETAILS.
	CEILING MOUNTED	DIRECTIONAL
	CEILING MOUNTED	DIRECTIONAL
"L	ELEV MACHINE ROOM DOOR	ROOM ID
"L	WALL SURFACE	WARNING
"L	ELEV MACHINE ROOM DOOR	WARNING
"L	COMMUNICATIONS ROOM DOOR	ROOM ID
	GUARDRAIL MOUNTED	DIRECTIONAL
	GUARDRAIL MOUNTED	DIRECTIONAL
	WALL SURFACE	WARNING









CONFORMED			
	DRWN	CHKD	APPVD






225 PARK AVENUE
NEW YORK, NY 10
KD APPVD NEW TORK, NT IO

) '			
EXISTIN	G PLATFORM	A000	
	I	A009	I
	G PLATFORM		
	100 <sup>-</sup> ТІТLЕ	<u>% RFC SUE</u>	SMISSION
Railroad	HARTSDALE AND SCARSDA IMPROVEMENTS STATION PLATFOF LEVEL SIGNAGE P	RM	1000106733 SCALE DATE 1/8" = 1'-0" 08/03/2021 PRAWING NO. SCD-A-902
	SCARSDALE STATION		SHEET <b>46</b> OF <b>112</b>






♦ STV	100
225 PARK AVENUE SOUTH, NEW YORK, NY 10003	Jeans

- 6" SLAB ON GRA OC EW TOP WIT	_	
COVER		
—— 1'-6" WIDE		
FOUNDATION	I WALL	
	27'-3½"	
X 8" HIGH URB	WORKPOINT 2 @ COF	RNER OF
	EXIST PLATFORM. LC TO BE VIF BY CONT	
		I
ES:		
ALL DIMENSIONS	& ELEVATIONS SHALL BE VERIFIED IN	N FIELD BY
AND NEW WORK	DRAWINGS FOR SCOPE OF WORK FOR REGARDING PARTIAL REMOVAL OF E FEMPORARY PLATFORM INSTALLATIO	XISTING
	ATE WITH ALL TRADES FOR ALL UTILI <sup>-</sup> THIN AREA OF WORK PRIOR TO ANY V WORK	TIES THAT WILL
	-100 FOR OVERPASS STRUCTURAL SE CKING SEQUENCE	PARATION
	RE DESIGNED FOR A NOMINAL BEARII FACTORED BEARING RESISTANCE FO	
	TITLE HARTSDALE AND SCARSDALE STATION	C SUBMISSION CONTRACT NO. 1000106733
ailroad	IMPROVEMENTS	SCALE         DATE           1/4" = 1'-0"         08/03/2021
	STATION FOUNDATION PLAN	DRAWING NO. SCD-S-101


SCARSDALE STATION

SHEET 448 112



	DRWN
REVISION	

	27'-3½"	
	21-3/2	
	WORKPOINT 2 @ CORNER OF - EXIST PLATFORM. LOCATION TO BE VIF BY CONTRACTOR	
		I
ES:		
ALL DIMENSIONS	& ELEVATIONS SHALL BE VERIFIED IN FIELD B	(
AND NEW WORK	DRAWINGS FOR SCOPE OF WORK FOR DEMOLI REGARDING PARTIAL REMOVAL OF EXISTING TEMPORARY PLATFORM INSTALLATION	ΓΙΟΝ
	ATE WITH ALL TRADES FOR ALL UTILITIES THAT THIN AREA OF WORK PRIOR TO ANY V WORK	WILL
	-100 FOR OVERPASS STRUCTURAL SEPARATIO CKING SEQUENCE	N
	RE DESIGNED FOR A NOMINAL BEARING RESIS FACTORED BEARING RESISTANCE FOR STREN	_
	100% RFC SU	BNNGGION
	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733
Railroad	IMPROVEMENTS	SCALE         DATE           1/4" = 1'-0"         08/03/2021
	STATION PLATFORM PLAN	drawing no. SCD-S-102
	SCARSDALE STATION	SHEET <b>49</b> 112





 DESIGNED
 SD

 DRAWN
 SD

 DRAWN
 SD


 CHECKED
 RA

 APPROVED
 MM



NOTE

- 1.
- •
- 2.
- 3.
- 0.
- 4.








REVISION

27'-3½'	_ 1	
PLATFORM	2 @ CORNER OF EXIST I BELOW. LOCATION TO E VIF BY CONTRACTOR	
S:		
ALL DIMENSIONS	& ELEVATIONS SHALL BE VERIFIED IN FIELD BY	/
AND NEW WORK	DRAWINGS FOR SCOPE OF WORK FOR DEMOLI REGARDING PARTIAL REMOVAL OF EXISTING FEMPORARY PLATFORM INSTALLATION	ΓΙΟΝ
	ATE WITH ALL TRADES FOR ALL UTILITIES THAT THIN AREA OF WORK PRIOR TO ANY V WORK	WILL
	-100 FOR OVERPASS STRUCTURAL SEPARATIOI CKING SEQUENCE	N
	100% RFC SU	BMISSION
ailroad	TITLE HARTSDALE AND SCARSDALE STATION IMPROVEMENTS	CONTRACT NO. 1000106733 SCALE DATE
amuau	STATION OVERPASS LEVEL PART PLAN	1/4" = 1'-0" 08/03/2021 DRAWING NO.

SCARSDALE STATION

SCD-S-103

SHEET 56 112





CONFORMED			
	DRWN	CHKD	APPVD

D														
27	' <b>-3½</b> "							►						
	ORM	BELC	OW. L	ER O OCAT ONTR	I TO	 	/		 					
Г	7		Г	٦		l			 					

- 1. ALL DIMENSIONS & ELEVATIONS SHALL BE VERIFIED IN FIELD BY CONTRACTOR
- 2. REFER TO CIVIL DRAWINGS FOR SCOPE OF WORK FOR DEMOLITION AND NEW WORK REGARDING PARTIAL REMOVAL OF EXISTING PLATFORM AND TEMPORARY PLATFORM INSTALLATION
- 3. GC TO COORDINATE WITH ALL TRADES FOR ALL UTILITIES THAT WILL BE IMPACTED WITHIN AREA OF WORK PRIOR TO ANY DEMOLITION/NEW WORK
- 4. REFER TO SCD-J-100 FOR OVERPASS STRUCTURAL SEPARATION DETAILS AND JACKING SEQUENCE


	100% RFC SL	IBMISSI	ON
	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733	
ailroad	IMPROVEMENTS STATION ROOF	SCALE 1/4" = 1'-0"	DATE 08/03/2021
	PART PLAN	DRAWING NO.	404
	SCARSDALE STATION	SCD-S	-104 112






100% R	FC SUBI	MISSION
--------	---------	---------

	SCARSDALE STATION	SHEET <b>GB</b>	112	
		SCD-S	-801	
	& DETAILS I	DRAWING NO.		
amoud	FOUNDATION SECTIONS	AS NOTED	08/03/2021	
ailroad	IMPROVEMENTS	SCALE	DATE	
	HARTSDALE AND SCARSDALE STATION	1000106733		
	TITLE	CONTRACT NO.		



DRWN	CHKD	APPVD
	DRWN	DRWN CHKD





### NOTES:


1. ALL BARS SHALL BE GALVANIZED STEEL.

2. REFER TO REINFORCED CONCRETE NOTES FOR MATERIAL SPECIFICATIONS FOR GALVANIZED STEEL BARS.

FOUNDATION SECTIONS & DETAILS II	AS NOTED DRAWING NO. SCD-S	-802
SCARSDALE STATION	SHEET 64	112








CONFORMED				
				225 PARK
				NEW YOR
	DRWN	CHKD	APPVD	

NOTES:


1. ALL ANCHOR BOLTS SHALL BE STAINLESS STEEL


2. ALL BARS SHALL BE GALVANIZED STEEL

	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733	
lailroad	IMPROVEMENTS	SCALE AS NOTED	DATE 08/03/2021
		DRAWING NO.	-810
	SCARSDALE STATION	SHEET <b>65</b>	112





CONFORMED					
	DRWN	СНКД	APPVD	225 PARK AVENUE SOUTH, NEW YORK, NY 10003	Metro-North Ra 420 Lexington Avenue New York, NY 10017





REVISION





GS APPROVED MM	POFESSIONAL MAN	NO.	DATE	REVISION	DRWN	CHKD	APPVD	NO.	DATE
CHECKED	S COM								
DRAWN	NEW OF NEW								
DESIGNED MK									

### **OVERPASS AND STAIRS - JACKING PLAN** 1/8"=1'-0" 4' 8'

CONFORMED			
	DRWN	CHKD	APPVD
D $D$ $T$ $T$ $C$ $T$ $O$ $N$			
REVISION			





1. DESIGN OF TEMPORARY SHORING AND FINAL JACKING SEQUENCE TO BE SIGNED AND SEALED BY NEW YORK STATE PE.

2. THE OBJECTIVE OF THIS SET OF DRAWING IS TO SHOW THE CONTRACTOR'S SUGGESTED TEMPORARY SUPPORT AND JACKING SCHEME. ALL THE WORKS SPECIFIED UNDER THIS SCHEME SHALL FOLLOW THE SPECIFICATIONS UNDER SECTION 059920.

3. ALL DIMENSIONS AND ELEVATIONS SHOWN ARE TAKEN FROM AS-BUILTS STRUCTURAL AND ARCHITECTURAL SET UNDER CONTRACT NO. 9543 IN 2006. THE CONTRACTOR SHALL FIELD VERIFY ALL THE DIMENSIONS AND ELEVATIONS PRIOR TO STARTING ANY WORK AND LOCATING THE TEMPORARY SUPPORT.

4. NO JACKING SHALL BE PERFORMED IF THE WIND EXCEEDS 45 MPH OR IS FORECAST THAT A WIND AT 45 MPH OR GREATER WILL OCCUR DURING THE 53-HOUR WEEKEND OUTAGE.

5. THE WORK BELOW SHALL BE COORDINATED WITH DIVISION OF WORK MATRIX FOR FORCE ACCOUNT WORK, SEE SPECIFICATION SECTION 01 11 00 PART3.2.A.8.


- 5.1. ALL UTILITIES SHALL BE DISCONNECTED, RAISED AND/OR RELOCATED PRIOR TO THE JACKING OF THE OVERPASS AND WEST STAIRS. UTILITIES INCLUDE ELECTRICAL / COMMUNICATION CONDUITS, AND DRY WATER LINE.
- 5.2. ALL SECURITY CAMERAS THAT INTERFERE WITH THE INSTALLATION OF THE JACKING SYSTEMS SHALL BE RELOCATED AS DIRECTED BY METRO-NORTH RAILROAD. 5.3. ELECTRICAL/COMMUNICATION CONDUITS TO BE RELOCATED TO INSTALL THE JACKING FRAME AT LOCATION 2.

6. FOR WORK ASSOCIATED WITH THE RELOCATION OF THE EXISTING DOORS AND GLAZING, SEE ARCHITECTURAL PLANS.

7. FOR SUGGESTED JACKING PREPARATIONS AND JACKING SEQUENCE, SEE DWG. NO. SCD-J-100A.

8. FOR JACKING NOTES, SEE DRAWING NO. SCD-J-100A.

### LEGEND:



TEMPORARY SUPPORT STRUCTURE WITH JACK LOCATION BELOW OVERPASS



TEMPORARY SUPPORT FOR ROOF CANOPY



PLATFORM PIER LINE, XX - NUMBER; W - WEST; E - EAST



**TEMPORARY STRUCTURE**, X - NUMBER

Railroad	TITLE HARTSDALE AND SCARSDALE STATION	<i>CONTRACT NO.</i> 1000106733		
	IMPROVEMENTS OVERPASS AND STAIRS	SCALE 1/8" = 1'-0"	DATE <b>08/03/2021</b>	
	JACKING PLAN	drawing no.	100	
	SCARSDALE STATION	SHEET 59 OF 112		


	OWING JACKING SEQUENCE AND OPE. ND WEEKENDS.	RATION SHALL B	E COMPLETED DURING		
	ALL 8 FT. BARRIER TO PROTECT THE O				
	OVE PART OF CONCRETE PLATFORM S PORARY STRUCTURE 2.	LAB TO ALLOW IN	ISTALLATION OF		
3. INST	ALL A TEMPORARY SUPPORT STRUCTU			т	
	R AS INDICATED IN THIS DRAWING AND ALL TEMPORARY SUPPORT STRUCTUR			т	
	CANOPY.			.1	
	CUT PLATFORM SLAB/ROOF AS SHOW ONNECT ALL UTILITIES ATTACHED ON <sup>-</sup>		ON DWG. NO. SCD-J-104		
	ONNECT ALL OTILITIES ATTACHED ON ONNECT EAST STAIR'S PLATFORM FRC	-	S (DISCONNECT ROOF		
	IS TO OVERPASS CANOPY COLUMN AN	ID FLOOR BEAMS	S TO OVERPASS MAIN		
GIRD 8. CUT	ERS). AND REMOVE PART OF THE OVERPASS	6 DECK TO ALLOV	V THE INSTALLATION OF	THE	
BEAR	RING STIFFENER.				
-	L HOLES IN EXISTING GIRDER FOR BEA	-		G	
LOCA	TION.	-		-	
	OVE EXISTING BOLTS/RIVETS ON THE C ERS OF OVERPASS.	COLUMN BRACKE	IS SUPPORTING MAIN		
12. DISC	ONNECT CONNECTIONS BETWEEN STA	AIR STRINGERS A	ND STAIR SUPPORTS AT		
	T STAIR. R THE LIFTING OPERATIONS ARE COM	PI FTED AND THE	TEMPORARY SUPPORT	S	
-	REMOVED, FURNISH AND INSTALL CAS	T IN PLACE CON			
THE	PLATFORM. FOR DETAILS, SEE DWG. N DWG. NO. SCD-J-100 FOR OVERPASS A		ING PLAN.		
THE	PLATFORM. FOR DETAILS, SEE DWG. N DWG. NO. SCD-J-100 FOR OVERPASS A		ING PLAN.		
THE I 14. SEE I	,		ING PLAN.		
THE I 14. SEE I JACKIN 1. JACK	DWG. NO. SCD-J-100 FOR OVERPASS A GNOTES: S SHALL HAVE RATED CAPACITY SHOW	ND STAIRS JACKI	-	TE	
THE I 14. SEE I JACKIN 1. JACK ATTA	DWG. NO. SCD-J-100 FOR OVERPASS A <u>G NOTES:</u> S SHALL HAVE RATED CAPACITY SHOW CHED TO EACH JACK.	ND STAIRS JACKI WN ON THE MANU	JFACTURER'S NAME PLA		
THE I 14. SEE I JACKIN 1. JACK ATTA 2. JACK DEVI0	DWG. NO. SCD-J-100 FOR OVERPASS A <u>G NOTES:</u> S SHALL HAVE RATED CAPACITY SHOW CHED TO EACH JACK. S SHALL BE EQUIPPED WITH PRESSUF CES THAT WILL ENABLE THE APPLIED L	ND STAIRS JACKI WN ON THE MANU RE GAUGES OR O	JFACTURER'S NAME PLA THER LOAD MEASURING	i	
THE I 14. SEE I JACKIN 1. JACK ATTA 2. JACK DEVIO TIME	DWG. NO. SCD-J-100 FOR OVERPASS A <u>G NOTES:</u> S SHALL HAVE RATED CAPACITY SHOW CHED TO EACH JACK. S SHALL BE EQUIPPED WITH PRESSUF CES THAT WILL ENABLE THE APPLIED L S.	ND STAIRS JACKI WN ON THE MANU RE GAUGES OR O LIFTING FORCE TO	JFACTURER'S NAME PLA THER LOAD MEASURING O BE MONITORED AT ALI	i	
THE I 14. SEE I JACKIN 1. JACK ATTA 2. JACK DEVIO TIME 3. JACK 4. ALL J	OWG. NO. SCD-J-100 FOR OVERPASS A <u>G NOTES:</u> S SHALL HAVE RATED CAPACITY SHOW CHED TO EACH JACK. S SHALL BE EQUIPPED WITH PRESSUF CES THAT WILL ENABLE THE APPLIED L S. S SHALL BE MANUFACTURED BY ENER ACKING LOCATIONS IN EACH SETUP S	ND STAIRS JACKI WN ON THE MANU RE GAUGES OR O LIFTING FORCE TO RPAC OR APPROV HALL BE JACKED	JFACTURER'S NAME PLA THER LOAD MEASURING O BE MONITORED AT ALI 'ED EQUAL. SIMULTANEOUSLY AND	i	
THE I 14. SEE I JACKIN 1. JACK ATTA 2. JACK DEVIO TIME 3. JACK 4. ALL J	DWG. NO. SCD-J-100 FOR OVERPASS A <u>G NOTES:</u> S SHALL HAVE RATED CAPACITY SHOW CHED TO EACH JACK. S SHALL BE EQUIPPED WITH PRESSUF CES THAT WILL ENABLE THE APPLIED L S. S SHALL BE MANUFACTURED BY ENER	ND STAIRS JACKI WN ON THE MANU RE GAUGES OR O LIFTING FORCE TO RPAC OR APPROV HALL BE JACKED	JFACTURER'S NAME PLA THER LOAD MEASURING O BE MONITORED AT ALI 'ED EQUAL. SIMULTANEOUSLY AND	i	
THE I 14. SEE I JACKIN 1. JACK ATTA 2. JACK DEVIO TIME 3. JACK 4. ALL J	OWG. NO. SCD-J-100 FOR OVERPASS A <u>G NOTES:</u> S SHALL HAVE RATED CAPACITY SHOW CHED TO EACH JACK. S SHALL BE EQUIPPED WITH PRESSUF CES THAT WILL ENABLE THE APPLIED L S. S SHALL BE MANUFACTURED BY ENER ACKING LOCATIONS IN EACH SETUP S ORMLY. JACKS SHALL NOT BE PRESSU	ND STAIRS JACKI WN ON THE MANU RE GAUGES OR O LIFTING FORCE TO RPAC OR APPROV HALL BE JACKED JRED INDIVIDUAL	JFACTURER'S NAME PLA THER LOAD MEASURING O BE MONITORED AT ALI (ED EQUAL. SIMULTANEOUSLY AND LY.	i	
THE I 14. SEE I JACKIN 1. JACK ATTA 2. JACK DEVIO TIME 3. JACK 4. ALL J	OWG. NO. SCD-J-100 FOR OVERPASS A <u>G NOTES:</u> S SHALL HAVE RATED CAPACITY SHOW CHED TO EACH JACK. S SHALL BE EQUIPPED WITH PRESSUF CES THAT WILL ENABLE THE APPLIED L S. S SHALL BE MANUFACTURED BY ENER ACKING LOCATIONS IN EACH SETUP S	ND STAIRS JACKI WN ON THE MANU RE GAUGES OR O LIFTING FORCE TO RPAC OR APPROV HALL BE JACKED JRED INDIVIDUAL	JFACTURER'S NAME PLA THER LOAD MEASURING O BE MONITORED AT ALI (ED EQUAL. SIMULTANEOUSLY AND LY.	i	
THE I 14. SEE I JACKIN 1. JACK ATTA 2. JACK DEVIO TIME 3. JACK 4. ALL J	OWG. NO. SCD-J-100 FOR OVERPASS A <u>G NOTES:</u> S SHALL HAVE RATED CAPACITY SHOW CHED TO EACH JACK. S SHALL BE EQUIPPED WITH PRESSUF CES THAT WILL ENABLE THE APPLIED L S. S SHALL BE MANUFACTURED BY ENER ACKING LOCATIONS IN EACH SETUP S ORMLY. JACKS SHALL NOT BE PRESSU	ND STAIRS JACKI VN ON THE MANU RE GAUGES OR O IFTING FORCE TO RPAC OR APPROV HALL BE JACKED JRED INDIVIDUAL	JFACTURER'S NAME PLA THER LOAD MEASURING O BE MONITORED AT ALI (ED EQUAL. SIMULTANEOUSLY AND LY.	i	
THE I 14. SEE I JACKIN 1. JACK ATTA 2. JACK DEVIO TIME 3. JACK 4. ALL J	OWG. NO. SCD-J-100 FOR OVERPASS A G NOTES: S SHALL HAVE RATED CAPACITY SHOW CHED TO EACH JACK. S SHALL BE EQUIPPED WITH PRESSUF CES THAT WILL ENABLE THE APPLIED L S. S SHALL BE MANUFACTURED BY ENER ACKING LOCATIONS IN EACH SETUP S ORMLY. JACKS SHALL NOT BE PRESSU JACKING TABLE OF	ND STAIRS JACKI	JFACTURER'S NAME PLA THER LOAD MEASURING O BE MONITORED AT ALI (ED EQUAL. SIMULTANEOUSLY AND LY. ND WEST STAIR D WIND LOAD	JACK CAPACITY	
THE I 14. SEE I 14. JACK 1. JACK ATTA 2. JACK DEVIO TIME 3. JACK 4. ALL J	DWG. NO. SCD-J-100 FOR OVERPASS A G NOTES: S SHALL HAVE RATED CAPACITY SHOW CHED TO EACH JACK. S SHALL BE EQUIPPED WITH PRESSUF CES THAT WILL ENABLE THE APPLIED L S. S SHALL BE MANUFACTURED BY ENER ACKING LOCATIONS IN EACH SETUP S DRMLY. JACKS SHALL NOT BE PRESSU JACKING TABLE OF LOCATION TEMPORARY STRUCTURE 1	ND STAIRS JACKI	JFACTURER'S NAME PLA THER LOAD MEASURING O BE MONITORED AT ALI (ED EQUAL. SIMULTANEOUSLY AND LY. <b>ND WEST STAIR</b> (MIND LOAD (KIPS) (PER AREMA)	JACK CAPACITY (TONS)	
THE I 14. SEE I JACKIN 1. JACK ATTA 2. JACK DEVIO TIME 3. JACK 4. ALL J UNIFO	DWG. NO. SCD-J-100 FOR OVERPASS A G NOTES: S SHALL HAVE RATED CAPACITY SHOW CHED TO EACH JACK. S SHALL BE EQUIPPED WITH PRESSUF CES THAT WILL ENABLE THE APPLIED L S. S SHALL BE MANUFACTURED BY ENER ACKING LOCATIONS IN EACH SETUP S DRMLY. JACKS SHALL NOT BE PRESSU JACKING TABLE OF LOCATION TEMPORARY STRUCTURE 1	ND STAIRS JACKI	JFACTURER'S NAME PLA THER LOAD MEASURING O BE MONITORED AT ALL (ED EQUAL. SIMULTANEOUSLY AND LY. <b>ND WEST STAIR</b> D WIND LOAD (KIPS) (PER AREMA) 40	JACK CAPACITY (TONS) 120	
THE I 14. SEE I JACKIN 1. JACK ATTA 2. JACK DEVIO TIME 3. JACK 4. ALL J UNIFO	DWG. NO. SCD-J-100 FOR OVERPASS A G NOTES: S SHALL HAVE RATED CAPACITY SHOW CHED TO EACH JACK. S SHALL BE EQUIPPED WITH PRESSUF CES THAT WILL ENABLE THE APPLIED L S. S SHALL BE MANUFACTURED BY ENER ACKING LOCATIONS IN EACH SETUP S DRMLY. JACKS SHALL NOT BE PRESSU JACKING TABLE OF LOCATION TEMPORARY STRUCTURE 1 SS TEMPORARY STRUCTURE 2	ND STAIRS JACKI	JFACTURER'S NAME PLA THER LOAD MEASURING O BE MONITORED AT ALL (ED EQUAL. SIMULTANEOUSLY AND LY. <b>ND WEST STAIR</b> D WIND LOAD (KIPS) (PER AREMA) 40 40	JACK CAPACITY (TONS) 120 120	
THE I 14. SEE I JACKIN 1. JACK ATTA 2. JACK DEVIO TIME 3. JACK 4. ALL J UNIFO	DWG. NO. SCD-J-100 FOR OVERPASS A G NOTES: S SHALL HAVE RATED CAPACITY SHOW CHED TO EACH JACK. S SHALL BE EQUIPPED WITH PRESSUF CES THAT WILL ENABLE THE APPLIED L S. S SHALL BE MANUFACTURED BY ENER ACKING LOCATIONS IN EACH SETUP S DRMLY. JACKS SHALL NOT BE PRESSU JACKING TABLE OF LOCATION TEMPORARY STRUCTURE 1 SS TEMPORARY STRUCTURE 2 TEMPORARY STRUCTURE 3 TEMPORARY STRUCTURE 4	ND STAIRS JACKI	JFACTURER'S NAME PLA THER LOAD MEASURING O BE MONITORED AT ALL (ED EQUAL. SIMULTANEOUSLY AND LY. AND WEST STAIR AD WIND LOAD (KIPS) (PER AREMA) 40 40 40 4	JACK CAPACITY (TONS) 120 120 20	
THE I 14. SEE I 14. JACK ATTA 2. JACK DEVIO TIME 3. JACK 4. ALL J UNIFO OVERPA	DWG. NO. SCD-J-100 FOR OVERPASS A G NOTES: S SHALL HAVE RATED CAPACITY SHOW CHED TO EACH JACK. S SHALL BE EQUIPPED WITH PRESSUF CES THAT WILL ENABLE THE APPLIED L S. S SHALL BE MANUFACTURED BY ENER ACKING LOCATIONS IN EACH SETUP S DRMLY. JACKS SHALL NOT BE PRESSU JACKING TABLE OF LOCATION TEMPORARY STRUCTURE 1 SS TEMPORARY STRUCTURE 2 TEMPORARY STRUCTURE 3 TEMPORARY STRUCTURE 4	ND STAIRS JACKI	JFACTURER'S NAME PLA THER LOAD MEASURING O BE MONITORED AT ALI /ED EQUAL. SIMULTANEOUSLY AND LY. AND WEST STAIR AD WIND LOAD (KIPS) (PER AREMA) 40 40 41 12	JACK CAPACITY (TONS) 120 120 20 20	
THE I 14. SEE I 14. JACK ATTA 2. JACK DEVIO TIME 3. JACK 4. ALL J UNIFO OVERPA	DWG. NO. SCD-J-100 FOR OVERPASS A G NOTES: S SHALL HAVE RATED CAPACITY SHOW CHED TO EACH JACK. S SHALL BE EQUIPPED WITH PRESSUF CES THAT WILL ENABLE THE APPLIED L S. S SHALL BE MANUFACTURED BY ENER ACKING LOCATIONS IN EACH SETUP S DRMLY. JACKS SHALL NOT BE PRESSU JACKING TABLE OF LOCATION TEMPORARY STRUCTURE 1 SS TEMPORARY STRUCTURE 2 TEMPORARY STRUCTURE 3 AIR TEMPORARY STRUCTURE 5	ND STAIRS JACKI	JFACTURER'S NAME PLA THER LOAD MEASURING O BE MONITORED AT ALL (ED EQUAL. SIMULTANEOUSLY AND LY. AND WEST STAIR AD WIND LOAD (KIPS) (PER AREMA) 40 40 41 12 7	JACK CAPACITY (TONS) 120 120 20 20 20 10	

- DURING OFF-PEAK HOURS DURING THE WEEKDAYS OR WEEKEND NIGHTS. 2. ALL WORK ASSOCIATED WITH JACKING OPERATIONS SHALL BE PERFORMED DURING A SINGLE 53-HOUR WEEKEND WORK.
- 3. THE 53-HOUR WEEKEND WORK STARTS AT 11:00 P.M. FRIDAY AND ENDS 4:00 A.M. THE FOLLOWING MONDAY. THE PLATFORMS SHALL BE CLEAR FOR THE PASSENGERS BY 4:00 A.M. ON MONDAY MORNING.
- 4. NOTIFY CUSTOMER SERVICE SEVEN CALENDAR DAYS PRIOR TO ANY OVERPASS CLOSURE.
- 5. NOTIFY CUSTOMER SERVICE SEVEN CALENDAR DAYS PRIOR TO ANY PLATFORM CLOSURE.
- 6. NOTIFY CUSTOMER SERVICE PRIOR TO ANY PLATFORM ACTIVITIES THAT WILL INTERFERE WITH THE PEDESTRIAN TRAFFIC.
- 7. NOTIFY MNR SEVEN CALENDAR DAYS PRIOR TO ANY TRACK OUTAGE. NOTIFY MNR AND CUSTOMER SERVICE AT LEAST FOURTEEN CALENDAR DAYS PRIOR TO THE TRACK AND OVERPASS OUTAGE FOR THE 53-HOUR WEEKEND.
- 8. MNR MUST BE NOTIFIED BEFORE PERFORMING LEAD ABATEMENT SO THAT OVERSIGHT IS PROVIDED FOR AIR MONITORING AND LEAD ABATEMENT.
- 9. NOTIFY MNR BEFORE UTILITY WORK IS PERFORMED.
- 10. CONTRACTOR SHALL COORDINATE PLACING BEAMS TO SUPPORT JACKING.

									-					
DESIGNED	EW										CONFORMED			
		MINIMOE NE WE												
DRAWN		MOS												
	EW	S F S S P												
CHECKED		IN A SA												
CHECKED	GS		NO.	DATE	DF	RWN C	HKD	APPVD	NO.	DATE		DRWN	CHKD	APPVD
		0 062155 CH												
APPROVED	MM	TOFESSIONA			REVISION						REVISION			


TASK NO.	TASK DESCRIPTION	WORK HOURS	TRACK OUTAGE	OVERPASS CLOSURE	18	REMOVE NO MORE TH BOLTS/RIVETS ON THE THE MAIN GIF
	PRE JACKING OPERATION - OFF PEAK HOURS W	EEKDAYS OR WEEKEND N	IGHTS			DISCONNECT CONNECT
1	SET UP PROPER MPT ON PLATFORM TO REMOVE PART OF THE PLATFORM AS SHOWN ON THE PLANS.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	AS NEEDED	AS NEEDED	19	AND STAIR SU
2	RELOCATE PLATFORM AMENITIES TO INSTALL TEMPORARY SUPPORTS FOR THE JACKING AS SHOWN ON THE PLANS. THIS WORK INCLUDES DISCONNECTING AND RELOCATING ELECTRICAL OUTLET AND CONDUITS AS NEEDED.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	NO	20	2 AND CANOPY TEMPC WITH PEDESTRIAN TE
3	CONSTRUCT TEMPORARY 8 FT. BARRIER AROUND THE OPENING ON THE PLATFORM.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	NO		UNTIL JA
4	SAWCUT PART OF THE CONCRETE PLATFORM BETWEEN COLUMN LINES 14W AND 15W AS SHOWN ON THE PLANS.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	NO	1	SET UP PROPER MPT ON O
5	DISCONNECT THE PRECAST CONCRETE BEAM AND REMOVE. FURNISH AND INSTALL TEMPORARY BARRIER UNDER PLATFORM BETWEEN COLUMN LINES 14W AND 15W.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	NO	2	FINISH INSTALLING TEM
6	REARRANGE THE UTILITY LINES UNDER THE PLATFORM AND SET THE TIMBER MAT FOUNDATION FOR TEMPORARY SUPPORT STRUCTURE 2	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	NO	3	UNDER THE GIRDERS STRUCTURE. VER REMOVE THE REMA
7	INSTALL TEMPORARY SUPPORT STRUCTURES UNDERNEATH OVERPASS AND WEST STAIR AS INDICATED ON DWG. NO. SCD-J-100 AND ON DWG. NO. SCD-J-101. THE INSTALLATION OF THE TEMPORARY SUPPORTS SHALL NOT INTERFERE WITH THE OPERATION OF THE PLATFORM OR	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	AS NEEDED	4	COLUMN BRACKETS SU ALL OTHER CONNECTIN OVERF
8	OVERPASS. INSTALL TEMPORARY SUPPORT STRUCTURE AT EAST STAIR PLATFORM TO SUPPORT ROOF CANOPY.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	NO	6	RESUME LIFTING OPE STAIRS TO TH
9	INSTALL NEW CONDUITS ALONG THE OUTSIDE OF THE OVERPASS TO ALLOW FOR THE LIFTING OF THE OVERPASS.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	TRACK 1 AND TRACK 2	NO	7	FURNISH AND INSTALL
9A	PULL THE ELECTRICAL CABLE IN THE NEW CONDUITS.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	NO		AS SHO
9B	PULL THE NEW FIBER CABLE WITH SLACK IN THE NEW CONDUITS.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	NO	8	ON TH
10	DISCONNECT UTILITIES ATTACHED ON THE OUTSIDE OF THE OVERPASS.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	NO	9	OPERATIONS 6 THROUG
10A	DISCONNECT COMMUNICATIONS WIRES (FIBER).	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	NO		REMOVE JACKS AND
10B	DISCONNECT ELECTRICAL CABLES.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND	NO	NO		SUPPORTS THAT INT
10C	REMOVE EXISTING CONDUITS ALONG THE OUTSIDE OF THE OVERPASS.	NIGHTS OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	TRACK 1 OR TRACK 2	NO	12	RESTORE ELEVATOR, OV CUSTOMER USE BY AD HANDRAILS, SLOPED RA SHOWN ON THE PLANS. THE ELEVATOR
11	DISCONNECT EAST STAIR PLATFORM FROM THE OVERPASS. DISCONNECT ROOF BEAMS TO OVERPASS CANOPY COLUMN AND FLOOR BEAMS TO OVERPASS MAIN GIRDERS.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	AS NEEDED		POST JACKI
12	DISCONNECT, EXTEND/RASIE, AND RECONNECT DRAY WATERLINE.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	NO	1	SET UP PROP
13	SAWCUT OVERPASS SLAB/ROOF AS SHOWN ON SECTION B ON DWG. NO. SCD-J-104.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	AS NEEDED	2	FINISH REMOVING
14	CUT AND REMOVE PART OF THE OVERPASS DECK TO ALLOW FOR THE INSTALLATION OF THE BEARING STIFFENER.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	AS NEEDED		FURNISH AND INSTALL F
15	PERFORM LEAD ABATEMENT.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	AS NEEDED	3	INBOUND PLATFORM B
16	DRILL HOLES IN EXISTING GIRDER FOR THE NEW BEARING STIFFENER.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	AS NEEDED	4	REMOVE FORMWOR OVERPASS CANOPY AND SEP
17	INSTALL NEW BEARING STIFFENER AT BOTH SIDES OF THE MAIN GIRDER AT THE JACKING LOCATIONS.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	AS NEEDED		






REMOVE NO MORE THAN 50 PERCENT OF THE EXISTING BOLTS/RIVETS ON THE COLUMN BRACKETS SUPPORTING THE MAIN GIRDERS OF THE OVERPASS.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	AS NEEDED
DISCONNECT CONNECTIONS BETWEEN STAIR STRINGERS AND STAIR SUPPORTS AT WEST STAIR.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	AS NEEDED
ENSURE ALL PREPARATION WORK AT THE SIX LOCATIONS WHERE TEMPORARY SUPPORTS ARE TO BE LOCATED ARE NSTALLED AND READY TO BE USED. TEMPORARY SUPPORT 2 AND CANOPY TEMPORARY SUPPORTS THAT INTERFERE WITH PEDESTRIAN TRAFFIC MUST NOT BE INSTALLED UNTIL JACKING OPERATION.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	NO
JACKING OPERATION - 53 HOUR	WEEKEND WORK		
ET UP PROPER MPT ON PLATFORM AND PROPER CLOSURE OF OVERPASS.	WEEKEND	NO	CONTINUOU S WEEKEND
INISH INSTALLING TEMPORARY SUPPORTS FOR THE JACKS.	WEEKEND	NO	CONTINUOU S WEEKEND
OPERATE AND STOP JACKS ONCE TIGHT FIT IS ACHIEVED UNDER THE GIRDERS, STAIR STRINGERS, AND ROOF STRUCTURE. VERIFY ALL JACKS ARE TIGHT FIT.	WEEKEND	NO	CONTINUOU S WEEKEND
REMOVE THE REMAINNIG BOLTS/RIVETS FROM THE COLUMN BRACKETS SUPPORTING THE MAIN GIRDER AND ALL OTHER CONNECTINOS TO ALLOW THE LIFTING OF THE OVERPASS AND STAIRS.	WEEKEND	NO	CONTINUOU S WEEKEND
SET UP OUTAGE ON TRACKS 1 AND 2	SATURDAY 2 A.M. TO 5:30 A.M.		
RESUME LIFTING OPERATIONS TO LIFT OVERPASS AND STAIRS TO THE REQUIRED ELEVATION.	WEEKEND	TRACK1 AND TRACK 2	CONTINUOU S WEEKEND
FURNISH AND INSTALL NEW BEAMS AND COLUMN SPLICE AS SHOWN ON THE PLAN.	WEEKEND	TRACK1 AND TRACK 2	CONTINUOU S WEEKEND
STOP THE JACKS WHEN THE OVERPASS AND STAIRS REST ON THE NEW SUPPORTS.	WEEKEND	TRACK1 AND TRACK 2	CONTINUOU S WEEKEND
SECURE ALL CONNECTIONS.	WEEKEND	TRACK1 AND TRACK 2	CONTINUOU S WEEKEND
OPERATIONS 6 THROUGH 9 SHALL BE COMPLETED IN 3.5 HOURS.			
REMOVE JACKS AND ALL TEMPORARY STRUCTURAL SUPPORTS THAT INTERFERE WITH THE PLATFORM'S OPERATIONS.	WEEKEND	NO	CONTINUOU S WEEKEND
RESTORE ELEVATOR, OVERPASS, AND ALL STAIRCASES FOR CUSTOMER USE BY ADDING CODE COMPLIANT STEMPS, HANDRAILS, SLOPED RAMPS, AND ANY OTHER FINISHES AS SHOWN ON THE PLANS. INSTALL AN ADA ACCESS RAMP TO THE ELEVATOR AS SHOWN ON THE PLANS.	WEEKEND	NO	CONTINUOU S WEEKEND
POST JACKING OPERATION - OFF PEAK HOURS V	NEEKDAYS OR WEEKEND N	IIGHTS	•
SET UP PROPER MPT ON PLATFORM.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	AS NEEDED
FINISH REMOVING ALL TEMPORARY STRUCTURAL SUPPORTS.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	NO
FURNISH AND INSTALL FORMWORK AND REINFORCEMENT AND POUR CONCRETE TO CLOSE THE OPENING AT THE INBOUND PLATFORM BETWEEN COLUMN LINES 14W AND 15W.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	NO
REMOVE FORMWORK FROM PLATFORM. REPAIR THE OVERPASS CANOPY AND WOOD CEILING AT ROOF CANOPY SEPARATION LINE.	OFF PEAK WEEKDAY NIGHTS OR WEEKEND NIGHTS	NO	NO


	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733		
Railroad	IMPROVEMENTS	SCALE 1/8" = 1'-0"	DATE <b>08/03/2021</b>	
	JACKING SEQUENCE	drawing no.	100A	
	SCARSDALE STATION	SHEET <b>60</b> O.	F <b>112</b>	






				EDGE DIS		
N A	DIMENSION B	DIMENSION C	DIMENSION D	DIMENSION E	DIMENSION F	DIMENSI
	6'-0"	1'-8"	1'-8"	3'-0"	3'-0"	11/2"
	6'-0"	1'-8"	1'-8"	3'-0"	3'-0"	11/2"
	2'-0"	1'-8"	1'-8"	1'-0"	1'-0"	11/2"
	2'-0"	1'-3"	1'-3"	1'-0"	1'-0"	11/2"
	2'-0"	1'-3"	1'-3"	1'-0"	1'-0"	11/2"
	2'-0"	1'-3"	1'-3"	1'-0"	1'-0"	11/2"


CONFORMED				
				1
				1
				1
				I
				1
	DRWN	CHKD	APPVD	1
				1
REVISION				
				i



CONFORMED	DRWN	CHKD	APPVD	225 PARK AVENUE SOUTH, NEW YORK, NY 10003	Metro-North 420 Lexington Avenue New York, NY 10017
REVISION					




CONFORMED			
	DRWN	CHKD	APPVD



0 Metro-North Railroad 420 Lexington Avenue New York, NY 10017		TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733	
	IMPROVEMENTS OVERPASS - INBOUND -	SCALE 3/8" = 1'-0"	DATE <b>08/03/2021</b>	
	5	TEMP. STRUCTURE 2 AND	drawing no.	105
		SCARSDALE STATION	SHEET <b>65</b> OF	112

♦ STV	
225 PARK AVENUE SOUTH,	
NEW YORK, NY 10003	Geals






—— ငို့ FC2


- FC3 (C15x33.9)


– W14

JACK

— W14










NOTES:

Means 100


1. ALL NEW STEEL IS TO BE PRIMED AND PAINTED THE SAME COLOR AS THE ATTACHING STEELWORK.

- 2. ROUND HEAD BOLTS TO BE INSTALLED IN THE EXISTING RIVET HOLES.
- 3. TACK WELD EXPANDED METAL FENCE TO THE END OF HSS, BOTH SIDES.
- 4. FOR EXISTING DOOR AND GLAZE REMOVAL AND RELOCATION DETAILS, SEE ARCHITECTURAL PLANS.






REVISION



SCALE IN FEET

100%	RFC	<b>SUBMISSION</b>

Railroad	HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733		
	IMPROVEMENTS OVERPASS - INBOUND - TEMPORARY STRUCTURE 2 - SECTIONS	SCALE AS NOTED	DATE <b>08/03/2021</b>	
		drawing no.	106	
	SCARSDALE STATION	SHEET <b>66</b> 0.	F 112	



REV	LS	IO	$\mathcal{N}$
	$I \cup J$	$I \cup I$	I V








### NOTES:


- 1. FOR JACKING NOTES, SEE DWG. NO. SCD-J-100 AND DWG. NO. SCD-J-100A.
- 2. FOR TIMBER MAT DETAIL, BASE PLATE SIZE, LAG SCREWS, SEE TABLE - 1 ON SCD-J-102.

ailroad	HARTSDALE AND SCARSDALE STATION	<i>CONTRACT NO.</i> <b>1000106733</b>	
	IMPROVEMENTS OVERPASS - INBOUND - TEMPORARY STRUCTURE 3 - SECTION	SCALE AS NOTED	DATE <b>08/03/2021</b>
		drawing no.	107
	SCARSDALE STATION	SHEET <b>67</b> O	F <b>112</b>










G	FINAL	SEC		ON
V-100	1/2"=1'-0"	0	1'	2'




SCARSDALE STATION

SHEET 70 OF 112

♦ ST\	100
225 PARK AVENUE SOUTH, NEW YORK, NY 10003	Jeans

	DRWN	CHKD	APPVD
D D U U U O U O M			

REVISION



### NOTE:


- 1. ALL NEW STEEL IS TO BE PRIMED AND PAINTED THE SAME
- COLOR AS THE ATTACHING STEELWORK.
- 2. FOR RAMP DETAILS, SEE DWGS. A-SCD-801 AND A-SCD-802.


<sup>7</sup>/<sub>8</sub>" DIA. BOLT (2 MIN.)


EXIST. W6x12 BEAM

RECONNECT EXIST. BRACKET

	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733	
ailroad	IMPROVEMENTS MISCELLANEOUS	SCALE 1"=1'-0"	DATE <b>08/03/2021</b>
		drawing no.	.111
	SCARSDALE STATION	SHEET <b>71</b> O.	F <b>112</b>











Metro-North R 420 Lexington Avenue New York, NY 10017

1. ALL NEW STEEL IS TO BE PRIMED AND PAINTED THE SAME COLOR AS THE ATTACHING STEELWORK. 2. ROUND HEAD BOLTS SHALL BE USED FOR SPLICE ATTACHMENTS.

	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733	
Railroad	IMPROVEMENTS MISCELLANEOUS	SCALE AS NOTED	DATE <b>08/03/2021</b>
	SECTIONS AND DETAILS - SHEET 3 OF 4	drawing no.	112
	SCARSDALE STATION	SHEET <b>72</b> of	F 112





- STAY-IN-PLACE



STRUCTURE 2 ONLY)

NOTES:

- 1. ALL NEW STEEL IS TO BE PRIMED AND PAINTED THE SAME COLOR AS THE ATTACHING STEELWORK.
- 2. ROUND HEAD BOLTS SHALL BE USED FOR STIFFENER ATTACHMENTS.

	TITLE HARTSDALE AND SCARSDALE STATION	<i>CONTRACT NO.</i> <b>1000106733</b>			
Railroad		SCALE AS NOTED	DATE <b>08/03/2021</b>		
	MISCELLANEOUS SECTIONS AND DETAILS -	DRAWING NO.			
	SHEET 4 OF 4	SCD-J-	113		
	SCARSDALE STATION	SHEET 73 O	F 112		

GENERAL DEMOLITION NOTES:

- UNLESS OTHERWISE NOTED REMOVE ALL LIGHT FIXTURES DEVICES, ELECTRICAL EQUIPMENT AND THEIR ASSOCIATED POWER SUPPLY CABLE AND CONDUIT IN THE AREAS WHERE REMOVAL WORK IS INDICATED ON THE DEMOLITION PLANS.
- 2. REMOVE ALL EXISTING ELECTRICAL EQUIPMENT NOT INDICATED TO REMAIN OR THAT ARE NOT SERVING EXISTING LOADS. PULL OUT EXISTING WIRING BACK TO THE PANEL BOARDS AND PROVIDE BLANK PLATES AS REQUIRED.
- 3. EXISTING EQUIPMENT TO REMAIN SHALL RETAIN ITS ORIGINAL POWER SOURCE UON
- 4. ALL ELECTRICAL EQUIPMENT WITH DISCONNECTED LOADS SHALL HAVE THE POWER SOURCE BREAKER LOCKED IN OPEN POSITION FOR SAFETY.
- 5. ALL WIRING SHALL BE NEW, UON. SPLICES TO EXTEND EXISTING WIRING SHALL BE MADE ONLY IN ACCESSIBLE JUNCTION BOX OR TO THE NEAREST JUNCTION/OUTLET BOX WHERE EXISTING WIRING CAN BE CUT AND SPLICED.
- THE CONTRACTOR SHALL DISCONNECT THE CIRCUIT WIRING AND REMOVE ALL WIRING MATERIALS. INCLUDING CONDUITS THAT ARE EXPOSED DUE TO DEMOLITION OR WHICH IMPEDE THE NEW WORK, OR WHICH ARE UNSIGHTLY.
- 7. AS INDICATED ON PLANS OR SPECIFICATION, ALL EXISTING EQUIPMENT TO BE RE-USED AND RELOCATED AFTER REMOVAL OF LOADS SHALL BE POWERED. PROVIDE NEW CABLE AND CONDUIT OR EXTEND EXISTING CONDUIT AS REQUIRED AND PROVIDE NEW WIRING.
- REFER TO THE CONTRACT DRAWINGS FOR THE EXTENT OF DEMOLITION WORK REQUIRED, INCLUDING ANY OR ALL ITEMS WHETHER OR NOT SPECIFICALLY MENTIONED OR INDICATED WHICH INTERFERE WITH OR ARE UNNECESSARY TO THE PROPOSED CONSTRUCTION AND FINISHES. DISPOSAL OF ALL REMOVED MATERIALS AND RUBBISH SHALL BE AT THE CONTRACTORS EXPENSE.
- 9. WORK SHALL PROCEED ONLY ON A SCHEDULE APPROVED BY METRO NORTH RAILROAD FACILITY, AND ALL WORK SHALL BE COORDINATED WITH THE STATION WORK SCHEDULE TO MINIMIZE INCONVENIENCE AND DISTURBANCE. WORK NORMALLY HANDLED BY HEATING AND VENTILATING. PLUMBING AND FIRE PROTECTION AND ELECTRICAL CONTRACTOR SHALL BE DEMOLISHED AND REMOVED BY SUCH CONTRACTORS.
- 10. AT SCARSDALE STATION EXISTING 400A SERVICE, CURRENT TRANSFORMER, AND UTILITY COMPANY METER PAN SHALL REMAIN UNTIL THE NEW SERVICE IS INSTALLED.
- 11. AT SCARSDALE STATION EXISTING MDP WILL REMAIN. EXTEND CABLES AND CONDUITS FOR NEW POWER SOURCE AS REQUIRED AND AS INDICATED. SEE DRAWING SCD-E-402.
- 12. CONTRACTOR SHALL MAINTAIN CONTINUOUS POWER SERVICES TO THE STATION THROUGHOUT THE DURATION OF CONSTRUCTION. COORDINATE ALL REQUIRED SHUTDOWNS WITH CON EDISON AND METRO NORTH RAILROAD TO MINIMIZE POWER DISRUPTION. CONTRACTOR SHALL PROVIDE PORTABLE GENERATOR AS REQUIRED TO MAINTAIN SERVICE DURING SWITCHOVERS. SWITCHOVERS SHALL ONLY BE ALLOWED DURING 3RD SHIFT OR WEEKENDS WITH 14 DAYS ADVANCED WRITTEN NOTICE TO METRO-NORTH RAILROAD AND CON EDISON.
- 13. THE CONTRACTOR SHALL MAINTAIN EXISTING UTILITIES AND SERVICES THROUGHOUT THE EXECUTION OF WORK.
- 14. IDENTIFY ALL SOURCES OF POWER AND DE-ENERGIZE REQUIRED CIRCUITS BEFORE COMMENCEMENT OF WORK.
- 15. ALL DEMOLITION WORK SHALL CONFORM WITH NEC. NYS CODE, LOCAL CODE AND MNR REQUIREMENTS.
- 17. THE CONTRACTOR SHALL NOT REMOVE ANY EXISTING CABLES OR COMPONENTS WITHOUT PRIOR WRITTEN NOTICE TO PROCEED FROM THE ENGINEER

DESIGNED	VC	TE OF NEW LO									-
DRAWN	SK	E GINI GOLDING									-
CHECKED	GG	you diff	NO.	DATE		DRWN	СНКД	APPVD	NO.	DATE	
APPROVED	GG	DFESSION			REVISION						

### **GENERAL NOTES:**

- 1. ALL WORK SHALL CONFORM TO THE REQUIREMENTS OF THE NATIONAL ELECTRIC CODE. NATIONAL ELECTRIC SAFETY CODE, CON EDISON, NYS UNIFORM FIRE PREVENTION AND BUILDING CODE. OSHA REGULATIONS. AND ALL OTHER EXISTING CODES AND **REGULATIONS OF AUTHORITIES WHICH WOULD HAVE JURISDICTION.**
- 2. GENERAL NOTES APPLY TO ALL ELECTRICAL, FIRE ALARM, AND LIGHTING DRAWINGS UNDER THIS CONTRACT. REFER TO INDIVIDUAL DRAWINGS FOR ADDITIONAL NOTES.
- 3. THE CONTRACT DRAWINGS ARE DIAGRAMMATIC IN NATURE AND NOT EVERY DETAIL OR CONDUIT IS SHOWN. ANY DEPARTURE FROM CONCEPT SHOWN IN THE CONTRACT DRAWINGS SHALL BE SUBMITTED TO THE ENGINEER FOR APPROVAL.
- THE CONTRACTOR SHALL PRODUCE SHOP DRAWINGS AND SUBMIT THEM TO THE 4. ENGINEER FOR APPROVAL PRIOR TO INSTALLATION. SHOP DRAWINGS SHALL INCLUDE, BUT NOT BE LIMITED TO:
  - a) INTERCONNECTING RACEWAY, FEEDER AND CIRCUITING PLANS, AND SECTIONS IN ALL ELECTRIC SPACES FOR OVERPASS, PLATFORM, PASSAGE WAY, EMR AND ANY OTHER AFFECTED AREAS.
  - b) DIMENSIONED INSTALLATION LAYOUTS OF THE EQUIPMENT, PANELS, BOXES, LIGHTING FIXTURES, RACEWAYS AND SUPPORT ITEMS.
  - c) PHYSICAL LAYOUT OF CONTRACTOR PROVIDED CUSTOM EQUIPMENT SUCH AS CABINETS, PANELS, RELAY BOXES, PULL AND TERMINAL BOXES, MANHOLES, ETC.
  - d) INTERCONNECTION WIRING DIAGRAMS BETWEEN RELATED EQUIPMENT AND PANEL SCHEDULES.
- 5. CABLES RATED 600VAC SHALL BE TYPE XHHW-2 FOR EXTERIOR LOCATIONS AND TYPE XHHW-2 OR DUAL RATED THHW/THWN IN INDOOR LOCATIONS UNLESS OTHERWISE NOTED. UTILITY 208/120V SERVICE CONDUCTORS SHALL BE TYPE USE-2/RHW-2, AS PER SPEC SECTION 26 05 19.
- ELBOWS AND STUB-UPS THROUGH CONCRETE FOUNDATIONS AND SLABS SHALL BE RIGID 6. GALVANIZED STEEL, UNLESS OTHERWISE NOTED.
- 7. FURNISH AND INSTALL GROUND WIRE IN ALL CONDUIT RUNS FOR 120V CIRCUIT OR HIGHER, SIZED PER NATIONAL ELECTRIC CODE BUT NOT LESS THAN #12 AWG.
- UNDERGROUND ELECTRICAL CONDUITS ROUTING ON PLANS ARE SHOWN FOR CLARITY ONLY. 8. EXACT ROUTING AND TERMINATION LOCATION SHALL BE COORDINATED IN THE FIELD WITH THE EXISTING UNDERGROUND UTILITIES AND ADJACENT INFRASTRUCTURES.
- CONDUITS SHALL CONTAIN AN INSULATED GROUND WIRE BONDED TO ENCLOSURES AND SIZED IN 9 ACCORDANCE WITH THE REQUIREMENTS OF THE NEC, IF SIZE IS NOT SHOWN ON THE CONTRACT DRAWINGS.
- 10. UNLESS OTHERWISE NOTED, EQUIPMENT AND MATERIAL TO BE FURNISHED AND INSTALLED SHALL BE NEW AND SHALL BEAR UL LISTING AND LABELING WHERE SUCH STANDARD HAS BEEN ESTABLISHED FOR THAT TYPE OF EQUIPMENT/MATERIAL.
- 11. FURNISH AND INSTALL TAGS FOR EQUIPMENT. CONDUITS AND CABLES THAT ARE INSTALLED UNDER THIS CONTRACT. TAG IDENTIFICATIONS SHALL BE IN ACCORDANCE WITH CONTRACT DRAWINGS.
- 12. FURNISH AND INSTALL CONDUIT FITTINGS, CONDUITS, CONNECTORS, CLAMPS, HARDWARE AND SUPPORTS AS NECESSARY FOR A COMPLETE INSTALLATION.
- 13. RACEWAYS RUNNING THROUGH STRUCTURE CONSTRUCTION JOINTS SHALL BE EQUIPPED WITH EXPANSION AND DEFLECTION FITTINGS.

- LINES.
- COMMENCEMENT.
- SATISFACTION OF THE ENGINEER.
- SITE.

- GLASS-FACED ELEVATOR.
- STEEL.

CONFORMED			
	DRWN	CHKD	APPVD
REVISION			





14. UON, CABLE, CONDUIT AND EQUIPMENT TO BE FURNISHED AND INSTALLED UNDER THIS CONTRACT ARE SHOWN IN HEAVY LINES. EXISTING EQUIPMENT AND WIRING IS SHOWN BY LIGHT

15. THE CONTRACTOR SHALL BE RESPONSIBLE TO OBTAIN ALL PERMITS NECESSARY TO PERFORM THE WORK SHOWN ON THESE DRAWINGS FROM THE APPROPRIATE AGENCIES PRIOR TO

16. THE CONTRACTOR SHALL USE CARE IN PERFORMING THE WORK SO AS NOT TO DAMAGE EXISTING STRUCTURE OR EQUIPMENT. THE CONTRACTOR SHALL REPAIR ANY DAMAGE CAUSED DURING CONSTRUCTION AT NO ADDITIONAL COST TO THE OWNER, AND TO THE FULL

17. UPON COMPLETION OF ALL ELECTRICAL WORK, ELECTRICAL CONTRACTOR SHALL BALANCE ALL PANELBOARDS AFFECTED TO WITHIN 10% DEVIATION BETWEEN PHASES.

18. AFTER COMPLETION OF WORK, CLEAN UP ALL RESULTANT DEBRIS AND REMOVE FROM THE

19. CONTRACTOR SHALL PROVIDE COORDINATION STUDY FOR ALL THE OVERCURRENT PROTECTION DEVICES SPECIFIC TO THE EQUIPMENT TO BE PURCHASED AND INSTALLED.

20. CONTRACTOR SHALL PROVIDE NEW ELECTRICAL SERVICE, SERVICE EQUIPMENT AND COORDINATE WITH CON EDISON AS SHOWN IN THE PLANS, ALL SERVICE EQUIPMENT AND INSTALLATION SHALL COMPLY WITH CON EDISON REQUIREMENTS.

21. CON EDISON CONTACT IS SEAN WALDRON - EMAIL ADDRESS IS WALDRONS@CONED.COM

22. PROVIDE CONDUIT ROUTING PLAN TO MNR FOR APPROVAL. DO NOT INSTALL CONDUIT ON

23. CONDUIT INSTALLED ABOVE GROUND OUTDOORS SHALL BE PVC COATED RIGID GALVANIZED


	100% RFC SU	BMISSI	ON
	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733	
ailroad	IMPROVEMENTS	SCALE	DATE
	ELECTRICAL GENERAL		08/03/2021
	NOTES	DRAWING NO.	
		SCD-E	-001
	SCARSDALE STATION	SHEET <b>74</b> O	F <b>112</b>


J OR J	JUNCTION BOX AS REQUIRED
	BRANCH CIRCUIT HOME RUN TO PANELBOARD. INDICATES PANEL CIRCUIT DESIGNATION
	LIGHT LINE - EXISTING EQUIPMENT/CONDUIT TO REMAIN
	DARK LINE1.NEW POWER EQUIPMENT TO BE INSTALLED OR2.NEW POWER CONDUIT TO BE INSTALLED EXPOSED ABOVE MEZZ./PLATFORM STRUCTURE OR IN ROOMS (U.O.N.)
	DARK DASHED LINE - CONDUIT CONCEALED EMBEDDED IN CONCRETE
•	CONDUIT TURNING DOWN
O	CONDUIT TURNING UP
	GFCI DUPLEX RECEPTACLE, 20A, 120VAC. G - INDICATES GROUND FAULT CIRCUIT INTERRUPTER (GFCI) WP - INDICATES WEATHER PROOF IG - INDICATES ISOLATED GROUND
60	ENCLOSED CIRCUIT BREAKER, RATING AS INDICATED ON PLANS, SQUARE "D", OR APPROVED EQUAL.
/// OR X	PANELBOARD, 120-208VAC, 3PH, 4W, S.N. SIZE AS INDICATED ON PLANS X INDICATES NAME OF PANEL.
	FUSED DISCONNECT SWITCH, AMPERE, POLE AND FUSE SIZE AS INDICATED, 60" AFF., WP INDICATES WEATHER PROOF.
	UNFUSED DISCONNECT SWITCH, AMPERE AND POLE AS INDICATED, 60" AFF, WP INDICATES WEATHER PROOF.
	ELECTRIC MOTOR
	METER
J OR J	JUNCTION BOX TO BE REMOVED
	EXISTING FIXTURE TO BE REMOVED
	LIGHT DOTTED LINE - REMOVALS
	ELECTRICAL PANEL TO BE REMOVED
	DISCONNECT SWITCH TO BE REMOVED
	EXISTING PANEL TO REMAIN
(M)	EXISTING METER TO BE REMOVED
	EXISTING POLE-MOUNTED LIGHTING FIXTURE TO BE REMOVED
	ELECTRIC UNIT HEATER
	EXISTING ELECTRIC UNIT HEATER TO BE REMOVED
PLB	PROPERTY LINE BOX
SPD	SURGE PROTECTION DEVICE
S	TOGGLE SWITCH, 30A, 120-277 VAC, IP, PASS AND SEYMOUR CAT. NO. 30AC1. MOUNTED IN CROUSE HINDS "FD" BOX WITH LUGS AND HUB


DESIGNED	VC										CONFORMED			
	VC	TE OF NEW L												
DRAWN	SK	SCHILL GOLDING												
CHECKED	GG	A Martin (1)		DATE		DDMAL			NO			DDIA		
ł	GG	Sources all	NO.	DATE		DRWN	CHKD	APPVD	NO.	DATE		DRWN	CHKD	APPVD
APPROVED	GG	OFESSIONAL			REVISION						REVISION			

## /IATIONS:

			1
AMPERES	MDB	MAIN DISTRIBUTION BOARD	
AMP FUSE	MDP	MAIN DISTRIBUTION PANEL	
AMP FRAME	MDS	MAIN DISTRIBUTION SWITCHBOARD	
AMERICAN SOCIETY FOR TESTING AND MATERIALS	MIN	MINIMUM	
AMP TRIP	MNR	METRO NORTH RAILROAD	
AMPERE SWITCH	MSB	MAIN SWITCHBOARD	
AMERICAN WIRE GAUGE CONDUIT, CONDUCTOR	Ν	NEUTRAL	
CONDUCTOR CONTINUATION	NEC	NATIONAL ELECTRIC CODE	
DISCONNECT SWITCH	NEMA	NATIONAL ELECTRICAL MANUFACTURER	
DISCONNECT SWITCH DRAWING(S)		ASSOCIATION	
ELECTRICAL	No	NUMBER	
ELEVATOR	NTS	NOT TO SCALE	
ELEVATOR MACHINE ROOM	PCD	PRECAST CONCRETE DUCT	
EXISTING	PH	PHASE	
EMERGENCY	PLB	PROPERTY LINE BOX	
EXISTING TO REMAIN	PNL	PANELBOARD	
FEEDER	PP	POWER PANEL	
GROUND	R	REMOVE	
GROUND FAULT	RGS	RIGID GALVANIZED STEEL	
GROUND FAULT CIRCUIT INTERRUPTER	SCH	SCHEDULE	
GROUND	SDB	SECOND DISTRIBUTION BOARD	
HERTZ	SEC	SECONDARY	
INCH	SWBD	SWITCHBOARD	
JUNCTION BOX	TYP.	TYPICAL	
KILOWATT	UL	UNDERWRITER'S LABORATORY	
LIGHT EMITTING DIODE	UON	UNLESS OTHERWISE NOTED	
LIGHTING POLE	V	VOLT	
LOW VOLTAGE	VAC	VOLT ALTERNATING CURRENT	
MAXIMUM	W	WATTS	
MAIN CIRCUIT BREAKER	WP	WEATHERPROOF	







HTIN	ITING SCHEDULE										
1BOL	ID	DESCRIPTION	MOUNTING TYPE	MANUFACTURER	MODEL #	LUMENS	VOLTAGE	LAMP TYPE	COLOR TEMP (K)	INPUT WATTS	REMARKS
	AA	48" EMS LED FIXTURE, 4000 LM, FROSTED OPTIC, WET IP66 RATED WITH BUILT-IN EMERGENCY BATTERY	SURFACE	HOLOPHANE	*EMS L48 4000LM IMAFD WD 120 GZ10 40K 80CRI BSL520 DPMD SPD STSL TRS	6321	120	LED	4000	44.58	EMR
	В	4.5' LED STRIP ARCHWAY PASSAGE FIXTURE,6000 LUMENS, FROSTED POLYCARBONATE LENS, WET IP66 RATED	SURFACE	HOLOPHANE	EVT4 6000LM FST MD MVOLT GZ10 35K 80CRI STSL	5637	120	LED	3000	63.73	OVERPASS ELEV LOBBY
	BB	SAME AS "B" EXCEPT WITH EMERGENCY BATTERY	SURFACE	HOLOPHANE	*EVT4 6000LM FST MD MVOLT GZ10 35K 80CRI E15WCP STSL	5637	120	LED	3000	63.73	OVERPASS ELEV LOBBY
	VR	SURFACE VANDAL RESISTANT, LED, 12.75" x 12.75", 300K, 0.156" K12 PRISMATIC POLYCARBONATE, LISTED FOR WET LOCATION - PROVIDE EMERGENCY BATTERY	SURFACE	ECLIPSE LIGHTING	*RM533 SERIES LED 3K 120 BZ 81 9002 FUS	5200	120	LED 40	3000	40	PLATFORM ELEV CANOPY
C	Ρ	WALL/CEILING MOUNTED VAPOR TIGHT FIXTURE. LISTED FOR WET LOCATION.	WALL MOUNTED	PHONEIX	VP-W-26-120-GPC-G	1710	120	QUAD CFL	3000	26	ELEVATOR PIT
	W	15.5" WALPACK FULL CUTOFF LED EXTERIOR BUILDING FIXTURE - PROVIDE BUILT IN PHOTOCELL AND EMERGENCY BATTERY.	SURFACE	HOLOPHANE	*HLWPC2 P30 30K 12 T3M AO	7058	120	LED	3000	71	EMR OUTDOOR

\*MODEL NUMBERS DO NOT INCLUDE BATTERY PACK. CONTRACTOR TO PROVIDE BATTERY PACKS WHERE INDICATED.





## AIR TERMINAL

LIGHTNING PROTECTION CONDUCTOR

DOWN LEAD

GROUND ROD

GROUND ROD


EXOTHERMIC WELD

GROUND TEST WELL

## **GROUNDING CONNECTIONS - ALL** CONNECTIONS TO BE THERMOWELD

	WELDED		WELDED
NECTION	CADWELL CAT#	TYPE OF CONNECTION	CADWELL CAT#
LUG	LA		HA OR VS
	GT	CABLE TO FLAT SURFACE	-
	GR		HA OR HS
ABLE CABLE	TV OR TA		

			011		
	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733			
lailroad	IMPROVEMENTS	SCALE	DATE		
	ELECTRICAL SYMBOL LIST		08/03/2021		
	AND ABBREVIATIONS	DRAWING NO.			
		SCD-E	-002		
	SCARSDALE STATION	SHEET <b>75</b> 0.	F 112		



CONFORMED			
	DRWN	CHKD	APPVD
D D T T T O T O M			


- 1. FOR GENERAL NOTES, SYMBOLS AND ABBREVIATIONS SEE DRAWINGS SCD-E-001 AND SCD-E-002.
- 2. EXISTING OVERPASS IS CALLED UNDER ARCHITECTURAL DRAWINGS TO BE RAISED BY 7". ALL ASSOCIATED ELECTRICAL WORK SHALL BE COORDINATED WITH THE GC AND STRUCTURAL WORK.
- 3. IDENTIFY/CONFIRM AND RECORD ALL EXISTING ELECTRICAL CONDUITS ROUTED AND SUPPORTED FROM EXISTING OVERPASS TO BE RAISED. VERIFY AND CONFIRM THE EXACT LOCATION OF THE CONDUIT WHERE IT CAN BE INTERCEPTED TO EXTEND THE CONDUIT AND WIRE. EXISTING CONDUITS CAN BE RE-USED AND EXTENDED. PROVIDE NEW WIRES AND REQUIRED AMOUNT OF CONDUIT. ALL AFFECTED EXISTING LOADS SHALL BE BACK TO ORIGINAL OPERATIONAL CONDITION WHEN WORK IS COMPLETED. DE-ENERGIZE ALL THE LOADS PRIOR COMMENCEMENT OF WORK.
- 4. MAINTAIN POWER TO THE EXISTING STATION HEADHOUSE AND CONCESSION. PROTECT PULLBOXES FEEDERS AS REQUIRED OR PROVIDE TEMPORARY POWER TO THE BUILDING DURING CONSTRUCTION.
- 5. EXISTING COMM ROOM WILL BE REMOVED. EXISTING POWER SUPPLY SHALL BE DISCONNECTED AND REMOVED INCLUDING POWER PANEL, CABLE & CONDUIT.
- 6. POWER TO THE EXISTING VENDING MACHINE OUTSIDE THE COMM ROOM SHALL BE DISCONNECTED AND REMOVED.
- 7. EXISTING MAIN DISTRIBUTION BOARD SHALL REMAIN.
- 8. VERIFY AND CONFIRM IN THE FIELD WHERE THE TERMINATION OF THE CONDUITS ARE LOCATED. THE SPARE CONDUIT WILL BE USED FOR THE STATION MAIN SERVICE UPGRADE TO THE NEW SERVICE EQUIPMENT.

# 100% RFC SUBMISSION

ailroad	HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733		
	IMPROVEMENTS	SCALE 1/8"=1'-0"	DATE <b>08/03/2021</b>	
	POWER PLAN - PLATFORM LEVEL	drawing no.	D-101	
	SCARSDALE STATION		F 112	

۵.


		_



CONFORMED			
	DRWN	CHKD	APPVD

- 1. FOR GENERAL NOTES, SYMBOLS AND ABBREVIATIONS SEE DRAWINGS SCD-E-001 AND SCD-E-002.
- 2. EXISTING UNIT HEATERS WILL BE REPLACED IN KIND. REMOVE EXISTING HEATER WITH ITS ASSOCIATED CONTROLS. EXISTING POWER SUPPLY CONDUIT SHALL BE RE-USED. POWER SUPPLY SHALL BE DE-ENERGIZED PRIOR TO REMOVAL WORK. VERIFY AND CONFIRM POWER SOURCE PRIOR TO COMMENCEMENT OF WORK. FURNISH AND INSTALL NEW HEATER TO MATCH EXISTING.
- 3. EXISTING OVERPASS IS CALLED UNDER ARCHITECTURAL DRAWINGS TO BE RAISED BY 7". ALL ASSOCIATED ELECTRICAL WORK SHALL BE COORDINATED WITH THE GC AND STRUCTURAL WORK.
- IDENTIFY AND RECORD ALL EXISTING ELECTRICAL CONDUITS ROUTED AND SUPPORTED FROM EXISTING OVERPASS TO BE RAISED. VERIFY AND CONFIRM THE EXACT LOCATION OF THE CONDUIT WHERE IT CAN BE INTERCEPTED TO EXTEND THE CONDUIT AND WIRE. EXISTING CONDUITS CAN BE RE-USED AND EXTENDED. PROVIDE NEW WIRES AND REQUIRED AMOUNT OF CONDUIT. ALL AFFECTED EXISTING LOADS SHALL BE BACK TO ORIGINAL OPERATIONAL CONDITION WHEN WORK IS COMPLETED. DE-ENERGIZE ALL THE LOADS PRIOR COMMENCEMENT OF WORK

ailroad	TITLE HARTSDALE AND SCARSDALE STATION	<i>CONTRACT NO.</i> <b>1000106733</b>	
	IMPROVEMENTS ELECTRIC DEMOLITION	SCALE 1/8"=1'-0"	DATE <b>08/03/2021</b>
	POWER PLAN - OVERPASS LEVEL	drawing no.	D-102
	SCARSDALE STATION		F 112




- 1. FOR GENERAL NOTES, SYMBOLS AND ABBREVIATIONS SEE DRAWINGS SCD-E-001 AND SCD-E-002.
- 2. CONDUIT RUNS SHALL BE COORDINATED IN THE FIELD WITH EXISTING CONDITIONS.
- 3. REFER TO DRAWINGS SCD-E-301 AND SCD-E-302 FOR ENLARGED PLANS.

### KEY NOTES:

- (1) EXISTING ELECTRICAL MAIN SERVICE ENCLOSURE "MDP" SEE DRAWING SCD-E-301 FOR ENLARGED PLAN AND DRAWINGS SCD-E-401, AND SCD-E-402 FOR EXISTING AND PROPOSED ONE LINE DIAGRAMS.
- NEW ELECTRICAL SERVICE EQUIPMENT WITH MAIN DISTRIBUTION BOARD. SEE DRAWING E-301 FOR ENLARGED PLAN AND DRAWING SCD-E-402 FOR NEW SINGLE LINE DIAGRAM AND FEEDER SIZE.
- (3) ELEVATOR #2 PROVIDE POWER TO THE ELEVATOR AND ITS AUXILIARY EQUIPMENT FROM PP-EMR. SEE DRAWINGS SCD-E-302, 402, & 403 FOR DETAILS.
- 4 ELEVATOR #2 ELEVATOR MACHINE ROOM (EMR) PROVIDE POWER TO ELEVATOR MACHINE ROOM FROM NEW DISTRIBUTION BOARD IN ELECTRICAL SPACE ON OUTBOUND PLATFORM. SEE DRAWINGS SCD-E- 302, 402, & 403 FOR DETAILS.
- 5 COMMUNICATION ROOM PROVIDE POWER TO COMM. ROOM FROM NEW DISTRIBUTION BOARD IN ELECTRICAL SPACE ON OUTBOUND PLATFORM. SEE DRAWING SCD-E-302 FOR DETAILS.


Railroad	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733		
	IMPROVEMENTS ELECTRICAL POWER PLAN PLATFORM LEVEL	SCALE 1/8"=1'-0"	DATE <b>08/03/2021</b>	
		drawing no.	-101	
	SCARSDALE STATION	SHEET <b>78</b> 0.	F <b>112</b>	



CONFORMED			
	DRWN	CHKD	APPVD
PFVISION			

- 1. FOR GENERAL NOTES, SYMBOL LIST AND ABBREVIATIONS SEE DRAWINGS SCD-E-001 AND SCD-E-002
- 2. EXISTING ELECTRIC UNIT HEATERS SHALL BE REPLACED IN-KIND AND SHALL BE POWERED FROM THE SAME POWER SUPPLY UTILIZING EXISTING CABLE AND CONDUIT.
- 3. ROUTE PP-EMR2 AND PP-COMM FEEDER CONDUIT AT THE EXTERIOR SIDE OF THE OVERPASS. COORDINATE EXACT LOCATION WITH EXISTING CONDITION.
- 4. SEE DRAWING SCD-E-402 FOR ELECTRICAL SINGLE LINE DIAGRAM FOR CONDUIT AND CABLE SIZES.

ailroad	HARTSDALE AND SCARSDALE STATION	1000106733		
	IMPROVEMENTS ELECTRICAL POWER PLAN OVERPASS LEVEL	SCALE 1/8"=1'-0"	DATE <b>08/03/2021</b>	
		DRAWING NO.		
		SCD-E	-102	
	SCARSDALE STATION	SHEET <b>79</b> O	F 112	




CONFORMED				
	DRWN	CHKD	APPVD	
REVISION				

420 Lexington Avenue New York, NY 10017

## NOTES:

- 1. FOR GENERAL NOTES, SYMBOLS AND ABBREVIATIONS SEE DRAWINGS SCD-E-001 AND SCD-E-002.
- 2. POWER CONDUITS ATTACHED OR SUPPORTED ON THE OVERPASS STRUCTURE SHALL BE INTERCEPTED AND ADJUSTED TO ACCOMMODATE THE STRUCTURE HEIGHT ADJUSTMENT. OVERPASS WILL BE ADJUSTED 7" HIGHER. MAKE THE CONDUIT ADJUSTMENT IN THE EXISTING PULL OR FITTINGS NEAR THE GROUND. PROVIDE NEW CABLE, REQUIRED BOXES AND FITTINGS. COORDINATE WORKS WITH THE EXISTING CONDITION.

Railroad	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733		
		SCALE 3/16"=1'-0"	DATE <b>08/03/2021</b>	
	ELECTRICAL OVERPASS	drawing no.	-201	
	SCARSDALE STATION	SHEET <b>80</b> OL	F 112	



1. FOR GENERAL NOTES, SYMBOLS AND ABBREVIATIONS SEE DRAWINGS SCD-E-001 AND SCD-E-002.

2. CONTRACTOR SHALL SURVEY THE AREA AND VERIFY AND CONFIRM THE EXACT LOCATION AND DIMENSION OF THE EXISTING ELECTRICAL SPACE AND EQUIPMENT.

3. CONDUIT LAYOUT IS DIAGRAMMATIC, CONTRACTOR SHALL COORDINATE THE EXACT ROUTING WITH THE EXISTING FIELD CONDITION.

4. REFER TO DRAWING SCD-E-401 AND SCD-E-402 FOR EXISTING AND NEW ELECTRICAL ONE LINE DIAGRAMS AND FOR THE SIZES OF FEEDERS AND CONDUITS.

5. ALL ELECTRICAL SERVICE WORK SHALL BE COORDINATED WITH CON EDISON AND METRO NORTH.

6. DUCT BANK RUNS ARE DIAGRAMMATIC. THE EXACT LOCATIONS OF DUCT BANK RUNS SHALL BE VERIFIED AND CONFIRMED IN THE FIELD.

7. PRIOR TO COMMENCEMENT OF WORK, CONTRACTOR SHALL CALL CODE 53 (CALL-BEFORE-YOU-DIG IN NYS, TEL# 1-800-962-7962 FOR NYS ONE CALL CALL CENTER) FOR LOCATION OF UTILITIES (NYS INDUSTRIAL CODE RULE 53-12 NYC RR 53). CONTRACTOR SHALL HAND DIG.

8. ALL EXCAVATION SHALL BE BY HAND TO PROTECT EXISTING UNDERGROUND FACILITIES. ALL CONDUITS TO BE INSTALLED SHALL BE SAW CUT AND HAND DIG.

9. FOR LANDSCAPING RENEWAL REFER TO LANDSCAPING DOCUMENTS.


- 10. STATION EXISTING ELECTRICAL SERVICE SHALL REMAIN UNTIL THE NEW ELECTRICAL SERVICE AND SERVICE EQUIPMENT IS FULLY INSTALLED, INSPECTED, AND OPERATIONAL. COORDINATE WITH CON EDISON.
- 11. ALL REQUIRED SHUTDOWN SHALL BE COORDINATED WITH MNR.
- 12. USE EXISTING SPARE CONDUIT IN EXISTING PLB AND THE EXISTING CONDUIT SERVING THE STATION FOR THE NEW ELECTRICAL SERVICE FEEDS TO NEW SERVICE EQUIPMENT OR SWITCHBOARD. FURNISH AND INSTALL NEW CONDUIT IN NEW UNDERGROUND DUCT BANK.
- 13. ALL WORK AND INSTALLATIONS SHALL COMPLY WITH THE CODES AND CON EDISON REQUIREMENTS.

KEYED NOTES:

- (1) PANEL B EXISTING TO REMAIN
- 2 PANEL A EXISTING TO REMAIN
- (3) PANEL C EXISTING TO REMAIN
- (4) GE MOBILE COMM PANEL EXISTING TO REMAIN
- (5) COMM BOX EXISTING TO REMAIN
- (6) EXISTING SERVICE END BOX
- (7) MAIN DISTRIBUTION BOARD EXISTING TO REMAIN
- (8) EXISTING CT CABINET TO BE REMOVED. COORDINATE WITH CON EDISON ALL ASSOCIATED WORK .
- (9) EXISTING CON ED METERS TO BE REPLACED BY NEW METERS MOUNTED IN NEW LOCATION
- (10) NEW ELECTRICAL SERVICE EQUIPMENT AND SWITCHBOARD
- D NEW SURGE PROTECTION DEVICE KINDORF-MOUNTED NEAR ELECTRICAL SERVICE EQUIPMENT ENCLOSURE

100% RFC SU	BMISSION
	GONER LOE NO


ailroad	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733			
		SCALE 1/4"=1'-0"	DATE <b>08/03/2021</b>		
	ELECTRIC SERVICE	drawing no.	-301		
	SCARSDALE STATION	SHEET <b>81</b> O	F <b>112</b>		



- 1. FOR GENERAL NOTES, SYMBOLS AND ABBREVIATIONS, SEE DI SCD-E-001 AND SCD-E-002.
- 2. POWER SUPPLY TO EMR 2 EQUIPMENT AND ELEVATOR PIT SH FROM PANEL 'PP-EMR-2'. COMMUNICATION ROOM EQUIPMENT BE POWERED FROM DEDICATED PANEL 'PP-COMM'. REFER TO SCD-E-403 FOR PANEL SCHEDULES.
- 3. COORDINATE LOCATION OF ALL DEVICES, LIGHTS, AND PANEL ELEVATOR CONTRACTOR.
- 4. PROVIDE GROUNDING CONNECTION BETWEEN GROUNDING B AND ALL ELECTRICAL PANELS AND DISCONNECT SWITCHES IN AND COMMUNICATION ROOM AS PER SPECIFICATIONS. SEE I SCD-E-402 FOR CONNECTIONS.

					$\sim$ STV $\sim$ 100	Mot
					225 PARK AVENUE SOUTH	420 Lex
						New Yo
TE		DRWN	CHKD	APPVD	NEW YORK, NY 10003	
	P H' V I S I O N					


	KEY	<u>NOTES</u> :	
DRAWINGS	$\langle 1 \rangle$	PP-EMR. POWER FROM ELECTRICAL MAIN DIST #500 KCMIL & 1 #1/0G, 4" CONDUIT.	RIBUTION PANEL WITH 4
SHALL BE NT SHALL FO DWG	2	ELEVATOR FUSED DISCONNECT SWITCH. PROV SWITCH WITH 4#4/0 1 #2G IN 2-1/2" CONDUIT. EI SHALL BE EQUIPPED WITH AN ELECTRICAL INT 'NC' CONTACTS FOR CONNECTION TO THE AUT DEVICE.	LEVATOR DISC. SWITCH ERLOCK KIT WITH 'NO' &
ELS WITH	$\langle 3 \rangle$	ELEVATOR CONTROLLER. POWER FROM ELEV 1#2G IN 2-1/2" CONDUIT.	DISC. SWITCH WITH 4#4/0
BUS BAR IN EMR	<u>(</u> 4)	ELEVATOR CAB LIGHTING AND EF DISC. SWITCH FUSED DISCONNECT SWITCH (FUSE AT 20A) AN WITH 2#12 & 1#12G IN 3/4"C.	
DRAWING	<b>(5)</b>	OUTDOOR CONDENSER UNITS (SEE MECHANIC EQUIPMENT SELECTION). PROVIDE NEMA 4X, S RATED, 60A, 240V, DISCONNECT SWITCHES AND WITH 2#8 & 1#10G IN 3/4"C.	TAINLESS STEEL, IP65
	<u>(6</u> )	PROVIDE DEDICATED WEATHERPROOF GFCI OF ROOM FOR OUTDOOR UNITS WITH 2#12 & 1#120	
	$\langle 7 \rangle$	POWER ALL GFCI RECEPTACLES FROM PP-EMF 3/4"C.	R WITH 2#12 & 1#12G IN
	<u>(8</u> )	PROVIDE DEDICATED OUTLETS FOR SCAVENGE SUMP PIT FROM PP-EMR WITH 2#10 & 1#12G IN	
	<b>(9</b> )	PROVIDE DEDICATED POWER OUTLET FOR ELE FROM PP-EMR WITH 2#10 & 1#10G IN 3/4"C.	EVATOR PIT AND POWER
	(10)	PROVIDE RECEPTACLE FOR SUMP PUMP AND F WITH 2#10 & 1#10G IN 3/4"C. RECEPTACLE TO E WATER LINE. IN ADDITION TO POWER CONDUC CABLE (CONTRACTOR TO CONFIRM SIZE OF CO PUMP TO SUMP PUMP CONTROL PANEL IN THE ROOM.	BE LOCATED ABOVE THE T, PROVIDE 1-1/2"C AND ONDUIT) FROM SUMP
	(11)	PROVIDE DEDICATED CIRCUIT FOR ELEVATOR WITH 2#12 & 1#12G IN 3/4"C.	LIFT NET PANEL. POWER
	(12)	PROVIDE HEAT-TRACING SYSTEM TO HEAT TRA PUMP DISCHARGE LINE AND POWER FROM PP- PANEL SHALL BE PROVIDED WITH 2-20A GFEP O COORDINATE EXACT LOCATION OF THE PIPES WITH PLUMBING AND ELEVATOR CONSULTANT BE XL-TRACE BY RAYCHEM CORPORATION OR HEAT TRACE DETAILS ON DWG. SCD-E-502.	EMR. HEAT TRACING CIRCUIT BREAKERS. TO BE HEAT TRACED . HEAT TRACE CABLE TO
	(13)	FIRE ALARM CONTROL PANEL - SEE DWG. SCD SUPPLY	-E402 FOR POWER
IG	(14)	POWER THE ELEVATOR POWER UNIT OIL COOL CIRCUIT IN PP-EMR WITH 2#10 & 1#12G IN 3/4"C. TO THE ELEVATOR PROVIDER.	
	(15)	PROVIDE 30A, 240V, FUSED DISCONNECT SWITC SYSTEM.	CH FOR FIRE ALARM
	(16)	BATTERY LOWERING DEVICE	
	(17)	PROVIDE 100A, 208V, 3PH, 4W PANELBOARD PP POWERED FROM THE MAIN DISTRIBUTION BOA SCD-E-402 FOR FEEDER SIZE.	
	(18)	POWER ALL GFCI RECEPTACLES IN COMM. RM. 2#12 & 1#12G IN 3/4"C.	FROM PP-COMM WITH
	(19)	POWER CEILING-MOUNTED DEDICATED RECEP FROM PP-COMM WITH 2#12 & 1#12G IN 3/4".	TACLE FOR CCTV RACK
	20>	PROVIDE INDOOR WALL-MOUNTED AC UNITS IN AND POWER FROM OUTDOOR AC UNITS WITH 2 AS INDICATED BY MANUFACTURER.	
	21>	PROVIDE GROUND BUS BAR. CONNECT TO GRO DRAWING SCD-E-501.	DUND GRID. SEE
	<b>(22)</b>	TELEPHONE TERMINAL BOX CONNECTION	
	23>	ELEVATOR CAB RECEPTACLES DISC. SWITCH. F FUSED DISCONNECT SWITCH (FUSED AT 20A) A PP-EMR WITH 2#12 & 1#12G IN 3/4"C.	
		100% RFC SU	BMISSION
		TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733
Railroad		IMPROVEMENTS ELECTRICAL EMR &	SCALE         DATE           1/2"=1'-0"         08/03/2021
		ELEVATOR PIT ENLARGED PART PLANS	drawing no. SCD-E-302
		SCARSDALE STATION	SHEET 82 OF 112



CONFORMED			
	DRWN	CHKD	APPVD
$D \Gamma U I \cap I \cap M$			

- 1. FOR GENERAL NOTES, SYMBOLS AND ABBREVIATIONS SEE DRAWINGS SCD-E-001 AND SCD-E-002.
- 2. REMOVE ALL THE POWER SUPPLY CABLE AND CONDUIT TO ALL EQUIPMENT TO BE DEMOLISHED UNLESS OTHERWISE NOTED. ALL REMOVAL WORK SHALL BE COORDINATED WITH MNR AND PHASING SCHEDULE.
- POWER SUPPLY TO THE STATION SHALL BE KEPT IN OPERATION 3. DURING CONSTRUCTION. ANY SHUTDOWN SHALL BE COORDINATED WITH MNR.
- 4. PROVIDE TEMPORARY POWER AS REQUIRED WHEN POWER SHUTDOWN IS REQUIRED AND/OR DURING THE SWITCH OF THE SERVICE.

	100% RFC SU	BMISSI	ON			
	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733				
Railroad		SCALE NTS	DATE <b>08/03/2021</b>			
	EXISTING ONE LINE	DRAWING NO.				
		SCD-E-401				
	SCARSDALE STATION	SHEET <b>83</b> O.	F <b>112</b>			



1.	FOR GENERAL NOTES, SYMBOLS AND ABBREVIATIONS SEE DRAWINGS SCD-E-001 AND SCD-E-002.	7.	CC			
		8.	SP			
2.	PROVIDE POWER SUPPLY TO ALL REQUIRED ELEVATOR AUXILIARY EQUIPMENT FROM RESPECTIVE POWER PANEL.	9.	TH CC			
3.	PROVIDE COPPER BUS FOR ALL ELECTRICAL EQUIPMENT.		PR CL			
4.	PROVIDE ELECTRONIC TRIP CIRCUIT BREAKER (LSI) FOR MAIN SERVICE SWITCH, MAIN DISTRIBUTION BOARD, ELEVATOR PANEL PP-EMR-2, AND ELEVATOR MOTOR CIRCUIT	10.	SE			
	BREAKER.					
5.	PROVIDE MULTIFUNCTION DIGITAL-METERING MONITOR IN MAIN DISTRIBUTION BOARD.	12.	AL			
6.	PROVIDE 6" CONCRETE PAD WITH FOUNDATION DESIGNED BY PROFESSIONAL STRUCTURE ENGINEER.	13.	IF I RE			

				PANELB	OARD SC	HEDULE				
		$\sim$								
MAIN F	ROTECTI	VE DEVICE: 400AF/300AT (LSI TYPE)		MOUNTI	NG: SURF	ACE		PANEL DESIGNATION:	EMR #2	
MAIN E	BUS RATIN	IG: 400 <b>A</b> , 65 <b>KAIC</b>		TYPE: N	IEMA 12			VOLTS: 120/208 PHASE: 3 WIRES:	4	
CKT NO.	TRIP AMPS	LOAD DESCRIPTION	VA	A	В	С	VA	LOAD DESCRIPTION	TRIP AMPS	CKT NO.
1	2004		18613	20013		(	1400	CAB LTG & FAN	20A	2
3	300A ((LSI))	ELEVATOR	18613		19789		1176	SUMP PUMP RECEPT	20A	4
5			18613			19789	1176	SCAVENGER PUMP RECEPT	20A	6
7	20A	SUMP PIT LIGHTING	26	206			180	PIT RECEPT	20A	8
9	20A	EMR LIGHTING	160		340		180	EMR RECEPT	20A	10
11	20A	OUTDOOR RECEPTACLE	180			360	180	EMR RECEPT	20A	12
13	40A	ACC-1/AC-1	1352	1532			180	EMR RECEPT	20A	14
15		A00-1/A0-1	1352		1352		0	- SPARE	20A -	16
17	20A	LIFT NET	1800			1800	0			18
19	20A	ELEVATOR OIL COOLER	1200	1200			0	SPARE	20A	20
21	20/1		1200		1700		500	HEAT TRACING SYSTEM	20A	22
23	20A	SPARE	0			500	500	(GFEP TYPE CB)	20/(	24
25	20A	SPARE	0	500			500	HEAT TRACING SYSTEM	20A	26
27	20A	SPARE	0		500		_ 500	GEEP TXPE-CB	20/1	28
29	20A	SPARE	0			500 /	500	TANK HEATER	20A	30
31	20A	BATTERY LOWERING DEVICE	500	860			360	CAB RECEPTACLES	) 20A	32
33	20A	SPARE	0		0		$\sim \sim$	SPARE	20A	34
35		SPACE				0		SPACE		36
37		SPACE		0				SPACE		38
39		SPACE			0			SPACE		40
41		SPACE				0		SPACE		42
				Α	В	С				
		TOTAL CONNEC	TED VA	24311	23681	22949				
		CONNECTED AMP	/PHASE	202.6	197.3	191.2				

DESIGNED	VC	OF NEW									
DRAWN	WF	STATE OF NEW LOOP									
CHECKED	GG	( you de la fin	NO.	DATE		DRWN	СНКД	APPVD	NO.	DATE	
APPROVED	GG	OFESSIONAL			REVISION						

NO.         AMPS         AMPS         AMPS           1         20A         *CCTV POWER SUPPLY FOR CAMERAS 4, 5, 6,7         400         560           3         20A         *CCTV POWER SUPPLY FOR CAMERAS 14, 15, 16,17         400         400           5         20A         *CCTV POWER SUPPLY FOR CAMERAS 18, 19, 20, 21         400         400           7         20A         CCTV RACK RECEPTACLE         1800         1980           9         40A         ACC-2/AC-2         1352         153           11         40A         ACC-2/AC-2         1352         153           13         20A         SPARE         0         0           15         20A         SPARE         0         0           17         20A         SPARE         0         0           19         20A         SPARE         0         0           21         20A         SPARE         0         0           23         20A         SPARE         0         0           24         SPARE         0         0         0           25         20A         SPACE         0         0           27         20A         SPACE <td< th=""><th></th><th></th><th></th><th></th><th>PANEL</th><th>BOARD</th></td<>					PANEL	BOARD
CKT         TRIP AMPS         LOAD DESCRIPTION         VA         A         B           1         20A         *CCTV POWER SUPPLY FOR CAMERAS 4, 5, 6, 7         400         560         400           3         20A         *CCTV POWER SUPPLY FOR CAMERAS 14, 15, 16, 17         400         400           5         20A         *CCTV POWER SUPPLY FOR CAMERAS 18, 19, 20, 21         400         400           7         20A         CCTV RACK RECEPTACLE         1800         1980         9           40A         ACC-2/AC-2         1352         153         113         20A         SPARE         0         0           15         20A         SPARE         0         0         0         1352         153           13         20A         SPARE         0         0         0         0           17         20A         SPARE         0         0         0         0         0           19         20A         SPARE         0         0         0         0         0           21         20A         SPARE         0         0         0         0         0           25         20A         SPACE         0         0         0 </th <th></th> <th>PROTECT</th> <th>IVE DEVICE: 100AF/100AT</th> <th></th> <th>MOUNT</th> <th>ING: <b>Sl</b></th>		PROTECT	IVE DEVICE: 100AF/100AT		MOUNT	ING: <b>Sl</b>
NO.         AMPS         LOAD DESCRIPTION         VA         A         B           1         20A         *CCTV POWER SUPPLY FOR CAMERAS 4, 5, 6,7         400         560           3         20A         *CCTV POWER SUPPLY FOR CAMERAS 14, 15, 16,17         400         400           5         20A         *CCTV POWER SUPPLY FOR CAMERAS 18, 19, 20, 21         400         400           7         20A         CCTV RACK RECEPTACLE         1800         1980           9         40A         ACC-2/AC-2         1352         153           11         0         ACC-2/AC-2         1352         153           13         20A         SPARE         0         0         0           15         20A         SPARE         0         0         0           17         20A         SPARE         0         0         0           19         20A         SPARE         0         0         0           21         20A         SPARE         0         0         0           25         20A         SPARE         0         0         0           27         20A         SPACE         0         0         0           31<	MAIN E	BUS RATI	NG: 200 <b>A</b> , 65 <b>KAIC</b>		TYPE:	NEMA 1
3         20A         *CCTV POWER SUPPLY FOR CAMERAS 14, 15, 16, 17         400         400           5         20A         *CCTV POWER SUPPLY FOR CAMERAS 18, 19, 20, 21         400         100           7         20A         CCTV RACK RECEPTACLE         1800         1980         1352         153           9         40A         ACC-2/AC-2         1352         153         113         20A         SPARE         0         0         0           13         20A         SPARE         0 <t< td=""><td></td><td></td><td>LOAD DESCRIPTION</td><td>VA</td><td>A</td><td>В</td></t<>			LOAD DESCRIPTION	VA	A	В
5         20A         *CCTV POWER SUPPLY FOR CAMERAS 18, 19, 20, 21         400         1800         1980           7         20A         CCTV RACK RECEPTACLE         1800         1980         1980           9         40A         ACC-2/AC-2         1352         153           11         40A         SPARE         0         0           13         20A         SPARE         0         0           15         20A         SPARE         0         0           17         20A         SPARE         0         0           19         20A         SPARE         0         0           21         20A         SPARE         0         0           23         20A         SPARE         0         0           25         20A         SPARE         0         0           27         20A         SPACE         0         0           29         20A         SPACE         0         0           31         20A         SPACE         0         0           33         20A         SPACE         0         0           33         20A         SPACE         0         0	1	20A	*CCTV POWER SUPPLY FOR CAMERAS 4, 5, 6,7	400	560	
7         20A         CCTV RACK RECEPTACLE         1800         1980           9         40A         ACC-2/AC-2         1352         153           11         0         0         0         0         0           13         20A         SPARE         0         0         0           15         20A         SPARE         0         0         0           17         20A         SPARE         0         0         0           19         20A         SPARE         0         0         0           21         20A         SPARE         0         0         0           23         20A         SPARE         0         0         0           25         20A         SPARE         0         0         0           27         20A         SPACE         0         0         0           29         20A         SPACE         0         0         0           31         20A         SPACE         0         0         0           33         20A         SPACE         0         0         0           33         20A         SPACE         0	3	20A	*CCTV POWER SUPPLY FOR CAMERAS 14, 15, 16,17	400		400
9         40A         ACC-2/AC-2         1352         153           11         40A         SPARE         0         0         0           13         20A         SPARE         0         0         0           15         20A         SPARE         0         0         0           17         20A         SPARE         0         0         0           19         20A         SPARE         0         0         0           21         20A         SPARE         0         0         0           23         20A         SPARE         0         0         0           25         20A         SPACE         0         0         0           27         20A         SPACE         0         0         0           31         20A         SPACE         0         0         0           33         20A         SPACE         0         0         0           33         20A         SPACE         0         0         0           33         20A         SPACE         0         0         0           37         20A         SPACE         0	5	20A	*CCTV POWER SUPPLY FOR CAMERAS 18, 19, 20, 21	400		
40A         ACC-2/AC-2         1352           13         20A         SPARE         0         0           15         20A         SPARE         0         0           17         20A         SPARE         0         0           19         20A         SPARE         0         0           19         20A         SPARE         0         0           21         20A         SPARE         0         0           23         20A         SPARE         0         0           25         20A         SPACE         0         0           27         20A         SPACE         0         0           31         20A         SPACE         0         0           33         20A         SPACE         0         0           34         20A         SPACE         0         0           <	7	20A	CCTV RACK RECEPTACLE	1800	1980	
11       1352         13       20A       SPARE       0       0         15       20A       SPARE       0       0         17       20A       SPARE       0       0         19       20A       SPARE       0       0         21       20A       SPARE       0       0         23       20A       SPARE       0       0         25       20A       SPACE       0       0         27       20A       SPACE       0       0         31       20A       SPACE       0       0         33       20A       SPACE       0       0         34       20A       SPACE       0       0         35       20A       SPACE       0       0         37       20A       SPACE       0       0         39       20A       SPACE       0       0         41       20A       SPACE       0	9	404				1532
15       20A       SPARE       0       0         17       20A       SPARE       0       0         19       20A       SPARE       0       0         21       20A       SPARE       0       0         23       20A       SPARE       0       0         25       20A       SPACE       0       0         27       20A       SPACE       0       0         29       20A       SPACE       0       0         31       20A       SPACE       0       0         33       20A       SPACE       0       0         34       SPACE       0       0       0         35       20A       SPACE       0       0         39       2	11	-07	A00-21A0-2	1352		
17       20A       SPARE       0       1         19       20A       SPARE       0       0         21       20A       SPARE       0       0         23       20A       SPARE       0       0         25       20A       SPACE       0       0         27       20A       SPACE       0       0         29       20A       SPACE       0       0         31       20A       SPACE       0       0         33       20A       SPACE       0       0         34       SPACE       0       0       0         35       20A       SPACE       0       0         39       20A       SPACE       0       0         39       20A       SPACE       0       0         41       2	13	20A	SPARE	0	0	
19         20A         SPARE         0         0           21         20A         SPARE         0         0           23         20A         SPARE         0         0           25         20A         SPACE         0         0           27         20A         SPACE         0         0           29         20A         SPACE         0         0           31         20A         SPACE         0         0           33         20A         SPACE         0         0           34         20A         SPACE         0         0           35         20A         SPACE         0         0           37         20A         SPACE         0         0           39         20A         SPACE         0         0           41         20A         SPACE         0         0 <td>15</td> <td>20A</td> <td>SPARE</td> <td>0</td> <td></td> <td>0</td>	15	20A	SPARE	0		0
21       20A       SPARE       0       0         23       20A       SPARE       0       0         25       20A       SPACE       0       0         27       20A       SPACE       0       0         29       20A       SPACE       0       0         31       20A       SPACE       0       0         33       20A       SPACE       0       0         34       20A       SPACE       0       0         35       20A       SPACE       0       0         37       20A       SPACE       0       0         39       20A       SPACE       0       0         41       20A       SPACE       0       0	17	20A	SPARE	0		
23       20A       SPARE       0       1         25       20A       SPACE       0       0         27       20A       SPACE       0       0         29       20A       SPACE       0       0         31       20A       SPACE       0       0         33       20A       SPACE       0       0         34       20A       SPACE       0       0         35       20A       SPACE       0       0         37       20A       SPACE       0       0         39       20A       SPACE       0       0         41       20A       SPACE       0       0	19	20A	SPARE	0	0	
25       20A       SPACE       0       0         27       20A       SPACE       0       0         29       20A       SPACE       0       0         31       20A       SPACE       0       0         33       20A       SPACE       0       0         35       20A       SPACE       0       0         37       20A       SPACE       0       0         39       20A       SPACE       0       0         41       20A       SPACE       0       0	21	20A	SPARE	0		0
27       20A       SPACE       0       0         29       20A       SPACE       0       0         31       20A       SPACE       0       0         33       20A       SPACE       0       0         33       20A       SPACE       0       0         33       20A       SPACE       0       0         35       20A       SPACE       0       0         37       20A       SPACE       0       0         39       20A       SPACE       0       0         41       20A       SPACE       0       0	23	20A	SPARE	0		
29       20A       SPACE       0       1         31       20A       SPACE       0       0         33       20A       SPACE       0       0         35       20A       SPACE       0       0         37       20A       SPACE       0       0         39       20A       SPACE       0       0         41       20A       SPACE       0       0	25	20A	SPACE	0	0	
31       20A       SPACE       0       0         33       20A       SPACE       0       0         35       20A       SPACE       0       0         37       20A       SPACE       0       0         39       20A       SPACE       0       0         41       20A       SPACE       0       0	27	20A	SPACE	0		0
33       20A       SPACE       0       0         35       20A       SPACE       0       0         37       20A       SPACE       0       0         39       20A       SPACE       0       0         41       20A       SPACE       0       0	29	20A	SPACE	0		
35         20A         SPACE         0            37         20A         SPACE         0         0            39         20A         SPACE         0         0         0           41         20A         SPACE         0         0	31	20A	SPACE	0	0	
37         20A         SPACE         0         0           39         20A         SPACE         0         0         0           41         20A         SPACE         0         0         0	33	20A	SPACE	0		0
39         20A         SPACE         0         0           41         20A         SPACE         0         0         0	35	20A	SPACE	0		
41 20A SPACE 0	37	20A	SPACE	0	0	
	39	20A	SPACE	0		0
	41	20A	SPACE	0		
A					A	В

TOTAL CONNECTED VA25401932CONNECTED AMP/PHASE21.216.1






CONFORMED			
	DRWN	CHKD	APPVD


REVISION


PANELBOARD SCHEDULE								
MOUN	ITING: <b>Sur</b> i	FACE		PANEL DESIGNATION:	PP-COMN	ОММ		
TYPE:	NEMA 12			VOLTS: 120/208 PHASE: 3 WIRES:	4			
A	В	С	VA	LOAD DESCRIPTION	TRIP AMPS	CKT NO.		
560			160	COMM RM LIGHTING	20A	2		
	400		0	SPARE	20A	4		
		580	180	RECEPTACLE	20A	6		
1980	)		180	RECEPTACLE	20A	8		
	1532		180	RECEPTACLE	20A	10		
		1532	180	RECEPTACLE	20A	12		
0			0	SPARE	20A	14		
	0		0	SPARE	20A	16		
		0	0	SPARE	20A	18		
0			0	SPARE	20A	20		
	0		0	SPARE	20A	22		
		0	0	SPARE	20A	24		
0			0	SPACE	20A	26		
	0		0	SPACE	20A	28		
		0	0	SPACE	20A	30		
0			0	SPACE	20A	32		
	0		0	SPACE	20A	34		
		0	0	SPACE	20A	36		
0			0	SPACE	20A	38		
	0		0	SPACE	20A	40		
		0	0	SPACE	20A	42		
Α	В	С						
4 2540	) 1932	2112						
E 21.2	16.1	17.6						


\* PROVIDE REQUIRED CABLE AND CONDUIT TO POWER EXISTING AND NEW CAMERA POWER SUPPLY. COORDINATION WITH COMMUNICATIONS. PROVIDE 2#10 & 1#10G TO POWER SUPPLIES IN 3/4"C.


	100% RFC SU	'BMISSI	ON		
	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT         NO.           DN         1000106733			
Railroad	IMPROVEMENTS	SCALE NTS	DATE <b>08/03/2021</b>		
	ELECTRICAL PANEL SCHEDULES	DRAWING NO.			
	SCARSDALE STATION	SCD-E-403 SHEET 85 OF 112			












Z

## NOTES:

- 1. FOR SYMBOL, ABBREVIATIONS, GENERAL NOTES AND LIGHTING FIXTURE SCHEDULE, SEE DWG SCD-E-001 AND SCD-E-002.
- 2. DISCONNECT AND REMOVE THE EXISTING LIGHTING FIXTURES SHOWN IN HIDDEN LINE. PROTECT THE POWER SUPPLY CABLE AND CONDUIT FOR RE-USE TO POWER THE NEW FIXTURES. DE-ENERGIZE THE POWER SUPPLY PRIOR DISCONNECTION.

ailroad	HARTSDALE AND SCARSDALE STATION	1000106733				
	IMPROVEMENTS	SCALE         DATE           1/8"=1'-0"         08/03/20				
	DEMOLITION PLAN OVERPASS LEVEL	drawing no.	D-101			
	SCARSDALE STATION		F 112			





	CONFORMED					
					225 PARK AVENUE SOUTH,	
DATE		DRWN	CHKD	APPVD	NEW YORK, NY 10003	
	PFVISION					


NOTES:


- 1. FOR GENERAL NOTES, SEE DRAWING SCD-E-001. FOR SYMBOLS, ABBREVIATIONS AND LIGHTING SCHEDULE, SEE DRAWING SCD-E-002.
- 2. POWER ALL THE LIGHTING FIXTURE FROM RESPECTIVE EMR ROOM POWER PANEL WITH 2 #12 AND 1#12G IN 3/4" CONDUIT. PROVIDE AN UNSWITCH HOT LEG WIRING TO FIXTURES WITH EMERGENCY BATTERY PACK OPERATION.
- 3. POWER THE LIGHTING FIXTURE ON THE PLATFORM ELEVATOR LOBBY FROM THE EXISTING PLATFORM LIGHTING PANEL PP-1 LOCATED IN THE EXISTING ELECTRICAL ENCLOSURE UTILIZING SPARE CIRCUITS WITH 2 #10 & 1#10G IN 3/4" CONDUIT. POWER THE EMERGENCY BATTERY PACK FROM THE EXISTING EMERGENCY CIRCUIT FEEDING THE EMERGENCY LIGHTS IN THE OVERPASS.
- 4. POWER THE SUMP PIT LIGHTING FIXTURE FROM RESPECTIVE EMR POWER PANEL WITH 2 #12 AND 1#12G IN 3/4" CONDUIT.
- 5. COORDINATE SUMP PIT LIGHTING AND SWITCH EXACT LOCATION WITH THE ELEVATOR PROVIDER.
- 6. COORDINATE CONDUIT ROUTING WITH THE EQUIPMENT AND OTHER TRADES.
- 7. SEE DRAWING SCD-E-403 FOR PANEL SCHEDULE.

	100% RFC SU	BMISSI	ON
	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733	
ailroad		SCALE 1/8"=1'-0"	DATE <b>08/03/2021</b>
	ELECTRICAL LIGHTING PLAN - PLATFORM LEVEL	drawing no.	-101
	SCARSDALE STATION	SHEET 89 O	F <b>112</b>









- 1. FOR GENERAL NOTES, SEE DRAWING SCD-E-001. FOR SYMBOLS, ABBREVIATIONS, AND LIGHTING FIXTURE SCHEDULE, SEE DRAWING SCD-E-002.
- 2. POWER THE NEW LIGHTING FIXTURES FROM THE SAME POWER SUPPLY OF THE REMOVED FIXTURES UTILIZING THE SAME CONDUIT AND CABLE. EXTEND CONDUIT AS REQUIRED. PROVIDE UNSWITCH HOT LEG WIRING FOR FIXTURES WITH EMERGENCY BATTERY PACK OPERATION.
- 3. POWER THE EMERGENCY BATTERY PACKS FROM THE EXISTING EMERGENCY CIRCUIT FEEDING THE EMERGENCY LIGHT IN THE OVERPASS.

	HARTSDALE AND SCARSDALE STATION	<i>CONTRACT NO.</i> <b>1000106733</b>	
ailroad		SCALE 1/8"=1'-0"	DATE <b>08/03/2021</b>
	LIGHTING PLAN OVERPASS LEVEL	drawing no.	-102
	SCARSDALE STATION	SHEET <b>90</b> 0.	

## ELECTRONICS NOTES:

- COORDINATE WITH THE ENGINEER FOR ALL CONNECTIONS TO THE EXISTING EQUIPMENT AND ANY DISRUPTIONS OF SERVICE.
- 2. CONDUIT SIZES SHOWN ARE MINIMUMS AND SIZED IN ACCORDANCE WITH NEC SPECIFICATIONS AND REQUIREMENTS. ENSURE ALL INSTALLATIONS COMPLY WITH NEC AND SPECIFICATION REQUIREMENTS AT NO ADDITIONAL COST BASED ON ACTUAL MATERIALS USED.
- 3. FIRE SEAL OPENINGS THROUGH FIRE RATED WALLS AND FLOOR SLABS FOR CONDUITS AND EQUIPMENT AS PER SPECIFICATION 07 84 00.
- 4. SEAL ALL WALL PENETRATIONS.
- 5. RESTORE TO EXISTING CONDITION ALL EXISTING SYSTEMS SHOWN ON THE CONTRACT DRAWINGS THAT ARE DAMAGED BY WORK UNDER THIS CONTRACT TO THE SATISFACTION OF THE ENGINEER AND AT NO ADDITIONAL COST TO THE AUTHORITY.
- 6. PROTECT ALL EXISTING EQUIPMENT THAT ARE TO REMAIN FROM DAMAGE IN THE WORK AREAS. ANY EQUIPMENT DAMAGED BY THE CONTRACTOR SHALL BE REPAIRED OR REPLACED AT NO ADDITIONAL COST TO THE AUTHORITY, AND TO THE SATISFACTION OF THE ENGINEER.
- 7. UPON COMPLETION OF THE WORK, REMOVE ALL DEBRIS, EQUIPMENT AND UNUSED MATERIALS FROM THE AUTHORITY PROPERTY AND RESTORE THE WORK AREA TO ITS ORIGINAL CONDITION, AS APPROVED BY THE ENGINEER.
- 8. THE CONTRACTOR IS RESPONSIBLE FOR SCHEDULING DELIVERY, RECEIVING, UNLOADING, STORING, UNCRATING, SETTING IN PLACE, AND PROTECTING FROM DAMAGE, VANDALISM, THEFT OR WEATHER DURING CONSTRUCTION ALL EQUIPMENT FURNISHED BY THE CONTRACTOR OR FURNISHED BY OTHER PARTIES TO THE CONTRACTOR FOR INSTALLATION BY THE CONTRACTOR.
- 9. COORDINATE WORK SHOWN ON ELECTRONICS DRAWINGS WITH WORK FOR ALL OTHER TRADES.
- 10. CARRY OUT ALL WORK WITH NO INTERFERENCE TO MNR OPERATIONS. ANY INTERRUPTIONS TO MNR OPERATIONS SHALL BE COORDINATED WITH AND AUTHORIZED BY THE ENGINEER
- 11. WORK SHALL COMPLY WITH ALL GOVERNING CODES, STANDARDS, AND ADVISORIES INCLUDING ALL UPDATES AND AMENDMENTS THAT WOULD APPLY IF THE AUTHORITY WERE A PRIVATE CORPORATION UNLESS OTHERWISE NOTED IN CONTRACT DOCUMENTS.
- 12. ALL EQUIPMENT AND MATERIALS FURNISHED UNDER THIS CONTRACT SHALL BE FACTORY TESTED. AT A MINIMUM. SUBMIT TEST RESULTS TO THE ENGINEER FOR APPROVAL PRIOR TO INSTALLATION. AFTER INSTALLATION, FIELD TEST IN ACCORDANCE WITH STANDARDS THAT WOULD APPLY IF THE AUTHORITY WERE A PRIVATE CORPORATION, CONTRACT SPECIFICATIONS AND MANUFACTURERS **RECOMMENDATIONS, TO VERIFY PROPER OPERATION TO THE** SATISFACTION OF THE ENGINEER
- 13. FOR ALL JUNCTION BOXES AND PULL BOXES INSTALLED IN OUTDOOR, DAMP, OR WET LOCATIONS, CONDUIT ENTRANCES SHALL ENTER ONLY THROUGH THE BOTTOM OR SIDES. TOP CONDUIT ENTRANCES SHALL NOT BE PERMITTED.
- 14. FURNISH AND INSTALL CONDUIT FITTINGS, CONDULETS, CONNECTORS, CLAMPS, HARDWARE, HANGERS, AND SUPPORTS NECESSARY FOR A COMPLETE SYSTEM INSTALLATION.
- 15. PRIOR TO INSTALLATION, SUBMIT CONDUIT ROUTING DETAILS IN THE FORM OF SHOP DRAWINGS FOR APPROVAL.
- 16. UNLESS OTHERWISE NOTED ALL CONDUITS SHALL BE 1 INCH OR LARGER. ALL CONDUITS SHALL BE THREADED GALVANIZED RIGID STEEL UNLESS OTHERWISE NOTED.
- 17. ALL EQUIPMENT AND ENCLOSURES SHALL BE GROUNDED USING APPROPRIATELY SIZED LUGS AND GROUNDING WIRES AS PER THE NEC, LOCAL CODES, AND SPECIFICATIONS. COORDINATE WITH THE ENGINEER FOR MEANS OF ATTACHMENT WHEN CONNECTING TO EXISTING STRUCTURES.
- 18. ALL EQUIPMENT SHALL BE INSTALLED TO PERMIT EASY ACCESS FOR OPERATION AND MAINTENANCE.
- 19. CONTRACT DRAWINGS ARE DIAGRAMMATIC IN NATURE AND NOT EVERY DETAIL OR EXACT LOCATION OF EQUIPMENT AND/OR CONDUIT IS SHOWN. VERIFY ALL CONDITIONS AND DIMENSIONS IN THE FIELD BEFORE COMMENCING ANY FABRICATION, ORDERING OF ANY MATERIAL OR PERFORMING ANY WORK. NOTIFY THE ENGINEER OF

DESIGNED	SS										
	33	OF NEW									
DRAWN		N. P. BUC CO									
DIVAWIN	SS	19/8° 574 E.E.									
			[								
CHECKED	TD	La									
	тв 🤇	Time the Is	NO.	DATE		DRWN	CHKD	APPVD	NO.	DATE	
APPROVED		092647 45			DEUICION						
	CH	Pression -			REVISION						
			[								

ANY CONDITIONS OR DIMENSIONS WHICH WOULD AFFECT THE PERFORMANCE OF WORK IN ACCORDANCE WITH THE CONTRACT DRAWINGS AND SPECIFICATIONS.

20. ALL FINISHES DAMAGED DURING THE SCOPE OF THIS CONTRACT SHALL BE RESTORED TO ORIGINAL FINISH TO THE SATISFACTION OF THE ENGINEER.

## CCTV SYSTEM NOTES:

1. ALL WORK ASSOCIATED WITH THE RELOCATION OF THE EXISTING CCTV SYSTEM EQUIPMENT SHALL BE COORDINATED WITH THE ENGINEER.

## **STAGING NOTES:**

ALL ACTIVE SYSTEMS MUST BE MAINTAINED IN THEIR EXISTING OPERATIONAL CONDITION THROUGHOUT ALL PHASES OF THE PROJECT UNTIL REPLACED BY COMPONENTS INSTALLED UNDER THIS PROJECT. ANY INTERRUPTIONS SHALL BE COORDINATED WITH THE ENGINEER.

2. EXISTING SYSTEMS SHALL INCLUDE AT A MINIMUM: CCTV, PUBLIC ADDRESS, DLC CABINET, EMERGENCY ELEVATOR INTERCOM, TICKET VENDING MACHINES, AND TELEPHONE. COORDINATE WITH THE ENGINEER FOR ANY RELOCATIONS, REMOVALS OR TEMPORARY CONNECTIONS REQUIRED. MNR IN HOUSE STAFF WILL RELOCATE ALL ACTIVE SYSTEMS.

3. FURNISH AND INSTALL AT A MINIMUM TEMPORARY SUPPORTS, CABLING, CONNECTIONS TO MAINTAIN EXISTING SYSTEMS. PROTECT EXISTING INFRASTRUCTURE TO MINIMIZE INTERRUPTIONS.

4. CUT OVER AND RECONNECTION OF EXISTING SYSTEMS SHALL BE BY MNR. COORDINATE WITH THE ENGINEER

## **ABBREVIATIONS:**

A	AMP	FOC
AC	ALTERNATING CURRENT	FRE
AFG	ABOVE FINISHED GRADE	FS
APPROX	APPROXIMATE	
ASTM	AMERICAN STANDARD FOR TESTING AND MEASUREMENTS	G, GND GALV
AWG	AMERICAN WIRE GAUGE	GBIC
BORA	BROADBAND OPTICAL RING ADAPTER	GFCI
BTU/H	BRITISH THERMAL UNITS PER HOUR	HP
С	CONDUIT	HT
CFM	CUBIC FEET PER MINUTE	HVAC
СН	COMMUNICATIONS HOUSE	HZ IN
CIH	CENTRAL INSTRUMENT HOUSE	IP
СОММ	COMMUNICATIONS	KW
DC	DIRECT CURRENT	LBS
DEG	DEGREES	LDF
DIA	DIAMETER	
DLC	DIGITAL LINE CIRCUIT	LFMC
DWG	DRAWING	
DSP	DIGITAL SIGNAL PROCESSOR	MAX MC
E	EAST	
E/S	ETHERNET-TO-SERIAL CONVERTER	MCA
EBP	EMERGENCY BLUE LIGHT PHONE	MIN MDF
E&W	EAST AND WEST	MNR
EL	ELEVATION	WINK
ENT	ENTERING	Ν
EQUIP	EQUIPMENT	N/A
ESP	EXTERNAL STATIC PRESSURE	NC
ETC	ET CETERA	NEC
ETEL	EMERGENCY TELEPHONE	NH
EXIST OR (E)	EXISTING	NIC NO
F	FAHRENHEIT	NTS
FLA	FULL LOAD AMPS	OTN
FT	FEET	
FDP	FIBER DISTRIBUTION PANEL	PA



DRWN	CHKD	APPVD
	DRWN	DRWN CHKD



FIBER OPTIC CABLE	PD	PLATFORM DISPLAY
	PH	PHASE
FIBERGLASS REINFORCED	PP	PATCH PANEL
EPOXY	POE	POWER OVER ETHERNET
FIRE SUPPRESSION	QTY	QUANTITY
GROUND	REF	REFERENCE
GALVANIZED	REQ'D	REQUIRED
	RF	RADIO FREQUENCY
CONVERTER GROUND FAULT	RGS	RIGID GALVANIZED STEEL
	RM	ROOM
HORSEPOWER	RPM	REVOLUTIONS PER MINUTE
HEATING VENTALATION AIR CONDITIONING	SCU	STATION CONTROL UNIT
HERTZ	SD	SCHEDULE DISPLAY
INCH	SM	SINGLE MODE
INTERNET	SS	STAINLESS STEEL
PROTOCOL	STA	STATION
KILOWATT	STD	STANDARD
POUNDS	STR	STRUCTURE
LOCAL DISTRIBUTION FRAME	TBD	TO BE DETERMINED
LIQUID-TIGHT FLEXIBLE METAL CONDUIT	T/F	TOP OF FOUNDATION
MAXIMUM	T/R	TOP OF RAIL
ETHERNET MEDIA	TRK	TRACK
CONVERTER	TYP	TYPICAL
MINIMUM CURRENT AMPACITY	UNGR	UNDERGROUND
MINIMUM	UPS	UNINTERRUPTIBLE POWER SOURCE
MAIN DISTRIBUTION FRAME	V	VOLT
METRO-NORTH RAILROAD	VIS	VARIABLE INFORMATION SIGN
NEUTRAL	VMS	VARIABLE MESSAGE SIGN
NOT APPLICABLE	VS	VIDEO SURVEILLANCE
NOISE CRITERIA	vo	VIDEO SUIVEILLANCE
NOISE CRITERIA		
CODE		
NODE HOUSE		

NOT IN CONTRACT

NUMBER

NOT TO SCALE

OPEN TRANSPORT NETWORK


PUBLIC ADDRESS

	TITLE	CONTRACT NO.	
	HARTSDALE AND SCARSDALE STATION	1000106733	
ailroad	IMPROVEMENTS	SCALE	DATE
	COMMUNICATION GENERAL		07/09/2021
	NOTES, LEGEND, AND	DRAWING NO.	
	ABBREVIATIONS DWG. 1 OF 2	SCD-E	S-001
	SCARSDALE STATION	SHEET 91 OF	F <b>112</b>

## **COMMUNICATION SYMBOLS:**

FIX	VIDEO SURVEILLANCE CAMERA (FIXED)
PTZ	VIDEO SURVEILLANCE CAMERA (PAN-TILT-ZOOM)
C###	CONDUIT ID TAG
•	CONDUIT TURNED DOWN
O	CONDUIT TURNED UP
	CONDUIT UP AND DOWN
	UNDERGROUND CONDUIT

DESIGNED	SS	and the second										
	33	E OF NEW H										
DRAWN	SS	S STAR P. BUCK P.										
CHECKED	ТВ	A Date of the second	NO.	DATE			DRWN	CHKD	APPVD	NO.	DATE	
		092647-1 45						_				
APPROVED	СН	OFESSION			REV	ISION						



CONFORMED			
	DRWN	CHKD	APPVD
$D \Box U U \Box U \cap M$			








REVISION

	TITLE	CONTRACT NO.	
	HARTSDALE AND SCARSDALE STATION	1000106733	
	IMPROVEMENTS	SCALE	DATE
	COMMUNICATION GENERAL		07/09/2021
	NOTES, LEGEND, AND	DRAWING NO.	
	ABBREVIATIONS DWG. 2 OF 2	SCD-E	S-002
	SCARSDALE STATION	SHEET 92 OL	F 112

DESIGNED	00										
	SS	OF NEW									
$DDAW\lambda I$		N. P. BUS CO									
DRAWN	SS	19/8 SZA ELF.									
		F.C. A. A. MAR									
CHECKED	TD	Let IN LATE									
	ТВ 🧲	TIMO VIELES	NO.	DATE		DRWN	CHKD	APPVD	NO.	DATE	
		092647 · 45									
APPROVED	СН	NOFESSIONA			REVISION						











REVISION

## <u>NOTES</u>


- 1. TERMINATION AND CROSS CONNECTING OF EQUIPMENT IN DLC CABINET SHALL BE BY MNR. COORDINATE WITH THE ENGINEER.
- 2. CONTRACTOR IS RESPONSIBLE FOR ALL TERMINAL BLOCKS, JUMPER, BRIDGING CLIPS, ETC. NECESSARY TO CONNECT ALL DEVICES.
- 3. COORDINATE CONNECTIONS TO FIRE ALARM AND ELEVATOR WITH EQUIPMENT VENDOR AND INSTALLER.

100% RFC SUBMISSION						
ailroad	TITLE HARTSDALE AND SCARSDALE STATION IMPROVEMENTS	CONTRACT NO. 1000106733				
	COMMUNICATION	SCALE 1/8" = 1'-0"	<i>DATE</i> <b>07/09/2021</b>			
	ONE LINE DIAGRAM	drawing no.	S-003			
	SCARSDALE STATION	SHEET <b>93</b> OI	F <b>112</b>			







OF OVERPASS AN FOR ELEVATION V CAMERA POWER S	ALL REMOVE EXISTING C D REMOVAL OF CCTV HU IEW. SUPPLIES, LOCATED INSI LOCATED BY METRO NO	ONDUIT IMPACTED BY I T. SEE DWG. SCD-ES-10 DE OF COMMUNICATIO	02
	 ۲		
	I		I
H.	100 TLE ARTSDALE AND SCARSD		MISSION NTRACT NO. 000106733 SCALE DATE
P C R	LATFORM LEVEL OMMUNICATION EMOVAL LAYOU CARSDALE STATION	CONDUIT	/8" = 1'-0"       07/09/2021         AWING NO.         SCD-ES-100         VEET 94 OF 112



CONFORMED			
	DRWN	CHKD	APPVD
D D U I C I O M			
$\kappa E V I S I U N$			
REVISION	1	1	

ailroad	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733			
	IMPROVEMENTS COMMUNICATION	SCALE AS NOTED	DATE <b>07/09/2021</b>		
	OVERPASS ELEVATION	DRAWING NO.			
	SOUTH VIEW REMOVALS	SCD-E	S-102		
	SCARSDALE STATION	SHEET <b>96</b> O.	F <b>112</b>		





SCARSDALE STATION

SHEET **97** OF **112** 


CONFORMED			
	DRWN	CHKD	APPVD
RFVLSION			






## NOTES:

1. INSTALL CONDUIT AS SHOWN AND RECONNECT TO EXISTING CONDUIT. SEE SCD-ES-100 SERIES DWGS FOR REMOVALS. SEE DWG. SCD-ES-202 FOR ELEVATION VIEW.




CONFORMED			
	DRWN	CHKD	APPVD
REVISION			



CONFORMED			
	DRWN	CHKD	APPVD

LINE [	DESIGNATIONS			AI	BBREVIA	FIONS		
CF D E EXH G GHWS GHWR GV HWR OF R ST V ST V	CHEMICAL FEED DRAIN EXPANSION EXHAUST NATURAL GAS GLYCOL HOT WATER SUPPLY GLYCOL HOT WATER RETURN GAS VENT HOT WATER SUPPLY HOT WATER RETURN NON-POTABLE WATER OVERFLOW REFRIGERANT LIQUID REFRIGERANT SUCTION REFRIGERANT DISCHARGE STORM WATER VENT PIPING	AAV ABV AD ADR AFF ALUM AP ATC AVER AWT BDD BFP BD BLDG BLDG BLW BM BSMT BTU CAP CBV CF	AUTOMATIC AIR VENT ABOVE ACCESS DOOR AREA DRAIN (SEE SYMBOLS) ABOVE FINISHED FLOOR ALUMINUM ACCESS PANEL AUTOMATIC TEMPERATURE CONT AVERAGE AVERAGE WATER TEMPERATURE - BACK DRAFT DAMPER BACK FLOW PREVENTOR BLAST DAMPER BUILDING BELL MOUTH BASEMENT BRITISH THERMAL UNIT - CAPACITY CIRCUIT BALANCING VALVE INLINE EXHAUST FAN	H2O HB HD HR HR HTR HZ – ID	HEIGHT WATER HOSE HEAD HORSE HOUR HEATEI HEATEI INSIDE INCHES INCLUI	N NIZED AL CON NS PER NS PER S PER S PER BIBB (SEE SI POWER R DIMEN S DIMEN S DIMEN S	ITRACTOR DAY HOUR MINUTE POUND CHEDULES	)
	LINE SYMBOLS, ENTS/VALVING	CFH CFM CHP CI CIP	CUBIC FEET PER MINUTE CUNCRETE HOUSEKEEPING PAD CAST IRON CLEAN IN PLACE	INV  L	INVERT – KILOWA – LENGTI	ATT .		
Image: CBV       I	EXISTING PIPING TO REMAIN EXISTING PIPING TO BE REMOVED NEW PIPING GATE VALVE GLOBE VALVE BUTTERFLY VALVE BALL VALVE OS&Y GATE VALVE SWING CHECK VALVE TRIPLE DUTY VALVE GATE VALVE, ANGLE AUTO FLOW CONTROL VALVE CIRCUIT SETTING BALANCING VALVE THREE WAY CONTROL VALVE THREE WAY CONTROL VALVE TWO WAY CONTROL VALVE VALVE-QUICK CLOSING RELIEF/SAFETY VALVE MANUAL AIR VENT AUTOMATIC AIR VENT (EXTEND DISCHARGE TO DRAIN) DIRECTION OF FLOW DIRECTION OF FLOW DIRECTION OF PITCH-RISE / DROP STRAINER STRAINER WITH BLOW OFF VALVE ) PIPE RISING UP ) PIPE RISING UP ) PIPE ROPPING DOWN TEE OUTLET UP TEE OUTLET UP TEE OUTLET DOWN - CONCENTRIC REDUCER - ECCENTRIC REDUCER - ECCENTRIC REDUCER - UNION - SCREWED OR FLANGED ANCHOR GUIDE EXPANSION JOINT - THERMOMETER GAUGE WITH GAUGE COCK & SYPHON (STEAM) - AQUASTAT - FLEXIBLE CONNECTION SYMBOLS, ABBREVIATIONS AND EVIATIONS INDICATED APPEAR	G G G C C O C O C O C O N D A M P D D A M P D D A M P D D A M P D D D D D D D D D D D D D D D D D D	CAPACITY CIRCUIT BALANCING VALVE INLINE EXHAUST FAN CUBIC FEET PER MUNUTE CONCRETE HOUSEKEEPING PAD CAST IRON CLEAN IN PLACE CENTER LINE CELLING CELING CLEAN OUT COLUMN COMPRESSOR CONCENTRIC CONDENSATE CONDENSATE CONDENSATE CONDENSATE CONDENSATE CONDENSATE CONDENSATE CONDENSATE CONDENTION CONTROL VALVE STATION — — DRECT ACTING DAMPER DRY BULB DEPARTMENT DIAGRAM DIFFERENTIAL DISCHARGE DIVSION DOWN IN WALL DOOR LOUVER DOWN IN WALL DOOR LOUVER DOWN ON DRAWING DIRECT EXPANSION — EXISTING EACH ENTERING AIR TEMPERATURE ELECTRICAL CONTRACTOR ECCENTRIC EGECRATE GRILLE ENCLOSURE END CAP EFFICIENCY EXPANSION JOINT ELECTRIC ELEVATOR ENTERING EQUIPMENT END SWITCH EXTERNAL — CORES FAHRENHEIT FROM BELOW FAIL COSED FLOOR TRANC EXTERNAL — DEGREES FAHRENHEIT FROM ABOVE FROM BELOW FAIL COSED FLOOR DRAIN EXTERNAL — DEGREES FAHRENHEIT FROM ABOVE FLOOR DRAIN EXTERNAL — DEGREES FAHRENHEIT FROM ABOVE FLOOR DRAIN EXTERNAL — DEGREES FAHRENHEIT FROM ABOVE FLOOR DRAIN EXTERNAL — DEGREES FAHRENHEIT FROM BELOW FAIL COSED FLICOR DRAIN FIRE DAMPER FLICOR FLAT ON BOTTOM FLAT ON BOTTOM FL	RAGRT CHDR SDD CGC OMS ABDCCHG T FROM SSIGA CFCCFGJP	LOVEN LOVEN LOVEN MANHO	G WATE R G WATE NICAL ( ANDS ( AND	JS IME DAMPI OSED RACT PEN E ENSION UND HYDF CITY ROP (SEE ED POLYET GLYCOL CITY ROP (SEE ED POLYET GLYCOL CITY ROP (SEE ED POLYET GLYCOL CITY ROP (SEE ED POLYET GLYCOL CITY ROP (SEE ED POLYET GLYCOL CITY CITY CITY ROP (SEE ED POLYET GLYCOL CITY COLY CITY C	RAT DR ER ER SITH INNER EEL
EJD	APE OF NEW YOR							+
DRAWN EJD	* 10 A A *							-
CHECKED AVB			DRW	/N CHKD	APPVD	NO.	DATE	
APPROVED AVB	APPOFESSIONAL	1	REVISION				. 27.116	<u></u>

# MECHANICAL INDEX SHEET



			GENERAL_NOTES	
	1.	BE EXERC THE BUILD TEMPORA	SHALL BE PERFORMED IN A CLEAN AND WORKMANLIKE M ISED TO MINIMIZE ANY INCONVENIENCE OR DISTURBANCE ING WHICH ARE TO REMAIN IN OPERATION. ISOLATE WOR RY PARTITIONS AND/OR TARPS TO KEEP DUST AND DIRT W CTION AREA.	TO OTHER AREAS OF K AREAS BY MEANS OF
	2.	WITHOUT I TO REMAIN OF WORK SUFFICIEN	, EQUIPMENT, ETC. SHALL BE REMOVED, DISCONNECTED ( PRIOR REVIEW WITH THE OWNER AND/OR ENGINEER TO C N IN OPERATION WILL NOT BE AFFECTED. IF ANY AREAS NO ARE AFFECTED BY ANY SHUTDOWN, REMOVAL OR DISC IT ADVANCE NOTICE MUST BE GIVEN TO THE OWNER INDIC FECTED, WHEN THE PROPOSED SHUTDOWN WILL OCCUR OF TIME.	ONFIRM THAT AREAS DT WITHIN THE SCOPE CONNECTION, CATING WHICH AREAS
	3.	OF AS PER WHICH AR	REMOVED SHALL BECOME PROPERTY OF THE OWNER AN THE OWNER'S INSTRUCTIONS, UNLESS INDICATED OTHEF E NOT TO BE STORED ON SITE BY OWNERS SHALL BE REM MMEDIATELY.	RWISE. ALL ITEMS
	4.	PROCEEDI DOCUMEN	TOR SHALL FIELD VERIFY ALL DIMENSIONS AND EXISTING ON NG WITH ANY WORK. WHERE DISCREPANCIES OCCUR BET TS AND EXISTING CONDITIONS, THE DISCREPANCY SHALL ND/OR ENGINEER FOR EXPEDITING AND RESOLVE.	WEEN THESE
	5.		E JOB SITE DAILY AND REMOVE FROM THE PREMISES ANY Y THE PERFORMANCE OF THE WORK INCLUDED IN THIS CO	
	6.	PROPERTY	RACTOR SHALL BE RESPONSIBLE FOR THE SAFEKEEPING ( ON THE JOB SITE. OWNER ASSUMES NO RESPONSIBILITY ES AGAINST FIRE, THEFT AND ENVIRONMENTAL CONDITIO	FOR PROTECTION OF
	7.	NORMAL S	FULLY PRESSURE TEST ALL PIPING SYSTEMS. TEST SHALL YSTEM OPERATING PRESSURES. REPAIR AND RETEST AS PROVE TIGHT.	
	8.		ALL NECESSARY TEMPORARY OR PERMANENT CAPS OR PL E PIPING OPEN ENDED.	UGS FOR PIPING. DO
	9.	WHERE US	GED, THE TERM "PROVIDE" SHALL MEAN "FURNISH AND INS	TALL"
	10.		FOR SHALL COORDINATE HIS WORK WITH ALL OTHER TRA ON, PURCHASE AND/OR INSTALLATION OF ALL WORK.	DES PRIOR TO
	11.		CTOR ENCOUNTERS WHAT APPEARS TO BE A HAZARDOUS HE SHALL DISCONTINUE WORK IMMEDIATELY AND CONTA ITATIVE.	
	12.		EPANCY ARISES BETWEEN THE DRAWINGS AND THE SPECIES IN THE SPECIES OF THE SPECIES FOR RESOLUTION BEFORE PROCEEDING	,
	13.	IN ACCORE	THAT ANY ASBESTOS IS FOUND ON THE JOB SITE, REMOVA DANCE WITH ALL APPLICABLE CODES, OSHA REGULATION D FEDERAL DUMPING GROUNDS.	
	14.	INTERNATI	SHALL BE PROVIDED IN ACCORDANCE WITH THE REQUIR ONAL MECHANICAL CODE AND THE 2018 INTERNATIONAL E ATION CODE.	
			100% RFC SL	IBMISSION
•		م م <b>ا</b>	HARTSDALE AND SCARSDALE STATION	1000106733
<b>1</b>	ilroa	BB	SYMBOLS LEGEND	SCALE         DATE           08/03/202
			ABBREVIATIONS & GENERAL	DRAWING NO.
			NOTES SCARSDALE STATION	SCD-M-001 SHEET 100 OF 112

HEAT PUMP	, AIR-COOLED, SPLIT-SY	STEM, DX UNIT COMPRES	SOR/CONDENS	ER SCHEDULE																	
TAG.	LOCATION	BASIS OF DESIGN		CONDENSER		COOLING EFFICIENCY	HEATING COP @	CONDEN O.A. TEMP.		COMPR MOT		COMPRESSOR	FAN MOTORS	MODEL No.						UNIT OVERALL DIMENSIONS	REMARKS
NO.	LOOATION	MANUFACTURER	SERVED	FAN CFM	CFM (BTUH)	EER	47°F	COOLING	HEATING	QTY.	RLA	TYPE	WATTS		POWER (V/PH/HZ)	(AMPS)	(AMPS)	(AMPS)	TYPE	(IN.) (LxWxH)	
ACC-1	ON GRADE	MITSUBISHI	AC-1	3,880	36,000	10.8	4.52	115	0	1	8	INVERTER DRIVEN SCROLL, HERMETIC	(2) 74	PUZ-A36NKA7	208/1/60	13	25	31	R410A	18x42x53	SEE NOTES
ACC-2	ON GRADE	MITSUBISHI	AC-2	3,880	36,000	10.8	4.52	115	0	1	8	INVERTER DRIVEN SCROLL, HERMETIC	(2) 74	PUZ-A36NKA7	208/1/60	13	25	31	R410A	18x42x53	SEE NOTES

UNIT MOUNTED ON CONCRETE PAD.


INDOOR UNIT POWERD FROM OUTDOOR. 2.

PROVIDE WITH WIND BAFFLE FOR LOW-AMBIENT OPERATION CAPABILITY DOWN TO AT LEAST ZERO °F. 3.


THE CONTRACTOR SHALL CONFIRM THE CORRECT SIZES OF THE RL AND RS REFRIGERANT PIPING OF 4.

EACH AC/ACC UNIT SYSTEM WITH THE APPROVED EQUIPMENT MANUFACTURER.

	P, AIR-COOLED, SPLIT-SY	STEM, DX UNIT EVAPOR	RATOR SCHEDULE											
TAG.	ASSOCIATED ACC	LOCATION	BASIS OF DESIGN	HIGH SPEED	GROSS COOLING	G COOLING	FAN MOTOR	FAN UNIT ELECTR		UNIT ELECTRICAL POWER		MODEL	MOUNTING ARRANGEMENT	REMARKS
NO.	UNIT		MANUFACTURER	SUPPLY CFM	CAPACITY (BTUH)	CAPACITY (BTUH)	W	VOLT/PH/HZ	FLA (AMPS)	No.				
AC-1	ACC-1	EMR	MITSUBISHI	810	36000	25000	56	208/1/60	.57	PKA-36KA7	WALL MOUNTED	-		
AC-2	ACC-1	EMR	MITSUBISHI	810	36000	25000	56	208/1/60	.57	PKA-36KA7	WALL MOUNTED	_		



EXTERIOR REFRIGERANT PIPE SUPPORT DETAIL




CONFORMED			
	DRWN	CHKD	APPVD
REVISION			





	100% RFC S	UBMISSI	ON			
	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733				
Railroad	IMPROVEMENTS	SCALE	DATE <b>08/03/2021</b>			
	DETAILS & SCHEDULES	DRAWING NO.				
		SCD-N	I-002			
	SCARSDALE STATION	SHEET <b>101</b> O	F <b>112</b>			



CONFORMED			
	DRWN	CHKD	APPVD

	HARTSDALE AND SCARSDALE STATION	1000106733			
ilroad	IMPROVEMENTS MECHANICAL	SCALE	DATE <b>08/03/2021</b>		
	PLATFORM PART PLAN	DRAWING NO.			
		SCD-M	-101		
	SCARSDALE STATION	SHEET 102 OF	F 112		

1.	RAL NOTES	INSTALLATION NOTES
	THE WORK INCLUDES PROVIDING ALL LABOR, EQUIPMENT, MATERIALS AND NECESSARY SERVICES TO PROVIDE A COMPLETE NEW ADDRESSABLE FIRE ALARM SYSTEM AT MNR	1. THE INSTALLATION SHALL COMPLY WITH THE REG
2.	SCARSDALE STATION AS INDICATED ON THE DRAWINGS AND SPECIFICATIONS ALL WORK SHALL COMPLY WITH NFPA 72-2013, THE INTERNATIONAL BUILDING CODE	2. ALL CONDUIT SHALL BE RIGID STEEL HOT-DIPPED CONDUIT OUTSIDE ABOVE GROUND.
	2015 WITH 2016 SUPPLEMENTS, NFPA 70-2014 (AS APPLIED TO CABLE APPROVALS ONLY).	3. ALL WALL PENETRATIONS SHALL BE FIRE STOPPI
3.	LOCATIONS OF CONDUITS AND DEVICES	4. CONDUIT SHALL BE INTERNALLY SEALED AT THE
	A. THE CONTRACTOR SHALL VISIT THE SITE AND VERIFY THE EXISTING CONDITIONS AS SHOWN ON THE CONTRACT DRAWINGS BEFORE SUBMITTING THE BID TO ENSURE THAT CONDITIONS AT THE TIME OF BID ARE ACCOUNTED FOR.	5. FOLLOWING THE INSTALLATION AND APPROVAL ON CONTRACTOR SHALL REPAIR, PATCH AND PAIN SURROUNDING AREAS TO THE SATISFACTION OF
	B. THE CONTRACTOR SHALL SUBMIT THE CONDUIT LAYOUT FOR APPROVAL BEFORE COMMENCEMENT OF INSTALLATION WORK.	6. COORDINATE ALL WORK WITH EXISTING FIELD CO
4.	C. THE CONTRACTOR SHALL SUBMIT CONDUITS AND DEVICES INSTALLATION DETAILS BEFORE COMMENCEMENT OF WORK. CONDUIT MOUNTING	<ol> <li>PROVIDE JUNCTION AND PULL BOXES AS REQUIR ALL BOXES SHALL BE ACCESSIBLE WITHOUT DAM STRUCTURE/FINISH.</li> </ol>
	<ul> <li>A. THE CONTRACTOR SHALL CONDUCT SITE SURVEYS AS REQUIRED TO DESIGN THE CONDUIT LAYOUT INCLUDING CONDUIT SIZE AND MOUNTING BRACKETS.</li> <li>B. FIRE ALARM CONDUIT SHALL BE ROUTED IN COORDINATION WITH EXISTING CONDITIONS. THE CONDUITS SHOWN ON THE DRAWINGS REPRESENTS A</li> </ul>	8. CONTROL/SIGNAL/ AUXILIARY RELAYS SHALL BE CONDITIONS WITH THE ENGINEER'S APPROVAL. ( BE LOCATED WITHIN 3 FT OF INTERFACED EQUIP
	SUGGESTED PATH OF ROUTINGS BASED ON FIELD CONDITIONS. CONTRACTOR SHALL SURVEY THE FIELD AND OBTAIN APPROVAL OF THE CONDUIT ROUTINGS FROM MNR. APPROVED CONDUIT LAYOUT AND APPROVAL SHALL BE SUBMITTED.	9. INSTALL MONITOR MODULES, CONTROL RELAYS, AT 60-96" AFF OR AS DIRECTED BY THE ENGINEEI
	C. CONDUIT SHALL BE PERMITTED TO BE WALL MOUNTED AT THE CEILING OR CEILING MOUNTED AT WALL.	10. THE FACP SHALL BE MOUNTED SUCH THAT THE D
	<ul> <li>D. ALL MOUNTING BRACKETS SHALL BE NEW.</li> <li>E. CLASS A CONDUIT SHALL COMPLY WITH NFPA 72.</li> <li>F. CONDUIT PERCENTAGE (%) FILL REQUIREMENTS PER NEC SHALL BE APPLIED</li> </ul>	11. NOTIFICATION, SIGNALING AND AUXILIARY POWE CO-LOCATED WITHIN THE SAME CONDUIT.
	UNDER THIS CONTRACT. PRIOR TO TESTING THE SYSTEM, ALL CABLE SEGMENTS BETWEEN DEVICES SHALL BE TESTED IN ACCORDANCE WITH THE APPROVED CABLE TEST. PROCEDURE. NO DEVICES	12. 120 VAC WIRING FOR FIRE ALARM SYSTEM EQUIP SEPARATE AND DEDICATED RACEWAY. REFER TO CIRCUITS.
	SHALL BE TERMINATED PRIOR TO THE SUCCESSFUL COMPLETION OF INSULATION RESISTANCE TESTS.	13. USE OF WIRE NUTS IS NOT ACCEPTABLE FOR AN
S.	THE SYSTEM SHALL BE TESTED IN ACCORDANCE WITH NFPA 72 REQUIREMENTS.	14. HEAT DETECTORS SHALL BE PROVIDED AS SHOW
	THE NEW FIRE ALARM SYSTEM SHALL REPORT TO LOCAL FIRE DEPARTMENT. THE CONTRACTOR SHALL TEST AND VERIFY THE TRANSMISSION OF FIRE ALARM CONDITIONS TO CAMS AS A PART OF THE FIRE ALARM SYSTEM TESTING PROCEDURE.	MUST BE COORDINATED WITH THE ELECTRICAL A EXACT PLACEMENT OF THE DEVICE PRIOR TO TH CONFLICTS SHALL BE BROUGHT TO THE ATTENTI PRIOR TO INSTALLATION. DISPOSITION OF THE SH
	ANY DEFICIENCIES IDENTIFIED DURING INSPECTION AS RESULT OF FALLURE TO COMPLY WITH CONTRACTUAL AND NFPA 72 INSTALLATION REQUIREMENTS SHALL BE CORRECTED BY THE CONTRACTOR AT NO ADDITIONAL COST TO THE AUTHORITY OR THE CONTRACTING PARTY.	THE CONTRACTOR OF PROVIDING A MAINTAINAB 15. PROVIDE LABELS AND TAGGING FOR ALL PANELS DEVICES.
).	DEVICE LOCATION SHOWN ON THE DRAWINGS IS APPROXIMATE. THE CONTRACTOR SHALL INSTALL EACH DEVICE PER NFPA 72 AND MNR REQUIREMENTS AS APPLICABLE.	16. PROVIDE CIRCUIT ID LABELS FOR ALL NOTIFICATI A CIRCUIT INDICATE "EOL".
10.	REFER TO SEQUENCE OF OPERATIONS FOR PROGRAMMING DETAILS.	
11.	ALL SYMBOLS ARE NOT DRAWN TO SCALE.	
12.	FOR DETAILS AND PROVISIONS REFER TO CONTRACT SPECIFICATIONS.	
13.	FACP SHALL BE ABLE TO ACCEPT INITIATION SIGNALS THAT CAN BE PROGRAMMED TO TRANSMIT 4 SIGNALS: FIRE, CARBON MONOXIDE, SUPERVISORY, AND TROUBLE.	
4.	FACP SHALL HAVE MONITORING CONNECTION VIA 2 POTS. THE MONITORING CONTRACT SHALL BE COVERED FOR ONE YEAR BY THE CAPITAL PROJECT AND SHALL USE THE OSS-FIRE SAFETY CONTRACTOR. THE PROJECT SHALL BE RESPONSIBLE FOR ANY CHANGES TO THE FIRE ALARM SYSTEM TO INTEGRATE INTO THE OSS-FIRE SAFETY CONTRACTOR.	
14. 15.	CONTRACT SHALL BE COVERED FOR ONE YEAR BY THE CAPITAL PROJECT AND SHALL USE THE OSS-FIRE SAFETY CONTRACTOR. THE PROJECT SHALL BE RESPONSIBLE FOR ANY CHANGES TO THE FIRE ALARM SYSTEM TO INTEGRATE INTO THE OSS-FIRE SAFETY	
	CONTRACT SHALL BE COVERED FOR ONE YEAR BY THE CAPITAL PROJECT AND SHALL USE THE OSS-FIRE SAFETY CONTRACTOR. THE PROJECT SHALL BE RESPONSIBLE FOR ANY CHANGES TO THE FIRE ALARM SYSTEM TO INTEGRATE INTO THE OSS-FIRE SAFETY CONTRACTOR. MONITORING CALL DOWN LIST FOR THE DIFFERENT SIGNALS SHALL BE APPROVED BY	

APPROVED	GG

S GRAIN COLONER STA	
5 , ASA, E	
Son the app	-
No. 039355 C	

	DRWN	CHKD	APPVD
REVISION			

LLATION NOTES
THE INSTALLATION SHALL COMPLY WITH THE REQUIREMENTS OF NFPA 72.
ALL CONDUIT SHALL BE RIGID STEEL HOT-DIPPED GALVANIZED. PROVIDE PVC COATED CONDUIT OUTSIDE ABOVE GROUND.
ALL WALL PENETRATIONS SHALL BE FIRE STOPPED (2 HOUR RATING).
CONDUIT SHALL BE INTERNALLY SEALED AT THE POINT OF PANEL ENTRY.
FOLLOWING THE INSTALLATION AND APPROVAL OF THE NEW FIRE ALARM SYSTEM THE CONTRACTOR SHALL REPAIR, PATCH AND PAINT ALL DAMAGED AREAS TO MATCH SURROUNDING AREAS TO THE SATISFACTION OF THE ENGINEER.
COORDINATE ALL WORK WITH EXISTING FIELD CONDITIONS TO AVOID INTERFERENCES.
PROVIDE JUNCTION AND PULL BOXES AS REQUIRED TO FACILITATE PULLING OF WIRES. ALL BOXES SHALL BE ACCESSIBLE WITHOUT DAMAGING THE BUILDING STRUCTURE/FINISH.
CONTROL/SIGNAL/ AUXILIARY RELAYS SHALL BE 5 ½- 7 FT AFF OR AS PER FIELD CONDITIONS WITH THE ENGINEER'S APPROVAL. CONTROL AND SIGNAL MODULES SHALL

ISTALL MONITOR MODULES, CONTROL RELAYS, TEST STATIONS, AUXILIARY RELAYS T 60-96" AFF OR AS DIRECTED BY THE ENGINEER.

THE FACP SHALL BE MOUNTED SUCH THAT THE DISPLAY IS 5 ½- 6 FT AFF.

IOTIFICATION, SIGNALING AND AUXILIARY POWER CIRCUITS ARE PERMITTED TO BE CO-LOCATED WITHIN THE SAME CONDUIT.

20 VAC WIRING FOR FIRE ALARM SYSTEM EQUIPMENT SHALL BE INSTALLED IN ITS OWN EPARATE AND DEDICATED RACEWAY. REFER TO ELECTRICAL DRAWINGS FOR THESE IRCUITS.

JSE OF WIRE NUTS IS NOT ACCEPTABLE FOR ANY WIRING TERMINATIONS.

IEAT DETECTORS SHALL BE PROVIDED AS SHOWN ON THE CONTRACT DRAWINGS AND IUST BE COORDINATED WITH THE ELECTRICAL AND MECHANICAL EQUIPMENT FOR XACT PLACEMENT OF THE DEVICE PRIOR TO THE ISSUANCE OF SHOP DRAWINGS. ALL ONFLICTS SHALL BE BROUGHT TO THE ATTENTION OF THE ENGINEER AND RESOLVED RIOR TO INSTALLATION. DISPOSITION OF THE SHOP DRAWING SHALL NOT RELIEVE THE CONTRACTOR OF PROVIDING A MAINTAINABLE SYSTEM.

PROVIDE LABELS AND TAGGING FOR ALL PANELS, CONDUITS AND ADDRESSABLE DEVICES.

PROVIDE CIRCUIT ID LABELS FOR ALL NOTIFICATION APPLIANCES. FOR LAST DEVICE ON A CIRCUIT INDICATE "EOL".

SYMBOL	
(C) WP	AREA SMOKE DE
(H) <sup>G</sup> WP	AREA HEAT DETE
$\mathbf{X}_{15}^{WP}$	STROBE ( 75 CAN FOR ALL OTHERS
	HORN/STROBE (1
FACP	FIRE ALARM CON
F	PULL STATION
К	KNOX BOX THAT
	PROPOSED UND
	PROPOSED ABO
9	CONDUIT UP
-	CONDUIT DOWN
RR	REMOTE RELAY
RI	RELAY INPUT MC
ММ	MONITOR MODU
EOL	END OF LINE RES

ABBREVIATION	DESCRIPTION
EMR	ELEVATOR MACHINE ROOM
MNR	METRO-NORTH RAILROAD
NAC	NOTIFICATION APPLIANCE CIRCUIT
R	RELAY CIRCUIT
RM	ROOM
SLC	SIGNAL LINE CIRCUIT
WP	WEATHER PROOF

CONFORMED			
	DRWN	CHKD	APPVD






DESCRIPTION
TECTOR ( G-WIRE GUARD, WP-WEATHER PROOF )
ECTOR (G-WIRE GUARD, WP-WEATHER PROOF )
IDEL SETTING FOR WEATHER PROOF APPLIANCES, 15 CANDELA S ) "WP" INDICATES WEATHERPROOF (CEILING MOUNTING)
5 CANDELA). "WP" INDICATES WEATHERPROOF.
ITROL PANEL
IS KEYED TO LOCAL FIRE DEPT.
ERGROUND CONDUIT
VE GROUND CONDUIT
DDULE
LE
SISTOR

	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733			
Railroad	IMPROVEMENTS FIRE ALARM SYSTEM	SCALE	DATE <b>08/03/2021</b>		
	GENERAL NOTES, SYMBOL	DRAWING NO.	06/03/2021		
	LIST, & ABBREVIATION LIST	SCD-F	A-001		
	SCARSDALE STATION	SHEET <b>103</b> O.	F 112		

		FACP	FUNCTIO			ICATION		TPUT: con					
		ACTIVATE SOUNDER, FIRE LED AND TEXTUALE DISPLAY ON PANEL	ACTIVATE SOUNDER, SUPERVISORY LED AND TEXTUALE DISPLAY ON PANEL AND ANNUNCIATOR	ACTIVATE SOUNDER, TROUBLE LED AND TEXTUALE DISPLAY ON PANEL AND ANNUNICATOR	ACTIVATE HORN/STROBES IN EMR AND OUTSIDE EMR	NOTIFY RCC CAMS OF ALARM CONDITION VIA IP CAPTURE CARD OR DACT	NOTIFY RCC CAMS OF SUPERVISORY CONDITION CIA IP CAPTURE CARD OR DACT	NOTIFY RCC CAMS OF TROUBLE CONDITION VIS IP CAPTURE CARD OR DACT	RECALL W1 TO LOWER LEVEL	RECALL W1 TO UPPER LEVEL	ACTIVATE CAB WARNING SIGNAL SIGN IN W1	INBOUND PLATFORM - ELEV-W1	R TC
SYSTEM INPUTS		A	B	C	D	E	F	G	H		J		
ELEV W1 FIRE ALARM MANUAL PULL STATION IN EMR AND COMM. RM.	1	х			х	x						FACP	
ELEV W1 EMR DETECTOR	2	x			x	x				x	x		
ELEV W1 COMM. RM. DETECTOR	3	Х			х	x							
ELEV W1 TOP OF SHAFT DETECTOR	4	X			х	x			x		x		
ELEV W1 PIT DETECTOR	5	х			х	X				x	Х		
ELEV W1 PLATFORM DETECTOR (LOWER LEVEL)	6	х			x	х				x			<u>/V1</u>
ELEV W1 OVERPASS DETECTOR (UPPER LEVEL)	7	Х			х	x			x				
GENERAL TROUBLE	8			x				Х					
AC POWER LOSS	9			x				x					
BATTERY TROUBLE	10			x				X					
DIRTY SMOKE DETECTOR	11			x				Х				CIRCUIT DESTINATION         CIRCUIT TYPE         CABLE TYPE           —         —         —         —         NAC         2-1PR. #12	
EXCESSIVELY DIRTY SD	12			х				Х				NAC 2-IPR. #12	
CLASS A TROUBLE	13			x				Х				R 2/C #14 AW	
SHORT CKT TROUBLE	14			х				Х				NOTES:	
24 VDC LOSS	15			x				Х				1. REFER TO PLAN DRAWINGS FOR THE LOC	ΑΤΙΟ
IP CAPTURE CARD TBL	16		x				Х					2. PHASE 1 ELEVATOR CONTROL A. PRIMARY LEVEL IS LOWER LEVEL:	
IP CAPTURE POWER LOSS	17		x				x					- RECALL TO PRIMARY LEVEL WHEN DETECTOR IS ACTIVATED. B. ALTERNATE LEVEL IS UPPER LEVEL: - RECALL TO ALTERNATE LEVEL WH	


DESIGNED										
	VC	OFNEW								
DRAWN		STATE GOLD LOD								
21011011	WF	10 10 T. 22								
CHECKED										
CHECKED	GG	12 Jon that it for	NO.	DATE		DRWN	CHKD	APPVD	NO.	DATE
APPROVED		OFFICEDON			DEVICIO	T				
	GG				REVISION					

3. PROVIDE REQUIRED COMMUNICATION EQUIPMENT TO INTERFACE WITH THE TELEPHONE PROVIDER TO DIAL TO MTA POLICE AND OCC IN THE EVENT OF ALARM.









DATA CABINET (SEE COMMUNICATION DRAWINGS)

- TELEPHONE DIAL TO LOCAL FIRE DEPARTMENT (SEE COMMUNICATION DRAWINGS)
- > 120V AC FROM FIRE ALARM DISCONNECT SWITCH -2#10 &1#8G - 3/4"C

WG NYC FPLP - 3/4"C


G NYC FPLP, T/S - 3/4"C


TION OF THE DEVICES.

TOP OF SHAFT DETECTOR OR UPPER LOBBY


N LOWER LOBBY DETECTOR , ELEVATOR DETECTOR IS ACTIVATED. C. PROVIDE REQUIRED MODULE TO CONNECT TO THE ELEVATOR CONTROLLERS.


	HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733		
Railroad	IMPROVEMENTS FIRE ALARM SYSTEM	SCALE	DATE <b>08/03/2021</b>	
	RISER DIAGRAM & SEQUENCE OF OPERATION	drawing no. SCD-FA-002		
	SCARSDALE STATION	SHEET <b>104</b> OF		













- 1. FOR SYMBOLS, ABBREVIATIONS, NOTES, RISER DIAGRAM AND SEQUENCE OF OPERATION, SEE DRAWING SCD-FA-001.
- 2. EXACT LOCATION OF THE EXTERIOR HORN/STROBE SHALL COMPLY WITH METRO-NORTH REQUIREMENTS.

	TITLE HARTSDALE AND SCARSDALE STATION	<i>CONTRACT NO.</i> <b>1000106733</b>				
ailroad	IMPROVEMENTS FIRE ALARM PLAN -	SCALE 1/8"=1'-0"	DATE <b>08/03/2021</b>			
	OVERPASS LEVEL	drawing no.	Λ 102			
	SCARSDALE STATION	SCD-1 /				



CONFORMED			
CONFORMED			
	DRWN	CHKD	APPVD
REVISION			

	100% RFC SU	BMISSI	ON		
	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733			
Railroad		SCALE AS NOTED	DATE <b>08/03/2021</b>		
	BENCH - PLANS, ELEVATIONS & DETAILS	drawing no. STD-AS-173			
	SCARSDALE STATION	STD-A			



GENERAL NOTES

- 1. ALL MATERIALS AND APPARATUS SHALL BE INSTALLED IN ACCORDANCE WITH ALL THE RULES AND REGULATIONS OF THE NEW YORK STATE BUILDING CODES AND ALL OTHER AUTHORITIES HAVING JURISDICTION.
- 2. BEFORE SUBMITTING PROPOSAL, BIDDERS SHALL CAREFULLY EXAMINE EXISTING FIELD CONDITIONS AND CONTRACT DRAWINGS OF ALL TRADES. SUBMISSION OF PROPOSAL WILL BE CONSTRUCTED AS EVIDENCE THAT REQUIRED EXAMINATION HAS BEEN MADE. TATER CLAIMS FOR EXTRA LABOR, EQUIPMENT AND MATERIALS REQUIRED DUE TO EXISTING FIELD CONDITIONS, WHICH COULD HAVE BEEN FORESEEN, WILL NOT BE RECOGNIZED.
- 3. PROCUREMENT OF ALL PERMITS AND CERTIFICATES FOR THE INSTALLATION OF THESE SYSTEMS SHALL BE PERFORMED IN ACCORDANCE WITH ALL THE RULES AND REGULATIONS OF THE NEW YORK STATE BUILDING CODES AND ALL OTHER AUTHORITIES HAVING JURISDICTION.
- 4. THE CONTRACTOR SHALL COORDINATE HIS WORK WITH ALL OTHER TRADES AND ALL EXISTING CONDITIONS, AND PROVIDE ALL REQUIRED TO OFFSET ALL ADDITIONAL PIPING AND FITTINGS AT NO EXTRA COST. TO AVOID EXISTING / NEW STRUCTURE. ARCHITECTURAL, MECHANICAL AND ELECTRICAL INTERFERENCES, WHETHER INDICATED OR NOT, BEFORE INSTALLING WORK.
- 5. CONNECTION TO EXISTING SERVICES SHALL BE PERFORMED DURING OFF-WORK HOURS OF ON WEEKENDS IN PREMIUM TIME. CONNECTION OF NEW WORK TO EXISTING WORK SHALL BE PERFORMED IN NEAT AND APPROVE MANNER, RESTORING EXISTING WORK DISTURBED TO ORIGINAL CONDITION.
- 6. ALL NEW PIPING SHALL BE RUN CLOSE TO BEAMS, WALLS AND SLABS, SQUARE TO BUILDING CONSTRUCTION, CONCEALED ABOVE HUNG CEILINGS AND WITHIN FURRED SPACES.
- 7. ALL EXISTING PIPING, INDICATED AND /OR NOTED TO REMOVED, SHALL BE REMOVED BACK TO EXISTING STACKS, RISERS OR MAINS AND CAPPED / PLUGGED AT TERMINAL POINT UNLESS OTHERWISE DIRECTED BY OWNER OR ENGINEER.
- 8. THE CONTRACTOR SHALL NOT INTERRUPT ANY OF SERVICES OF THE EXISTING BUILDING WITHOUT THE EXPRESSED WRITTEN PERMISSION OF THE OWNER AND SUCH INTERRUPTIONS SHALL BE AS BRIEF AS POSSIBLE, AND AT THE TIME AGREED TO WITH THE OWNER.
- 9. UNDER NO CIRCUMSTANCES WILL THIS CONTRACTOR OR HIS WORKMEN BE PERMITTED TO USE ANY PART OF THE BUILDING AS A SHOP EXCEPT AREAS DESIGNATED BY OWNER.
- 10. EXISTING PIPING DAMAGED AS A RESULT OF PERFORMING THE WORK OF THIS CONTRACT SHALL BE REPAIRED OF REPLACE AS REQUIRED WITH MATERIAL AND FINIS TO MATCH EXISTING.
- 11. DRAWINGS ARE DIAGRAMMATIC AND INDICATE GENERAL ARRANGEMENT.
- 12. THIS CONTRACTOR SHALL PATCH AND FIRE PROOF ALL OPENINGS IN FLOORS OR WALLS AS REQUIRED.

ľ	DESIGNED	AD	E OF NEW L										
	DRAWN		STATL SPERIOD										
	DILAWIV	AD	* A A A A A A A A A A A A A A A A A A A										
	CHECKED	JP	The second secon	NO.	DATE				DRWN	CHKD	APPVD	NO.	DATE
	APPROVED	JP	APOFESSIONAL			1	REV	ISION			1		I

# PLUMBING INDEX SHEET

### PLUMBING INSTALLATION CRITERIA:


EACH BIDDER SHALL VISIT THE SITE AND BECOME INFORMED AS TO THE CONDITION OF THE PREMISES AND THE EXTENT AND CHARACTER OF WORK REQUIRED. NO ADDITIONAL COMPENSATION WILL BE APPROVED DUE TO FIELD CONDITIONS.

- 1. COORDINATE POSITION OF SLEEVES AND OPENINGS THROUGH FLOOR WITH THE GENERAL CONTRACTOR.
- 2. ALL PIPING AND EQUIPMENT SHALL BE SUBSTANTIALLY SUPPORTED FROM THE BUILDING STRUCTURE. HANGER AND SUPPORTS SHALL BE SPECIFICALLY APPROVED FOR USE IN PLUMBING SYSTEMS.
- A. WHERE OVERHEAD CONSTRUCTION DOES NOT PERMIT FASTENING OF HANGER RODS IN REQUIRED LOCATIONS, PROVIDE ADDITIONAL STEEL FRAMING AS REQUIRED AND APPROVED.
- B. NO PLUMBING PIPING SHALL BE HUNG FROM THE PIPING OF OTHER TRADES OR DUCTWORK. HANGERS SHALL BE OF HEAVY CONSTRUCTION SUITABLE FOR THE SIZE OF PIPE TO BE SUPPORTED.
- 3. ALL HORIZONTAL PIPING RUNS WILL BE AT THE HIGHEST PRACTICAL ELEVATION AND NOT LESS THAN 6" ABOVE THE FLOOR SO AS TO PROVIDE CLEARANCE.

LIST OF SYMBOLS							
PD	PUMP DISCHARGE						
o	PIPE UP OR RISE						
	PIPE DN OR DROP						
	CAP						
I	CUT AND RECONNECT						
· · · · · · · · · · · · · · · · · · ·	PIPE BREAK						
6	GAS SAFETY SHUT OFF VALVE – MAXON						
Ŕ	GAS SERVICE VALVE						
¥	GAS COCK						
~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	VALVE ON VERTICAL – VOV						
$\bowtie$	SHUT OFF VALVE						
M	CHECK VALVE						

NOTE: NOT ALL SYMBOLS, ABBREVIATIONS AND EQUIPMENT ABBREVIATIONS INDICATED APPEAR ON THESE CONTRACT DRAWINGS

## REFERENCE SYMBOLS



(APPLIES ONLY WHERE INDICATED ÒN DRAWINGS)

Х

、 X 🖌

INDICATES DRAWING ON WHICH DETAIL APPEARS

LIST OF A	BBREVIATIONS
AFF	ABOVE FINISH FLOOF
BLDG	BUILDING
CLG	CEILING
CONN	CONNECTION
CONT	CONTINUED
CFH	CUBIC FEET PER HO
DIM	DIMENSION
DN	PIPE DOWN THRU FI
DROP	PIPE DROPPING BET
DWG	DRAWING
EL	ELEVATION
EXIST	EXISTING
FL	FLOOR
GPM	GALLONS PER MINUT
HP	HORSE POWER
INV EL	INVERT ELEVATION
NC	NORMALLY CLOSED
NO	NORMALLY OPEN
N.T.S	NOT TO SCALE
PD	PUMP DISCHARGE
PLBG	PLUMBING
RISE	PIPE RISING BETWEE
RM	ROOM
RPM	ROTATION PER MINU
SQ FT	SQUARE FEET
TYP	TYPICAL
UP	PIPE RISING THRU F
VIF	VERIFY IN FIELD
VOV	VALVE ON VERTICAL
WC	WATER COLUMN
WTS	WATER TIGHT SLEEVE

CONFORMED			
	DRWN	CHKD	APPVD
REVISION			
$I \setminus L \lor I \cap I \cup I \lor I$			






420 Lexington Avenue New York, NY 10017

R
OUR
LOOR
IWEEN FLOORS
TE
EN FLOORS
JTE
FLOOR
·

100% RFC SUBMISSIO	Ν
--------------------	---

	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733			
Railroad	IMPROVEMENTS	SCALE	DATE		
amouu	SYMBOLS LEGEND		08/03/2021		
	ABBREVIATIONS & GENERAL	DRAWING NO.			
	NOTES	SCD-P-001			
	SCARSDALE STATION	SHEET 109 OF 112			



P-1	
CD-P-501	
P-601	


IICATIONS JOM FUTU	OILER ROOM, NIC



CONFORMED			
	DRWN	CHKD	APPVD
REVISION			







1. FOR SYMBOLS, ABBREVIATIONS AND GENERAL NOTES SEE DRAWING SCD-P-001

# SUMP PUMP DISCHARGE NOTES:

- 1. PROVIDE ELECTRICAL HEAT TRACING ON PUMP AND PUMP DISCHARGE LINES CONTAINING STANDING WATER.
- 2. INSULATE ALL HEAT TRACED PUMP DISCHARGE LINES.
- 3. FIELD ROUTE AND COORDINATE WITH MNR DISCHARGE DRAIN LINE AT 12" ABOVE GRADE. SPILL DISCHARGE ON GRADE AND PROVIDE SLEEVE AND SEAL AT PENETRATION.

	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733				
Railroad	IMPROVEMENTS PLUMBING	SCALE	DATE <u>08/03/202</u> 1			
	SCARSDALE STATION PLATFORM PART PLAN	drawing no.	-101			
	SCARSDALE STATION	SHEET <b>110</b> OF	F 112			

PUMP SCH	EDULE												
PUMP	LOCATION	TYPE SERVIO		MANUFACTURER MODEL	MODEL		MAX FLOW (GPM)			MOTOR DATA			
NO.			SERVICE		MODEL			(FT)		HP PHASE	CYCLE	VOLTS	
SP-1	PASSENGER ELEVATOR	SIMPLEX SUBMERSIBLE PUMP	ELEVATOR PIT	STANCOR	SE50		74	37	1,750	<u>1</u> 2	1	60	115

DESIGNED AD										
DRAWN AD										
CHECKED JP	NO.	DATE			DRWN	CHKD	APPVD	NO.	DATE	
APPROVED JP			REVIS	SION						

CONFORMED			
	DRWN	CHKD	APPVD
DELLCION			
REVISION			






## REMARKS

SIMPLEX OIL SENSING ELEVATOR SUMP PUMP. SINGLE DIRECT PLUG-IN POWER.

100%	RFC	SU	BMISSION
			CONTROLOTE NO

	TITLE HARTSDALE AND SCARSDALE STATION	CONTRACT NO. 1000106733			
Railroad	IMPROVEMENTS	SCALE	DATE		
	PLUMBING		08/03/2021		
	SCARSDALE STATION	DRAWING NO.			
	SCHEDULES	SCD-P	-501		
	SCARSDALE STATION	SHEET 111 O	F 112		

DESIGNED											
	AD	TATE OF NEW LOP									
DRAWN	AD	* SA SA X									
CHECKED		- and - chuse									
011201122	JP		NO.	DATE			DRWN	CHKD	APPVD	NO.	DATE
APPROVED	JP	PROFESSIONAL ES			REV	ISION					



### KEY NOTES:

- 1. SUBMERSIBLE SUMP PUMP 1/2 HP, 115 VOLT, 1,750 RPM, 2" DISCHARGE CONNECTION
- 2. CHECK VALVE
- AUDIBLE ALARM BUILT INTO PANEL. PANEL SHALL HAVE RUN.
- AND CORD OF REQUIRED LENGTHS TO REACH PANEL.
- 5. ALL PUMP PRESSURE DISCHARGE PIPING SHALL BE PROTECTED SYSTEM (CONNECTION TO BE DETERMINED BY MNR).
- ALARM CABLE AND PUMP-ON FLOAT CABLE.
- PUMP DISCHARGE PIPING.
- 8. PUMP-ON FLOAT
- REMOVAL OF THE PUMP FROM THE PIT.
- 10. HEAT TRACING
- 11. PROVIDE LINK SEAL OR EQUAL AT WALL PENETRATION.

HYDRAULIC ELEVATOR SUMP PUMP DETAIL 601 NOT TO SCALE

CONFORMED			
	DRWN	CHKD	APPVD
REVISION			





3. 115V, SINGLE PHASE (1Ø) CONTROL SYSTEM WITH BUILT-IN AUDIBLE AND VISUAL ALARM FOR WHEN PUMP DOES NOT RUN DUE TO OIL IN PIT OR HIGH LIQUID ALARM. PROVIDE SILENCING BUTTON FOR ADDITIONAL CONTACT FOR A REMOTE ALARM LOCATION. LIGHTS FOR OIL SPILL, POWER, HIGH LIQUID LEVEL, OVERLOAD, & PUMP

4. JUNCTION BOX SHALL BE PROVIDED WITH MULTI-PIN CONNECTOR

WITH TAPECOAT CORROSION PROTECTION TAPE AND PROVIDED WITH HEAT TRACING WHEN PIPE IS BELOW FREEZING. IN ADDITION, DISCHARGE PIPING SHALL CONNECT TO THE SITE DRAINAGE

6. OIL-MINDER CABLES: POWER CABLE, PROBE CABLE, HIGH- LIQUID

7. HIGH-LIQUID ALARM FLOAT WITH CLAMP DEVICE TO MOUNT TO

9. PROVIDE A MINIMUM FIVE FEET EXTRA OF EACH CABLE (SLACK) ROLLED CLAMPED TO THE DISCHARGE PIPE TO ALLOW FOR THE



100%	RFC	SUBN	<b>IISSION</b>
------	-----	------	----------------

	TITLE	CONTRACT NO.	
	HARTSDALE AND SCARSDALE STATION	1000106733	
Railroad	IMPROVEMENTS	SCALE	DATE
	PLUMBING		08/03/202
	SCARSDALE STATION	DRAWING NO.	
	DETAILS	SCD-P	-601
	SCARSDALE STATION	SHEET <b>112</b> 0	F <b>112</b>