ADDENDUM NO. 02

PROJECT:	Ossining Union Free School District Ossining High School Guidance Office Renovations
SED PROJECT NO:	66-14-01-03-0-003-039
DATE:	January 04, 2021
CPL PROJECT NO:	14428.12

Include this Addendum as part of the Contract Documents. It supplements portions of the original Specifications and Drawings, the extent of which shall remain, except as revised herein:

CLARIFICATIONS / RESPONSE TO BIDDER QUESTIONS:

1.1 Question: Drawing OHS-E100, it appears that the maximum length for data cabling will be exceeded based on the current data rack location. Is this acceptable? *Answer: This is not acceptable. Scale noted on plans on Drawing OHS-E100 were mis-labeled. Refer to the replaced drawing attached to this addendum.*

CHANGES TO THE DRAWINGS


1.2 Drawing OHS/E100:

A. Replace Drawing with Drawing OHS/E100, attached to this addendum.

PREVIOUSLY ISSUED ADDENDA

A. Addendum No. 01, dated 12/22/2020.

END OF ADDENDUM NO. 02



KEY NOTES:

UTILIZE EXISTING 100-AMP, 3-POLE CIRCUIT BREAKER IN EXISTING PANEL LDB TO FEED NEW PANEL PP1. LABEL BREAKER ACCORDINGLY.

AREA OF PANEL PP1 ABOVE IN GUIDANCE SUITE ROOM STORAGE 103L. PROVIDE (4) #2, (1) #6 GND IN 2" CONDUIT FROM PANEL LDB TO NEW PANEL PP1, ALL CONDUIT AND WIRING TO BE RUN TIGHT TO CEILING THEN UP INTO NEW PANEL.

