



Peekskill City  
School District  
1031 Elm St.,  
Peekskill, NY 10566

# PEEKSKILL RECONSTRUCTION

SED Project: 66-15-00-01-0-005-020  
HDG Project: 201  
**OAKSIDE ELEMENTARY**  
200 Decatur Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-007-014  
HDG Project: 202  
**URIAH HILL SCHOOL**  
980 Pemart Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-008-017  
HDG Project: 203  
**WOODSIDE ELEMENTARY**  
612 Depew St.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-014-005  
HDG Project: 204  
**MIDDLE SCHOOL**  
212 Ringgold St.,  
Peekskill, NY 10566



Architect:  
**Hamlin Design Group**  
915 Broadway, Suite 101A  
Albany, New York 12207  
Tel: 518.724.5159  
Fax: 518.320.8633  
Web: hamlindesigngroup.com

## DRAWING LIST

A.000.00 ■ COVER SHEET  
ARCHITECTURAL  
A.001.00 ■ GENERAL NOTES, SYMBOLS, & DIAGRAMS  
MECHANICAL  
M.001.00 ■ NOTES AND SYMBOLS  
M.701.00 ■ TEMPERATURE CONTROLS  
M.702.00 ■ TEMPERATURE CONTROLS

### OAKSIDE ELEMENTARY

ARCHITECTURAL  
O-A.100.00 ■ LOWER LEVEL FLOOR PLAN  
O-A.101.00 ■ MAIN LEVEL FLOOR PLAN  
O-A.500.00 ■ DETAILS  
HAZARDOUS MATERIAL  
O-H.100.00 ■ EXISTING MAIN LEVEL HAZARDOUS MATERIALS PLAN  
ELECTRICAL  
O-E.001.00 ■ LEGEND, GENERAL NOTES, SCHEDULES AND DETAILS  
O-E.201.00 ■ LOWER LEVEL REMOVAL PLAN  
O-E.202.00 ■ MAIN LEVEL REMOVAL PLANS  
O-E.401.00 ■ LOWER LEVEL POWER PLAN  
O-E.402.00 ■ MAIN LEVEL POWER PLANS  
MECHANICAL  
O-M.002.00 ■ HVAC SCHEDULES  
O-M.201.00 ■ REMOVAL PLAN  
O-M.401.00 ■ HVAC PLAN  
O-M.601.00 ■ HVAC DETAILS AND DIAGRAMS  
PLUMBING  
O-P.001.00 ■ SYMBOLS, ABBREVIATIONS & NOTES  
O-P.301.00 ■ REMOVAL & NEW PLUMBING PLAN

### URIAH HILL SCHOOL (ALTERNATE NO. 1)

ARCHITECTURAL  
U-A.100.00 ■ BASEMENT FLOOR PLAN AND DETAILS  
HAZARDOUS MATERIAL  
U-H.100.00 ■ EXISTING BASEMENT HAZARDOUS MATERIALS PLAN  
ELECTRICAL  
U-E.001.00 ■ LEGEND, GENERAL NOTES & BASEMENT POWER PLAN  
MECHANICAL  
U-M.301.00 ■ BASEMENT REMOVAL AND HVAC PLAN

### WOODSIDE ELEMENTARY


ARCHITECTURAL  
W-A.100.00 ■ BASEMENT FLOOR PLAN  
W-A.101.00 ■ PARTIAL FIRST FLOOR PLAN  
W-A.102.00 ■ PARTIAL FIRST FLOOR PLAN  
W-A.103.00 ■ PARTIAL FIRST FLOOR PLAN  
W-A.500.00 ■ DETAILS  
HAZARDOUS MATERIAL  
W-H.101.00 ■ EXISTING FIRST FLOOR HAZARDOUS MATERIALS PLAN  
W-H.102.00 ■ EXISTING FIRST FLOOR HAZARDOUS MATERIALS PLAN  
ELECTRICAL  
W-E.001.00 ■ LEGEND, GENERAL NOTES, SCHEDULES AND DETAILS  
W-E.201.00 ■ FIRST FLOOR REMOVAL PLAN  
W-E.202.00 ■ FIRST FLOOR REMOVAL PLANS  
W-E.401.00 ■ FIRST FLOOR POWER PLAN  
W-E.402.00 ■ FIRST FLOOR POWER PLAN & PANELBOARD SCHED.  
MECHANICAL  
W-M.002.00 ■ HVAC SCHEDULES  
W-M.201.00 ■ REMOVAL PLAN - AREA A  
W-M.202.00 ■ REMOVAL PLAN - AREA B  
W-M.203.00 ■ REMOVAL PLAN - AREA C  
W-M.401.00 ■ BASEMENT HVAC PLAN - AREA B  
W-M.402.00 ■ BASEMENT HVAC PLAN - AREA C  
W-M.403.00 ■ FIRST FLOOR HVAC PLAN- AREA A  
W-M.404.00 ■ FIRST FLOOR HVAC PLAN- AREA B  
W-M.405.00 ■ FIRST FLOOR HVAC PLAN- AREA C  
W-M.601.00 ■ HVAC DETAILS AND DIAGRAMS  
W-M.602.00 ■ HVAC DETAILS AND DIAGRAMS  
PLUMBING  
W-P.001.00 ■ SYMBOLS, ABBREVIATIONS & NOTES  
W-P.301.00 ■ REMOVAL & NEW PLUMBING PLAN  
W-P.302.00 ■ REMOVAL & NEW PLUMBING PLAN

### MIDDLE SCHOOL


ARCHITECTURAL  
M-A.101.00 ■ PARTIAL FIRST FLOOR PLAN  
ELECTRICAL  
M-E.001.00 ■ LEGEND, GENERAL NOTES, AND REMOVAL PLAN  
PLUMBING  
M-P.001.00 ■ SYMBOLS, ABBREVIATIONS & NOTES  
M-P.301.00 ■ REMOVAL & NEW PLUMBING PLAN




Hazardous Material Consultant:



MEP Engineer:



MAP:



DATE: 02/01/2021  
REVISION:



ABBREVIATIONS


SEE DRAWINGS WITHIN SET FOR ADDITIONAL ABBREVIATIONS

ACM	ASBESTOS CONTAINING MATERIAL
AFF	ABOVE FINISH FLOOR
ALUM	ALUMINUM
AR	ABUSE RESISTANT
ARCH	ARCHITECTURAL
B/	BOTTOM OF
CB	CATCH BASIN
CIP	CAST IN PLACE
CLG	CEILING
£	CENTERLINE
CMU	CONCRETE MASONRY UNIT
COL	COLUMN
CONC	CONCRETE
CONST	CONSTRUCTION
CPT	CARPET
CT	CERAMIC TILE
DWG	DRAWING
EA	EACH
EF	EXHAUST FAN
EQ	EQUAL
ELEC	ELECTRICAL
ELEV	ELEVATION
EXIST	EXISTING
FIN	FINISHED
FO	FINISHED OPENING
FR	FIRE RETARDANT
FT	FOOT
FV	FIELD VERIFY
FTR	FLUE THRU ROOF
GYP BD	GYP SUM BOARD
HCP	HANDICAP
HW	HOLLOW METAL
ID	INSIDE DIAMETER
IN	INCH
MATL	MATERIAL
MAX	MAXIMUM
MECH	MECHANICAL
MIN	MINIMUM
MO	MASONRY OPENING
MTD	MOUNTED
MTL	METAL
NIC	NOT IN CONTRACT
OC	ON CENTER
OD	OUTSIDE DIAMETER
OH	OPPOSITE HAND
OPG	OPENING
OPP	OPPOSITE
P/C	PRECAST CONCRETE
PL	PLATE
PT	PRESSURE TREATED
PTD	PAINTED
PTR	PIPE THRU ROOF
RCB	RESILIENT COVE BASE
RD	ROOF DRAIN
REQ'D	REQUIRED
RM	ROOM
RTU	ROOF THRU TOP UNIT
SAC	SUSPENDED ACOUSTICAL PANEL CEILING
SG	SAFETY GLAZING
SIM	SIMILAR
SS	STAINLESS STEEL
STL	STEEL
STR	STRUCTURAL
TBD	TO BE DETERMINED
T/	TOP OF
TYP	TYPICAL
UNO	UNLESS NOTED OTHERWISE
W/	WITH
VIF	VERIFY IN FIELD
VTR	VENT THRU ROOF
WG	WIRE GLASS

GRAPHIC SYMBOLS

DETAIL NUMBER


SHEET NUMBER



SECTION SYMBOL


DETAIL NUMBER

SHEET NUMBER



ELEVATION INDICATOR


M-MASONRY  
S-STUD  
F-FURRING



WALL TYPE DESIGNATION

DETAIL NUMBER


SHEET NUMBER



PAINT INDICATOR

DETAIL NUMBER

SHEET NUMBER



DETAIL SYMBOL

000

ROOM NUMBER

0


KEYED NOTE DESIGNATION

00

FINISH FLOOR CHANGE

DETAIL NUMBER


SHEET NUMBER



DETAIL TITLE

DETAIL NUMBER

SHEET NUMBER



ELEVATION SYMBOL

000 X

DOOR NUMBER

0

WINDOW NUMBER

SP

DIMENSIONAL START POINT FOR LAYOUT

FM

DIMENSION TO FACE OF STUD

FM


DIMENSION TO FACE OF MATERIAL

GENERAL NOTES


- ALL WORK SHALL CONFORM TO THE REQUIREMENTS OF THE NEW YORK STATE BUILDING CODE, FIRE DEPARTMENT REGULATIONS, STATE EDUCATION DEPARTMENT MANUAL OF PLANNING STANDARDS FOR SCHOOL BUILDINGS (MARCH 1998), UTILITY COMPANY REQUIREMENTS AND THE BEST TRADE PRACTICES.
- BEFORE COMMENCING WORK, THE CONTRACTOR SHALL FILE ALL REQUIRED CERTIFICATES OF INSURANCE WITH THE DISTRICT.
- THE CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS IN THE FIELD PRIOR TO COMMENCING WORK, AND SHALL REPORT ANY DISCREPANCIES BETWEEN DRAWINGS AND FIELD CONDITIONS TO THE ARCHITECT.
- THE JOB MAY INVOLVE PHASING OF CONSTRUCTION WORK SO AS NOT TO DISRUPT ACTIVITIES AROUND THE EXISTING FACILITY. THE CONTRACTOR IS TO FAMILIARIZE HIMSELF WITH THESE REQUIREMENTS AND REQUIREMENTS FOR OPERATION AROUND THE PREMISES OF THE BUILDING.
- ALL DIMENSIONS ARE TO FINISH FACE OF SURFACES UNLESS OTHERWISE NOTED.
- THE CONTRACTOR IS NOT TO SCALE DRAWINGS OR DETAILS. ONLY WRITTEN DIMENSIONS ARE TO BE USED.
- MINOR DETAILS AND BLOCKING NOT USUALLY SHOWN OR SPECIFIED, BUT NECESSARY FOR PROPER CONSTRUCTION OF ANY PART OF THE WORK SHALL BE INCLUDED AS IF THEY WERE INDICATED IN THE DRAWINGS.
- THE CONTRACTOR SHALL COORDINATE ALL WORK PROCEDURES WITH CONSTRUCTION MANAGER AND SCHOOL DISTRICT.
- THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROTECTION OF ALL CONDITIONS AND MATERIALS WITHIN THE PROPOSED CONSTRUCTION AREA. THE CONTRACTOR SHALL DESIGN AND INSTALL ADEQUATE SHORING AND BRACING FOR ALL STRUCTURAL OR REMOVAL TASKS. THE CONTRACTOR SHALL HAVE SOLE RESPONSIBILITY FOR ANY DAMAGE OR INJURIES CAUSED BY OR DURING THE EXECUTION OF THE WORK.
- THE CONTRACTOR SHALL LAY OUT HIS OWN WORK, AND SHALL PROVIDE ALL DIMENSIONS REQUIRED FOR OTHER TRADES (PLUMBING, ELECTRICAL, ETC.).
- THE CONTRACTOR SHALL DO ALL CUTTING, PATCHING, REPAIRING AS REQUIRED TO PERFORM ALL OF THE WORK INDICATED ON THE DRAWINGS, AND ALL OTHER WORK THAT MAY BE REQUIRED TO COMPLETE THE JOB.

Architect:  
**Hamlin Design Group**  
915 Broadway, Suite 101A  
Albany, New York 12207  
Tel: 518.724.5159  
Fax: 518.320.8633  
Web: hamlindesigngroup.com

Hazardous Material Consultant:



MEP Engineer:



Client:



**Peekskill City School District**  
1031 Elm St.  
Peekskill, NY 10566

Peekskill Reconstruction

SED Project: 66-15-00-01-0-005-020  
HDG Project: 201  
**Oakside Elementary**  
200 Decatur Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-007-014  
HDG Project: 202  
**Uriah Hill School**  
980 Pemart Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-008-017  
HDG Project: 203  
**Woodside Elementary**  
612 Depew St.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-014-005  
HDG Project: 204  
**Middle School**  
212 Ringgold St.,  
Peekskill, NY 10566

DRAWN BY:  
TG

ISSUE: 02/01/2021  
REV:



DESCRIPTION  
General Notes, Symbols, & Diagrams

A.001.00



GENERAL NOTES - REMOVALS	
A.	ALL WORK IS SHOWN DIAGRAMMATIC, AND ACTUAL SITE CONDITIONS MUST BE FIELD VERIFIED BY THE CONTRACTOR PRIOR TO THE COMMENCEMENT OF WORK.
B.	REMOVE ALL EQUIPMENT, PIPING, AND DUCTWORK SHOWN DASHED.
C.	THIS CONTRACTOR IS RESPONSIBLE FOR ALL CUTTING AND PATCHING REQUIRED TO COMPLETE THIS WORK UNLESS OTHERWISE NOTED. ALL PATCHING AND PAINTING MUST EXACTLY MATCH EXISTING CONDITIONS.
D.	EVERY EFFORT HAS BEEN MADE TO INDICATE ALL EQUIPMENT THAT IS BEING REMOVED THROUGH EXISTING DRAWINGS AND FIELD OBSERVATIONS, HOWEVER THE CONTRACTOR IS TO VISIT THE SITE PRIOR TO BIDDING AND VERIFY ALL REMOVALS, SOME DIFFERENCES MAY OCCUR.
E.	THIS CONTRACTOR SHALL FIELD VERIFY ALL EXISTING EQUIPMENT AND PIPING LOCATIONS, PIPE SIZES, AND COORDINATE WITH ALL OTHER TRADES.
F.	RE-USE EXISTING FLOOR/WALL/ROOF PENETRATIONS WHERE POSSIBLE. PROVIDE NEW PENETRATIONS AS REQUIRED. ALL OPEN PENETRATIONS THROUGH FLOOR AND OR WALLS SHALL BE SEALED OR PATCHED.
G.	THIS CONTRACTOR SHALL REMOVE ALL PIPING, VALVES, SPECIALTIES AND CONTROLS ASSOCIATED WITH EACH PIECE OF EQUIPMENT TO BE REMOVED.
H.	IF EXISTING HV UNIT, UNIT VENTILATOR, OR ANY OTHER MECHANICAL SYSTEM IS TO BE REMOVED, MC WILL REMOVE ALL ACCESSORIES, HANGERS, SUPPORTS AND EXISTING ROOM SENSORS/THERMOSTATS AND TERMINATE ALL EXISTING WIRES NOT USED IN JUNCTION BOX. ANY HOLES/OPENINGS OF OLD ROOM SENSORS SHALL BE COVERED WITH BLANK STAINLESS STEEL PLATES.
I.	THIS CONTRACTOR SHALL REMOVE AND RE-INSTALL ALL CEILINGS AS REQUIRED TO COMPLETE HIS WORK. ANY DAMAGE TO THE EXISTING CEILING AS A RESULT OF THIS WORK SHALL BE THE RESPONSIBILITY OF THIS CONTRACTOR.
J.	ALL EQUIPMENT REMOVED IS PROPERTY OF THE OWNER. IF THE OWNER DEEMS EQUIPMENT "UNSAVAGEABLE" THE CONTRACTOR IS TO DISPOSE OF IT IN A PROPER MANNER.
K.	ALL EQUIPMENT TO BE REMOVED SHALL HAVE ALL ACCESSORIES AND SUPPORTS REMOVED WITH IT, WHETHER INDICATED OR NOT. IN ADDITION, UNLESS OTHERWISE NOTED, ANY REFRIGERANT CONTAINING EQUIPMENT THAT IS SHOWN FOR REMOVAL SHALL HAVE ALL REFRIGERANT EVACUATED FROM THE SYSTEM AND PROPERLY DISPOSED OF AND ALL REFRIGERANT PIPING REMOVED FROM THE SITE.
GENERAL INSTALLATION NOTES	
A.	ALL WORK IS SHOWN DIAGRAMMATIC. FIELD VERIFY ALL EXISTING SITE CONDITIONS, PIPING, DUCTWORK, UNIT LOCATIONS ETC. PRIOR TO THE COMMENCEMENT OF WORK.
B.	THIS CONTRACTOR TO VISIT JOB SITE BEFORE BID DATE TO VERIFY ALL EXISTING CONDITIONS INDICATED. IT IS THE RESPONSIBILITY OF THE MC TO VERIFY ALL EXISTING QUANTITIES FOR REPLACEMENT/RECONDITIONING ETC. COORDINATE ALL DUCTWORK, PIPING AND EQUIPMENT LOCATIONS WITH ALL OTHER TRADES.
C.	INSTALL NEW SUPPLY DIFFUSERS, REGISTERS, AND EXHAUST GRILLES INTO NEW CEILING GRID AVOIDING LIGHTS, AT APPROXIMATE LOCATIONS SHOWN.
D.	ALL RECTANGULAR DUCTWORK BRANCH CONNECTIONS TO HAVE A 45 DEGREE CINCH COLLAR WITH AN INTEGRAL VOLUME DAMPER. ALL ROUND DUCTWORK BRANCH CONNECTIONS TO HAVE A HIGH EFFICIENCY FITTING WITH AN INTEGRAL VOLUME DAMPER.
E.	PROVIDE TURNING VANES IN ALL SUPPLY DUCTS COMING OUT OF ROOF-TOP UNITS AND ALL 90 DEG ELBOWS, WHETHER SHOWN OR NOT.
F.	PROVIDE ACCESS DOORS FOR ALL FIRE DAMPERS AND DUCT COILS UNLESS OTHERWISE NOTED.
G.	PROVIDE A MINIMUM SIZE ACCESS DOOR OF 24"x24" ON ALL FIRE AND FIRE/SMOKE DAMPERS UNLESS NOT PERMITTED BY DUCT SIZE.
H.	RE-USE EXISTING FLOOR/SLAB/ROOF PIPING PENETRATIONS WHEREVER POSSIBLE. MC RESPONSIBLE FOR ENLARGING OR MODIFYING EXISTING PENETRATIONS AS REQUIRED TO ACCOMMODATE NEW PIPING.
I.	ALL NEW PENETRATIONS FOR PIPING, DUCTWORK OR TO COMPLETE HIS WORK ARE BY THE MC. ALL OPENINGS THAT ARE BY THE GC ARE NOTED ON THESE DRAWINGS OR THE GC DRAWINGS.
J.	PROVIDE ADDITIONAL STRUCTURAL STEEL AND HANGERS AS REQUIRED TO INSTALL AND SUPPORT HVAC EQUIPMENT.
K.	IN GENERAL, ALL DUCTWORK IS TO BE TIGHT TO JOISTS AND MC IS TO COORDINATE DUCTWORK ELEVATIONS WITH ALL OTHER TRADES.
L.	THIS CONTRACTOR IS RESPONSIBLE FOR ALL CUTTING, PATCHING AND PAINTING REQUIRED TO COMPLETE THIS WORK UNLESS OTHERWISE NOTED. ALL PATCHING AND PAINTING MUST EXACTLY MATCH EXISTING CONDITIONS.
M.	ALL AREAS WHERE PIPING IS REMOVED AND NOT REPLACED, THIS CONTRACTOR SHALL PATCH THE AREAS TO MATCH EXISTING CONDITIONS.
N.	REFER TO PIPING SCHEMATICS FOR DETAILED PIPING INFORMATION FOR BOTH THE HEATING AND DOMESTIC HOT WATER SYSTEMS.
O.	NO VALVES SHALL BE PLACED ABOVE/BEHIND DUCTWORK OR IN AN INACCESSIBLE LOCATION.
P.	ALL WORK IS SHOWN DIAGRAMMATIC, IF OFFSETS OR TRANSITIONS IN DUCTWORK ARE REQUIRED FOR SITE CONDITIONS, TO MAINTAIN ARCHITECTS CEILING HEIGHTS AND/OR COORDINATION WITH OTHER TRADES IT IS THE RESPONSIBILITY OF THE MC. ADDITIONALLY, IF A TRANSITION FROM ANY TYPE OF AIR HANDLING UNIT TO THE DUCTWORK SIZE INDICATED IS REQUIRED, IT IS THE RESPONSIBILITY OF THE MC, WETHER THE TRANSITION IS SHOWN OR NOT.
Q.	REFER TO STRUCTURAL DRAWINGS FOR FINAL LOCATIONS OF UNITS AND PENETRATIONS THROUGH DECKS. STRUCTURAL DRAWINGS ARE TO TAKE PRECEDENCE OVER DUCTWORK DRAWINGS FOR LOCATIONS. ANY OFFSETS OR TRANSITIONS IN DUCTWORK REQUIRED FOR COORDINATION WITH STEEL IS THE RESPONSIBILITY OF THE MC.
R.	IT IS NOT THE INTENT OF THE DRAWINGS TO SHOW ALL AIR VENTS OR DRAINS ON THE PIPING SYSTEMS. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO PROVIDE ALL NECESSARY AIR VENTS AT HIGH POINTS WHICH COULD ACCUMULATE AIR WHICH WOULD PREVENT THE PROPER OPERATION OF THE HWS&R AND CHWS&R PIPING. DRAINS SHALL BE PROVIDED AT LOW POINTS IN THE SYSTEM TO FACILITATE THE DRAINING OF HWS&R AND CHWS&R PIPING.
S.	ALL WORK IS SHOWN DIAGRAMMATIC, IF ELBOWS OR CHANGES IN PIPING ELEVATION ARE REQUIRED FOR SITE CONDITIONS, TO MAINTAIN ARCHITECTS CEILING HEIGHTS AND/OR COORDINATION WITH OTHER TRADES IT IS THE RESPONSIBILITY OF THE MC.
T.	UNLESS NOTED ON THE EC OR TC DRAWINGS, THIS CONTRACTOR IS FULLY RESPONSIBLE TO PROVIDE ALL WIRING OR ANY FINAL CONNECTIONS FOR ANY MECHANICAL EQUIPMENT TO MAKE THAT UNIT FULLY OPERATIONAL.
U.	INSTALLATION OF ROOF TOP DUCTWORK SHALL BE ACCORDING TO SPECIFICATION SECTION 233330, ITEM 2.15. DUCT LINER INSTALLATION SHALL BE ACCORDING TO SPECIFICATION SECTION 233330 ITEM 2.11. ALSO REFER TO SECTION 230005, ITEM 1.17 FOR STORAGE OF MATERIALS.
GENERAL NOTES - TEMPERATURE CONTROLS	
A.	ALL WORK SHOWN SHALL BE BY TEMPERATURE CONTROLS CONTRACT UNLESS NOTED OTHERWISE (TYPICAL FOR ALL TC DRAWINGS).
B.	WIRE ALL LOW VOLTAGE, LINE VOLTAGE CONTROL, AND COMMUNICATIONS CABLING FOR A COMPLETE FULLY OPERATIONAL SYSTEM. COORDINATE WITH HEATING CONTRACTOR & ELECTRIC CONTRACTOR WHERE REQUIRED FOR ALL INTERFACES.
C.	CONTROL PANELS ARE NOT SHOWN ON THE DRAWINGS. CONTRACTOR IS RESPONSIBLE FOR PROVIDING PROPER QUANTITIES OF PANELS TO MEET I/O SCHEDULE & DIAGRAM I/O. RISER DIAGRAMS ARE FOR INFORMATION ONLY & MAY NOT INDICATE ALL PANELS. ADDITIONALLY, SOME JOBS MAY HAVE LINE VOLTAGE POWER PROVIDED BY THE EC IN POSSIBLE PANEL LOCATIONS. THE TC SHALL REVIEW THESE PRIOR TO BID AND SHALL PROVIDE ANY ADDITIONAL LOCATIONS FOR POWER UNDER HIS CONTRACT AND WITHIN THE TC BID.
D.	LOCATE ALL BUILDING CONTROLLERS ON THE SUBMITTAL SO THAT C.C. CAN FURNISH A DATA DROP IN THAT SPACE. T.C. TO COORDINATE WITH E.C..
E.	IN ROOMS THAT HAVE A HARD CEILING TC SHALL PROVIDE RACEWAY FOR HIS WIRING. THERE SHALL BE NO EXPOSED CONTROL WIRING IN A OCCUPIED SPACE.
F.	TEMPERATURE CONTROL VALVES: SIZE VALVES PER CHART IN SPECIFICATION SECTION WITH MAXIMUM DELTA P OF 3PSI.
G.	WHERE ANY THERMOSTAT THAT IS REMOVED, THE WALL SHALL BE PATCHED AND PAINTED TO MATCH THE EXISTING.

GENERAL	
	REMOVE / CONNECT TO
	REMOVAL NOTE TAG
	INSTALLATION NOTE TAG
	PIPING BREAK
	EDGE BREAK LINE
	OFFSET FOR CLARITY
	DUCT WORK ELEVATION

DUCTWORK AND FITTINGS	
	DUCTWORK W / INTERNAL LINER
	DUCTWORK UNLINED
	TURNING VANES
	SQUARE TO ROUND TRANSITION
	HIGH EFFICIENCY TAKE-OFF W / INTEGRAL DAMPER
	VOLUME DAMPPER
	FIRE DAMPER W / ACCESS DOOR
	FIRE/SMOKE DAMPER W / ACCESS DOOR
	DUCT ACCESS DOOR
	FLEXIBLE DUCTWORK (6" MAX)
	FLEXIBLE COLLAR
	RECTANGULAR DUCT DESIGNATION
	ROUND DUCT DESIGNATION
	FLAT OVAL DUCT DESIGNATION
	ROOF MOUNTED EXHAUST FAN
	4 - WAY SUPPLY DIFFUSER
	2 - WAY SUPPLY DIFFUSER
	RETURN AIR GRILLE
	BACKDRAFT DAMPER (BD-1,2)
	SMOKE DETECTOR FURNISHED AND WIRED BY EC, INSTALLED BY MC

FITTINGS & ACCESSORIES	
	PIPE ELBOW DOWN
	PIPE ELBOW UP
	PIPE TEE DOWN
	PIPE UNION
	PIPE REDUCER
	CAP - SCREWED
	PIPE FLANGE
	PIPE STRAINER W / BLOW DOWN
	PIPE ANCHOR
	MANUAL AIR VENT
	PRESSURE GUAGE W / SNUBBER
	TEMPERATURE GUAGE
	PIPE ISOLATION JOINT
	RELIEF VALVE (RV)

PIPING	
	PIPING BEING REMOVED
	EXISTING PIPING TO REMAIN
	HOT WATER SUPPLY
	HOT WATER RETURN
	PROPYLENE GLYCOL HOT WATER SUPPLY
	PROPYLENE GLYCOL HOT WATER RETURN
	LOW PRESSURE STEAM
	CONDENSATE RETURN
	CONDENSATE DRAIN (GRAVITY)
	CONDENSATE DRAIN (PUMPED)
	REFRIGERANT SUCTION LINE
	REFRIGERANT LIQUID LINE
	HOT GAS BYPASS REFRIGERANT LINE

VALVES	
	BALL VALVE(BV)
	BUTTERFLY OR WAFER VALVE(WV)
	GATE VALVE(GV)
	GLOBE VALVE(GLV)
	CHECK VALVE(CKV)
	CONTROL VALVE (2-WAY)
	CONTROL VALVE (3-WAY)
	BALANCING VALVE(CBV)
	TRIPLE DUTY VALVE (TDV)
	FLOW CONTROL VALVE(FCV)
	DRAIN VALVE ASSEMBLY(SS)

PIPE SIZING	
0-2 GPM	3/4" COPPER
3-5 GPM	1" COPPER
6-8 GPM	1-1/4" COPPER
9-14 GPM	1-1/2" COPPER
15-30 GPM	2" COPPER
31-50 GPM	2-1/2" STEEL
51-90 GPM	3" STEEL
91-200 GPM	4" STEEL
201-500 GPM	6" STEEL

TEMP CONTROL SYMBOLS	
	LINE VOLTAGE BY T.C.
	LOW VOLTAGE WIRING BY T.C.
	WIRING BY DIV #26(EC)
	CONDUCTORS
	CURRENT FLOW SWITCH (STATUS)CFS-1
	CONTROL RELAY CR-1
	CARBON DIOXIDE SENSOR CDS-1, CDS-2
	DUCT SENSOR, SPS-1
	DAMPER - OPPOSED BLADE D-1
	DAMPER - PARALLEL BLADE D-2
	DAMPER ACTUATOR ME-1,2,3
	DIFFERENTIAL PRESSURE SWITCH - DPT-1,1A
	END SWITCH ES-1
	FLOW SWITCH FS-1
	HORN
	HUMIDITY SENSOR DUCT MOUNTED HSR
	HUMIDITY SENSOR HSTS
	LOW TEMPERATURE CUT OUT MANUAL RESET LC-1
	MOTOR STARTER
	MOTION SENSOR MS-1, MDS-1, MDS-2
	MOTOR
	NORMALLY OPEN CONTACT
	NORMALLY CLOSED CONTACT
	PROGRAM CLOCK
	PILOT LIGHT
	START PUSH BUTTON
	STOP PUSH BUTTON
	STATIC PRESSURE FILTER ALARM - DPS-1
	STATIC PRESSURE NETWORK SENSOR SPNL-1
	STATIC PRESSURE SENSOR SPS-1
	SWITCH
	TWO WAY VALVE CVF, CVT
	THREE WAY VALVE CVM, CVT, CVZM
	TEMPERATURE SENSOR ITS, ITS-1
	TEMPERATURE SENSOR AVERAGING TSDA
	TEMPERATURE SENSOR TSD
	TEMPERATURE CONTROL POINT
	TEMPERATURE CONTROL PANEL TCP
	TRANSFORMER - XT-1
	THERMOSTAT W / GUARD TSB, TSR
	VARIABLE AIR VOLUME MODULAR ASSEMBLY VMA
	VARIABLE FREQUENCY DRIVE

ABBREVIATIONS	
A	AIR OR COMPRESSED AIR
AC	AIR CONDITIONING
AD	ACCESS DOOR
AFF	ABOVE FINISHED FLOOR
AFG	ABOVE FINISHED GRADE
AHU	AIR HANDLING UNIT
APD	AIR PRESSURE DROP AUTOMATIC
ATC	TEMPERATURE CONTROL
ATM	ATMOSPHERE
ACCU	AIR COOLED CONDENSING UNIT
ADJ	ADJUSTABLE
BD	BACKDRAFT DAMPER
BHP	BRAKE HORSEPOWER
BOD	BOTTOM OF DUCT
BMS	BUILDING MANAGEMENT SYSTEM
BC	BOOKCASE
CH	CABINET HEATER
CFM	CUBIC FEET PER MINUTE
CT	COOLING TOWER
CH	CABINET UNIT HEATER
CD	CONTROL DAMPER
DB	DRY BULB
DEGREE	DEGREE
DDC	DIRECT DIGITAL CONTROL
DP	DIFFERENTIAL PRESSURE
DAC	DUCTLESS SPLIT A/C UNIT
DCU	DUCTLESS SPLIT CONDENSING UNIT
DHU	DEHUMIDIFYING UNIT
DS	DUCT SILENCER
EA	EXHAUST AIR
EC	ELECTRICAL CONTRACTOR
EAT	ENTERING AIR TEMPERATURE
EF	EXHAUST FAN
EMS	ENERGY MANAGEMENT SYSTEM
ESP	EXTERNAL STATIC PRESSURE
EWI	ENTERING WATER TEMPERATURE
EXH	EXHAUST
EXR	EXISTING TO REMAIN
ERU	ENERGY RECOVERY UNIT
EG	EXHAUST GRILL
F	FAHRENHEIT
FA	FREE AREA
FCU	FAN COIL UNIT
FRD-B/A	FIRE DAMPER
FRD-S	FIRE/SMOKE DAMPER
FLA	FULL LOAD AMPS
FPM	FEET PER MINUTE
FPS	FEET PER SECOND
FS	FLOW SWITCH
FTR	FIN TUBE RADIATION
GC	GENERAL CONTRACTOR
GPM	GALLONS PER MINUTE
HV	HEATING & VENTILATING UNIT
HD	HEAD
HP	HORSEPOWER
HRI	HEAT RECOVERY UNIT
HTG	HEATING
HP	HEAT PUMP UNIT
HZ	HERTZ (CYCLES PER SECOND)
KW	KILOWATT
LAT	LEAVING AIR TEMPERATURE
LWT	LEAVING WATER TEMPERATURE
MAT	MIXED AIR TEMPERATURE
MBH	1000 BTUHR
MCA	MECHANICAL CONTRACTOR
MUA	MAKE UP AIR
MCA	MINIMUM CIRCUIT AMPACITY
MOP/ MOCP	} MAXIMUM OVERCURRENT PROTECTION
NC	
NO	NORMALLY CLOSED
NOM	NORMALLY OPEN NOMINAL
OA	OUTSIDE AIR
OD	OUTSIDE DIAMETER
ODP	OPEN DRIP PROOF
OV	OPEN VELOCITY
OAT	OUTSIDE AIR TEMPERATURE
PC	PLUMBING CONTRACTOR
PD	PRESSURE DROP
PRV	PRESSURE REDUCING VALVE
PSI	POUNDS PER SQ IN
RESR	ROOF EQUIPMENT SUPPORT RAIL
RH	ROOF HOOD
RTU	ROOFTOP UNIT
RA	RETURN AIR
RET	RETURN
RH	RELATIVE HUMIDITY
RPM	REVOLUTIONS PER MINUTE
SAT	SUPPLY AIR TEMPERATURE
SF	SUPPLY FAN
SCV	SELF CONTAINED VALVE
SA	SUPPLY AIR
SP	STATIC PRESSURE
SG	SUPPLY GRILL
T	TEMPERATURE OR THERMOSTAT
TEMP	TEMPERATURE
TON	12,000 BTUH (COOLING CAPACITY)
TSB	TEMPERATURE SENSOR BUTTON TYPE
TSR	TEMPERATURE SENSOR WIDISPLAY
TSP	TOTAL STATIC PRESSURE
TYP	TYPICAL
TC	TEMPERATURE CONTROL CONTRACTOR
UV	UNIT VENT
UH	UNIT HEATER
UC	UTILITY COMPARTMENT
V	VOLTS
VAV	VARIABLE AIR VOLUME
VD	VOLUME DAMPER
VEL	VELOCITY
VFD	VARIABLE FREQUENCY DRIVE
VFC	VARIABLE REFRIGERANT FAN COIL
WB	WET BULB TEMPERATURE
WG	WATER GAGE
WPD	WATER PRESSURE DROP



Architect:  
**Hamlin Design Group**  
915 Broadway, Suite 101A  
Albany, New York 12207  
Tel: 518.724.5159  
Fax: 518.320.8633  
Web: hamlindesigngroup.com

Hazardous Material Consultant:

Ambient Environmental, Inc.  
Comprehensive Building Science solutions  
NYS/NES Certified WBE  
E SBA EDW058 & DBE

MEP Engineer:

Engineered Solutions  
646 Plank Road #104  
Clifton Park, NY 12061  
phone: (518) 280-2410  
fax: (518) 280-2481  
www.engineered-solutions.net  
Electrical  
Communications  
Mechanical  
ES # 19071

Client:

**Peekskill City School District**  
1031 Elm St.  
Peekskill, NY 10566

**Peekskill Reconstruction**  
SED Project: 66-15-00-01-0-005-020  
HDG Project: 201  
**Oakside Elementary**  
200 Decatur Ave.,  
Peekskill, NY 10566  
SED Project: 66-15-00-01-0-007-014  
HDG Project: 202  
**Uriah Hill School**  
980 Pemart Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-008-017  
HDG Project: 203  
**Woodside Elementary**  
612 Depew St.,  
Peekskill, NY 10566  
SED Project: 66-15-00-01-0-014-005  
HDG Project: 204  
**Middle School**  
212 Ringgold St.,  
Peekskill, NY 10566

DRAWN BY:  
MLB


ISSUE: 02/01/2021  
REV:



DESCRIPTION  
Notes and Symbols

M.001.00






1

THERMOSTAT/SENSORS DIAGRAMS

SCALE : NONE

POINT NAME	DEVICE NAME	HARDWARE POINTS				SOFTWARE POINTS					GRAPHIC
		AI	AO	DI	DO	AV	BV	SCHED	TREND	ALARM	
HEATING VALVE	CVF		X						X		X
SPACE TEMPERATURE	TSB/TSR	X						X	X		X



2

PERIMETER RADIATION CONTROLS DIAGRAM

SCALE : NONE

NOTES:  
1. TYPICAL FOR ALL UNITS W/O SELF CONTAINED CONTROL VALVE.

A. FIN RADIATION/RADIANT PANEL CONTROL SEQUENCE: FIN RADIATION/PANEL RADIATION WILL BE CONTROLLED BY ROOM SENSOR OR SEQUENCE WITH HVAC EQUIPMENT SERVICING INDIVIDUAL ROOM BY MEANS OF A CONTROL VALVE.


DECTRON POINT NAME	WRITEABLE FUNCTION	SHOWN ON BMS GRAPHIC
ON/OFF	Y	X
RETURN AIR HUMIDITY	N	X
RETURN AIR TEMPERATURE	N	X
SUPPLY AIR TEMPERATURE	N	X
DEHUMIDIFICATION ON/OFF	N	X
FAN ON/OFF	N	X
COMPRESSOR ON/OFF	N	X
SYSTEM RESTART	Y	X

NOTES:  
1. BMS CONNECTION AT UNIT. ALL FUNCTIONS AND OPERATION WILL GO THROUGH THE UNIT BACnet CONNECTION.

BMS POINT LIST

POINT NAME	DEVICE NAME	HARDWARE POINTS				SOFTWARE POINTS					GRAPHIC
		AI	AO	DI	DO	AV	DV	SCHED	TREND	ALARM	
CRAWL SPACE TEMP/HUMIDITY	HSTS	X							X		X
BACNET INTERFACE											X
HIGH SPACE TEMPERATURE										X	
DAMPER	ME-1				X			X	X		X

BMS SYSTEM SEQUENCE:  
1. WHEN DEHUMIDIFIER IS IN OPERATION, AND THE OUTSIDE AIR TEMPERATURE IS ABOVE 40F AND BELOW 50% RH, THE OUTSIDE AIR DAMPER SHALL BE OPEN.



e

ME-1

e

TSR

e

CVF

4

CRAWL SPACE DEHUMIDIFIER CONTROL DIAGRAM


SCALE : NONE

THE UNIT SHALL COME WITH MANUFACTURERS CONTROLS. THE BMS SHALL INTERFACE WITH THE UNIT AND DISPLAY THE UNITS OUTPUTS GRAPHICALLY.

A. THE UNIT SHALL FOLLOW THE MANUFACTURERS SEQUENCE (ABBREVIATED HERE):

- WHEN THE UNIT IS STARTED, THE FAN SHALL START AND RUN CONTINUOUSLY TO MAINTAIN DESIRED HUMIDITY LEVELS.
- IF THE FREEZESTAT IS TRIPPED, THE UNIT WILL SHUT DOWN.

POINT NAME	DEVICE NAME	HARDWARE POINTS				SOFTWARE POINTS					GRAPHIC
		AI	AO	DI	DO	AV	BV	SCHED	TREND	ALARM	
FAN START/STOP	CR-1				X			X	X		X
FAN STATUS	CFS-1			X					X	X	X
DAMPER OPEN/CLOSE	ME-2				X			X	X		X
END SWITCH	ES-1				X			X	X		X




3

EXHAUST FAN CONTROLS DIAGRAM

SCALE : NONE

BMS SYSTEM SEQUENCE:

- THE EXHAUST FAN SHALL OPERATE WHEN THE OUTSIDE AIR DAMPER ON THE DEHUMIDIFIER IS OPEN OR BASED ON A SCHEDULE. THE SCHEDULE SHALL BE 9AM TO 5PM (adj). THE OPERATOR SHALL BE ABLE TO SWITCH BETWEEN THE 2 MODES.



Architect:  
**Hamlin Design Group**  
915 Broadway, Suite 101A  
Albany, New York 12207  
Tel: 518.724.5159  
Fax: 518.320.8633  
Web: hamlindesigngroup.com

Hazardous Material Consultant:



MEP Engineer:



Client:



**Peekskill City School District**  
1031 Elm St.  
Peekskill, NY 10566

**Peekskill Reconstruction**

SED Project: 66-15-00-01-0-005-020  
HDG Project: 201  
**Oakside Elementary**  
200 Decatur Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-007-014  
HDG Project: 202  
**Uriah Hill School**  
980 Pemart Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-008-017  
HDG Project: 203  
**Woodside Elementary**  
612 Depew St.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-014-005  
HDG Project: 204  
**Middle School**  
212 Ringgold St.,  
Peekskill, NY 10566

DRAWN BY:  
MLB


ISSUE: 02/01/2021  
REV:



DESCRIPTION  
Temperature Controls

M.701.00





POINT NAME	DEVICE NAME	HARDWARE POINTS				SOFTWARE POINTS					GRAPHIC
		AI	AO	DI	DO	AV	DV	SCHED	TREND	ALARM	
SUPPLY FAN		--									
FAN START/STOP	CR-1				X				X		X
FAN STATUS	CFS-1			X					X		X
FAN FAILURE										X	
O.A. DAMPER	ME-1		X						X		X
R.A. DAMPER	ME-1		X						X		X
RELIEF DAMPER	ME-1		X						X		X
FACE AND BYPASS	ME-1		X						X		X
MIXED AIR TEMPERATURE	TSB	X							X		X
FREEZESTAT	LC-1			X						X	X
COOLING STAGES				X					X		X
DISCHARGE AIR TEMPERATURE	TSB	X							X		X
HIGH DISCHARGE TEMPERATURE										X	
LOW DISCHARGE TEMPERATURE										X	
SPACE TEMPERATURE	TSB	X							X		X
HIGH SPACE TEMPERATURE										X	
LOW SPACE TEMPERATURE										X	
SPACE TEMP. SETPOINT						X			X		
SCHEDULE							X				
POINTS LIST BY UNIT MANUFACTURER.											
ITEMS SHOULD BE SHOWN ON GRAPHIC INTERFACE											

- A. UNIT VENTILATOR:
- GENERAL: WHEN SUPPLY FAN IS OFF, OA (OUTSIDE AIR) DAMPER IS CLOSED, MA (MIXED AIR) DAMPER IS FULL OPEN. WHERE APPLICABLE.
  - WHEN SPACE OR LOCAL ZONE SWITCHES TO OCCUPIED CYCLE, FAN SHALL START AND RUN CONTINUOUSLY. OA AND MA DAMPERS OPEN TO MINIMUM POSITION. RELIEF DAMPER IS OPEN.
  - HEATING:
    - GENERAL: OA DAMPER SHALL BE SET AT A MINIMUM POSITION. OA DAMPER AND RELIEF DAMPER SHALL CONTINUOUSLY ALLOW INTRODUCTION OF FRESH AIR REGARDLESS OF OUTSIDE AIR TEMPERATURE. FAN DISCHARGE SENSOR WILL MAINTAIN A MINIMUM TEMPERATURE OF 60°F (ADJUSTABLE).
    - COIL:
      - CHANGES IN SPACE TEMPERATURE BELOW SETPOINT WILL CAUSE CONTROLLER TO INDEX DISCHARGE TEMPERATURE ACCORDING TO A PRESET SCHEDULE. CONTROLLER WILL MODULATE FACE AND BYPASS DAMPER TO MAINTAIN DESIRED TEMPERATURE.
      - IF HEATING COIL LEAVING AIR TEMPERATURE FALLS BELOW 35°F, LOW LIMIT CONTROLLER (LC-1) SHALL STOP FAN, CLOSE OAD, OPEN FACE DAMPER AND SIGNAL ALARM CONDITION TO SYSTEM.
  - SPACE TEMPERATURE SETPOINT SHALL BE AN ADJUSTABLE BIAS LIMITED TO ±2°F SPACE SENSOR, NORMAL SETPOINT SHALL BE ADJUSTABLE FROM MAIN CONSOLE ONLY.
  - ON RISE IN SPACE TEMPERATURE ABOVE SETPOINT AND OA TEMPERATURE IS BETWEEN 55°F (adj) AND 75°F (adj), FACE AND BYPASS DAMPER CLOSES TO COIL, OA DAMPER OPENS FULLY, RA DAMPER CLOSES FULLY TO PROVIDE ECONOMIZER COOLING.
  - WHEN OAT UNABLE TO PROVIDE COOLING, OAD, RELIEF DAMPER SHALL CLOSE TO MINIMUM POSITION, FACE AND BYPASS DAMPER OPENS TO COOLING COIL WITH AUXILIARY SWITCH ON ACTUATOR PROVIDING POSITIVE PROOF OF POSITION.
  - IF OAT FALLS BELOW SETPOINT (50°F), LTCO SHALL LOCK OUT CONDENSER UNITS.
  - IF HOT WATER/DX COIL DISCHARGE SENSOR TEMPERATURE FALLS BELOW 50°F WHEN CONDENSER IS OPERATING, ALARM DDC SYSTEM IMMEDIATELY.
  - UNOCCUPIED CYCLE:  
WHEN ZONE SWITCHES TO NIGHT CYCLE, CLOSE OAD, RELIEF DAMPER AND FULLY OPEN RA DAMPER. WHERE APPLICABLE, HEAT CONTROL VALVE OPENS TO COIL AND/OR FACE DAMPER OPENS TO COIL.
    - FAN SHALL RUN INTERMITTENTLY TO MAINTAIN A LOWER NIGHT SETPOINT.
    - COOLING SHALL BE LOCKED OUT, I.E. CONDENSER UNIT IS OFF.
    - NIGHT OVERRIDE SHALL BE BY PB ON TEMPERATURE SENSOR OR BY MAIN CONSOLE.

SEQUENCE BY UNIT MANUFACTURER.

## 1 SELF CONTAINED UNIT VENTILATOR DETAIL


SCALE: NONE

CONTROLS FOR A SELF CONTAINED UNIT VENTILATOR ARE BY THE UNIT MANUFACTURER.

- THROUGH THE DDC INTERFACE, THE BMS CAN:
- CHANGE THE UNIT STATUS (OCCUPIED/UNOCCUPIED)
  - ADJUST TEMPERATURE SETPOINT
  - CHANGE THE UNIT FROM HEATING TO COOLING
  - CHANGE FAN SPEED
  - CHANGE THE OUTSIDE AIR DAMPER SETTING

POINT NAME	DEVICE NAME	HARDWARE POINTS				SOFTWARE POINTS					GRAPHIC
		AI	AO	DI	DO	AV	DV	SCHED	TREND	ALARM	
SUPPLY FAN		--									
FAN START/STOP	CR-1				X				X		X
FAN STATUS	CFS-1			X					X		X
FAN FAILURE										X	
O.A. DAMPER	ME-3		X						X		X
R.A. DAMPER	ME-3		X						X		X
FACE AND BYPASS	ME-3		X						X		X
MIXED AIR TEMPERATURE	TSB	X							X		X
HEATING VALVE	CVT		X						X		X
FREEZESTAT	LC-1			X						X	X
DISCHARGE AIR TEMPERATURE	TSB	X							X		X
SCHEDULE							X				

- A. UNIT VENTILATOR SEQUENCE (HEATING):
- GENERAL: WHEN SUPPLY FAN IS OFF, OUTDOOR AIR AND RELIEF AIR DAMPERS ARE CLOSED. RETURN AIR DAMPER IS OPEN. WHERE APPLICABLE, HEATING COIL VALVE IS OPEN TO COIL AND/OR FACE DAMPER IS OPEN TO COIL. HEATING VALVE WILL MODULATE WITH FACE AND BYPASS DAMPER WHEN OUTDOOR AIR TEMPERATURE IS ALMOST 38°F. WHEN OUTDOOR AIR TEMPERATURE IS BELOW 35°F CONTROL VALVE IS OPEN AND ONLY FACE AND BYPASS DAMPER IS USED. WATER VALVE REMAIN UNDER CONTROL OF ROOM SENSOR.
  - OCCUPIED CYCLE:
    - WHEN SPACE OR LOCAL ZONE SWITCHES TO DAY CYCLE, FAN SHALL START AND RUN CONTINUOUSLY.
    - OUTSIDE AIR DAMPER AND RELIEF DAMPER OPENS TO MINIMUM POSITION REGARDLESS OF OUTDOOR AIR TEMPERATURE. MINIMUM POSITION TO BE SET FROM SCHEDULE.
    - AS SPACE TEMPERATURE FALLS, RADIATOR VALVE SHALL MODULATE OPEN, A CONTINUED DROP IN ROOM TEMPERATURE WILL MODULATE COIL VALVE AND FACE AND BYPASS DAMPER AS NOTED ABOVE OPEN TO MAINTAIN DESIRED ROOM CONDITIONS.
    - SPACE TEMPERATURE SETPOINT OF 70°F (ADJUSTABLE) SHALL BE AN ADJUSTABLE BIAS LIMITED TO ±2°F AT SPACE SENSOR, NORMAL SETPOINT SHALL BE ADJUSTABLE FROM LOCAL ROOM SENSOR OR MAIN CONSOLE.
    - IF SAT FALLS BELOW 35°F, LOW LIMIT CONTROLLER (LC-1) SHALL STOP FAN. SHUT DOWN INCLUDES CLOSE OAD, STOP SUPPLY AIR FAN, OPEN CONTROL VALVE.
    - OUTSIDE AIR DAMPER AND RELIEF DAMPER SHALL CONTINUOUSLY ALLOW INTRODUCTION OF FRESH AIR REGARDLESS OF OUTSIDE AIR TEMPERATURE.
    - ON RISE IN SPACE TEMPERATURE, UV COIL VALVE, FACE AND BYPASS DAMPER AND RADIATOR VALVE WILL CLOSE IN SEQUENCE, OAD AND RELIEF DAMPER WHERE REQUIRED WILL MODULATE OPEN TO PROVIDE ECONOMIZER COOLING. LOW LIMIT THERMOSTAT SHALL PREVENT DISCHARGE AIR FROM FALLING BELOW SETPOINT (SET AT 60°F).
    - ECONOMIZER MODE: CONTROLLER SHALL MODULATE OA DAMPER IN SEQUENCE TO MINIMUM VALUE AT 68°F LAT (ADJUSTABLE). IF OUTSIDE AIR TEMP RISES ABOVE 72°F, THEN OUTSIDE AIR DAMPERS SHALL BE POSITIONED FOR MAXIMUM VALUE AND HEATING IS OFF. WHEN OUTSIDE AIR TEMP GOES ABOVE 78°F (ADJUSTABLE) OUTSIDE AIR DAMPER SHALL RETURN TO MINIMUM VALUE.
  - UNOCCUPIED CYCLE:
    - WHEN ZONE SWITCHES TO NIGHT CYCLE, CLOSE OAD, RELIEF DAMPER AND FULLY OPEN RA DAMPER.
    - FAN SHALL RUN INTERMITTENTLY TO MAINTAIN A LOWER NIGHT SETPOINT OF 55°F.
    - NIGHT OVERRIDE SHALL BE BY PB ON TEMPERATURE SENSOR OR BY MAIN CONSOLE.




## 2 UV CONTROLS HEATING ONLY

SCALE: NONE

NOTE: ALL UNIT VENTS TO HAVE FACE AND BYPASS CONTROL AND VALVE CONTROL.

HAMLIN



Architect:

**Hamlin Design Group**

915 Broadway, Suite 101A


Albany, New York 12207

Tel: 518.724.5159


Fax: 518.320.8633

Web: hamlindesigngroup.com

Hazardous Material Consultant:



MEP Engineer:



Client:



**Peekskill City School District**

1031 Elm St.

Peekskill, NY 10566

**Peekskill Reconstruction**

SED Project: 66-15-00-01-0-005-020

HDG Project: 201

**Oakside Elementary**

200 Decatur Ave.,

Peekskill, NY 10566

SED Project: 66-15-00-01-0-007-014

HDG Project: 202

**Uriah Hill School**

980 Pemart Ave.,

Peekskill, NY 10566

SED Project: 66-15-00-01-0-008-017

HDG Project: 203

**Woodside Elementary**

612 Depew St.,

Peekskill, NY 10566

SED Project: 66-15-00-01-0-014-005

HDG Project: 204

**Middle School**

212 Ringgold St.,

Peekskill, NY 10566

DRAWN BY:

MLB

ISSUE: 02/01/2021

REV:




DESCRIPTION


Temperature Controls

M.702.00






HAMLIN




Architect:  
**Hamlin Design Group**  
915 Broadway, Suite 101A  
Albany, New York 12207  
Tel: 518.724.5159  
Fax: 518.320.8633  
Web: hamlindesigngroup.com

Hazardous Material Consultant:



MEP Engineer:



Client:



**Peekskill City School District**  
1031 Elm St.  
Peekskill, NY 10566

### Peekskill Reconstruction

SED Project: 66-15-00-01-0-005-020  
HDG Project: 201

#### Oakside Elementary

200 Decatur Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-007-014  
HDG Project: 202

#### Uriah Hill School

980 Pemart Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-008-017  
HDG Project: 203

#### Woodside Elementary

612 Depew St.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-014-005  
HDG Project: 204

#### Middle School

212 Ringgold St.,  
Peekskill, NY 10566


DRAWN BY:  
TG

ISSUE: 02/01/2021  
REV:



DESCRIPTION  
Lower Level Floor Plan

O-A.100.00




1

## Oakside Elementary - Lower Level Floor Plan

SCALE: 1/8" = 1'-0"

### LEGEND



### GENERAL REMOVAL NOTES

- ALL WALL, FLOORING, & CLG. SURFACES TO REMAIN WHICH ARE DAMAGED DURING REMOVALS SHALL BE REPAIRED TO MATCH SURROUNDING MATERIALS & PREPARED READY FOR APPLICATION OF REQ'D FINISHES. PROVIDE MATERIALS TO MATCH EXIST. MATERIALS & SURFACES "IN-KIND". THIS INCLUDES BUT NOT LIMITED TO REPLACEMENT OF FINISH MATLS, DRYWALL CONST., MASONRY, & MASONRY REPAIRS, TAPING, SANDING, & PAINTING ETC.
- DIMENSIONED REMOVALS ARE FOR GENERAL INFORMATIONAL PURPOSES ONLY. COORDINATE EXACT EXTENT OF ALL REMOVALS AND MODIFICATIONS W/ CONST.
- WHERE REMOVALS OF MASONRY OCCURS, TOOTH IN MASONRY TO MATCH EXIST. COURSING & CONST. MATCH EXIST. MASONRY MATLS, USE SALVAGED MASONRY FOR PATCHING & REPAIR.
- AT ALL MASONRY OPENINGS OF REMOVALS PROVIDE TEMPORARY SHORINGS TO MAINTAIN STRUCTURAL INTEGRITY OF EXISTING CONST.
- SEE MECHANICAL, ELECTRICAL, AND PLUMBING FOR ADDITIONAL REMOVALS.
- CONTRACTOR SHALL PROVIDE PROTECTION OVER EXISTING FLOORING SYSTEMS AT ALL TIMES UNLESS FLOORING IS SCHEDULED FOR REMOVAL.
- HAZARDOUS MATERIAL SHALL BE REMEDIATED BY CERTIFIED HAZARDOUS MATERIAL CONTRACTOR. COORDINATE ALL WORK WITH HAZARDOUS MATERIAL DOCUMENTS.

### KEYED REMOVAL NOTES


- REMOVE EXISTING VINYL TILE FINISH FLOORING & CONCEALED FLOORING MATERIALS COMPLETE, INCLUDING BUT NOT LIMITED TO ADHESIVES, AS REQUIRED FOR INSTALLATION OF NEW UNIT VENT.
- REMOVE WALL CONST. AS REQUIRED FOR INSTALLATION OF NEW UNIT VENT AND LOUVER. SEE MECHANICAL DRAWINGS.
- REMOVE EXISTING CEILING SYSTEM COMPLETE, INCLUDING SUSPENSION WIRES, ANCHORS, CLIPS, FASTENERS, CHANNELS, ETC. (V.I.F.) SALVAGE EXISTING CEILING TILES, LIGHT FIXTURES, SMOKE DETECTORS, SECURITY CAMERAS, AND SPEAKERS.
- REMOVE AND SALVAGE EXISTING WINDOW SASH AS REQUIRED FOR INSTALLATION OF NEW UNIT VENT. SEE MECHANICAL DRAWINGS.
- REMOVE AIR CONDITIONER WINDOW UNIT AND PANEL. RETURN TO OWNER

### GENERAL PLAN NOTES


- ALL DIMENSIONS ARE TO FINISH FACE AT EXISTING CONST. AND UNIT MASONRY CONSTRUCTION AND TO FACE OF FRAMING AT DRYWALL CONSTRUCTION UNLESS OTHERWISE NOTED.
- ± NOTATIONS ARE USED IN DIMENSION STRINGS TO ACCOUNT FOR VARIATIONS BETWEEN DRAWINGS AND FIELD CONDITIONS. CONTRACTOR SHALL VERIFY ALL ± DIMENSION DURING LAYOUT AND INFORM ARCHITECT OF ANY DISCREPANCIES OR NECESSARY MODIFICATIONS PRIOR TO PROCEEDING WITH CONSTRUCTION.
- CLEAN PATCH & REPAIR EXISTING WALLS AS REQ'D TO RESTORE TO LIKE NEW CONDITION. FINISH SURFACES TO BE SMOOTH AND FLUSH WITH ADJACENT SURFACES AND READY TO RECEIVE PAINT.

### KEYED PLAN NOTES

- INSTALL NEW FLOORING TO MATCH EXIST WHERE DAMAGED DURING REMOVAL / INSTALLATION.
- PATCH & REPAIR EXTERIOR WALL CONST. AS REQUIRED FOR NEW UNIT VENT INSTALLATION.
- INSTALL NEW 2'X2' SUSPENDED ACOUSTICAL CEILING SYSTEM IN EXISTING LOCATION USING SALVAGED CEILING TILES.
- PAINT ENTIRE WALL BELOW WINDOW UNITS TO MATCH EXISTING ROOM COLOR AND FINISH.







**1 Oakside Elementary - Main Level Floor Plan**  
O-A.101 SCALE: 1/8" = 1'-0"

LEGEND

- EXISTING WALL CONST. TO REMAIN
- EXISTING DOOR AND FRAME TO REMAIN
- AREA OF WORK  
(SEE ELECTRICAL, MECHANICAL, AND PLUMBING FOR ADDITIONAL DETAILS)
- REFERENCE PHOTO

GENERAL REMOVAL NOTES

- R1. ALL WALL, FLOORING, & CLG. SURFACES TO REMAIN WHICH ARE DAMAGED DURING REMOVALS SHALL BE REPAIRED TO MATCH SURROUNDING MATERIALS & PREPARED READY FOR APPLICATION OF REQ'D FINISHES. PROVIDE MATERIALS TO MATCH EXIST. MATERIALS & SURFACES "IN-KIND". THIS INCLUDES BUT NOT LIMITED TO REPLACEMENT OF FINISH MATLS, DRYWALL CONST., MASONRY, & MASONRY REPAIRS, TAPING, SANDING, & PAINTING ETC.
- R2. DIMENSIONED REMOVALS ARE FOR GENERAL INFORMATIONAL PURPOSES ONLY. COORDINATE EXACT EXTENT OF ALL REMOVALS AND MODIFICATIONS W/ CONST.
- R3. WHERE REMOVALS OF MASONRY OCCURS, TOOTH IN MASONRY TO MATCH EXIST. COURSING & CONST. MATCH EXIST. MASONRY MATLS, USE SALVAGED MASONRY FOR PATCHING & REPAIR.
- R4. AT ALL MASONRY OPENINGS OF REMOVALS PROVIDE TEMPORARY SHORINGS TO MAINTAIN STRUCTURAL INTEGRITY OF EXISTING CONST.
- R5. SEE MECHANICAL, ELECTRICAL, AND PLUMBING FOR ADDITIONAL REMOVALS.
- R6. CONTRACTOR SHALL PROVIDE PROTECTION OVER EXISTING FLOORING SYSTEMS AT ALL TIMES UNLESS FLOORING IS SCHEDULED FOR REMOVAL.
- R7. HAZARDOUS MATERIAL SHALL BE REMEDIATED BY CERTIFIED HAZARDOUS MATERIAL CONTRACTOR. COORDINATE ALL WORK WITH HAZARDOUS MATERIAL DOCUMENTS.

KEYED REMOVAL NOTES


- 1V REMOVE EXISTING VINYL TILE FINISH FLOORING & CONCEALED FLOORING MATERIALS COMPLETE, INCLUDING BUT NOT LIMITED TO ADHESIVES, AS REQUIRED FOR INSTALLATION OF NEW UNIT VENT.
- 2 REMOVE WALL CONST. AS REQUIRED FOR INSTALLATION OF NEW UNIT VENT AND LOUVER. SEE MECHANICAL DRAWINGS.
- 3 REMOVE EXISTING CEILING SYSTEM COMPLETE, INCLUDING SUSPENSION WIRES, ANCHORS, CLIPS, FASTENERS, CHANNELS, ETC. (V.I.F.) SALVAGE EXISTING CEILING TILES, LIGHT FIXTURES, SMOKE DETECTORS, SECURITY CAMERAS, AND SPEAKERS.
- 4 REMOVE AND SALVAGE EXISTING WINDOW SASH AS REQUIRED FOR INSTALLATION OF NEW UNIT VENT. SEE MECHANICAL DRAWINGS.
- 5 REMOVE AIR CONDITIONER WINDOW UNIT AND PANEL. RETURN TO OWNER

GENERAL PLAN NOTES

- G1. ALL DIMENSIONS ARE TO FINISH FACE AT EXISTING CONST. AND UNIT MASONRY CONSTRUCTION AND TO FACE OF FRAMING AT DRYWALL CONSTRUCTION UNLESS OTHERWISE NOTED.
- G2. ± NOTATIONS ARE USED IN DIMENSION STRINGS TO ACCOUNT FOR VARIATIONS BETWEEN DRAWINGS AND FIELD CONDITIONS. CONTRACTOR SHALL VERIFY ALL ± DIMENSION DURING LAYOUT AND INFORM ARCHITECT OF ANY DISCREPANCIES OR NECESSARY MODIFICATIONS PRIOR TO PROCEEDING WITH CONSTRUCTION.
- G3. CLEAN PATCH & REPAIR EXISTING WALLS AS REQ'D TO RESTORE TO LIKE NEW CONDITION. FINISH SURFACES TO BE SMOOTH AND FLUSH WITH ADJACENT SURFACES AND READY TO RECEIVE PAINT.

KEYED PLAN NOTES

- 1 INSTALL NEW FLOORING TO MATCH EXIST WHERE DAMAGED DURING REMOVAL / INSTALLATION.
- 2 PATCH & REPAIR EXTERIOR WALL CONST. AS REQUIRED FOR NEW UNIT VENT INSTALLATION.
- 3 INSTALL NEW 2'X2' SUSPENDED ACOUSTICAL CEILING SYSTEM IN EXISTING LOCATION USING SALVAGED CEILING TILES.
- 4 PAINT ENTIRE WALL BELOW WINDOW UNITS TO MATCH EXISTING ROOM COLOR AND FINISH.




DRAWN BY: TG  
ISSUE: 02/01/2021  
REV:



DESCRIPTION  
Main Level Floor Plan

O-A.101.00





4 Oakeside Elementary - Typical Jamb Detail at Unit Vent  
O-A.500 SCALE: 1 1/2" = 1'-0"




PHOTO 1



PHOTO 3




PHOTO 2




PHOTO 4

3 Oakeside Elementary - Reference Photos  
O-A.500 SCALE: NTS




2 Oakeside Elementary - Typical Wall Detail at Unit Vent  
O-A.500 SCALE: 1 1/2" = 1'-0"



1 Oakeside Elementary - Typical Wall Detail at Unit Vent  
O-A.500 SCALE: 1 1/2" = 1'-0"


#### LINTEL NOTES

- COORDINATE WALL OPENINGS WITH ELECTRICAL, MECHANICAL, AND PLUMBING DRAWINGS.
- FOR OPENINGS NOT OTHERWISE DETAILED OR SCHEDULED, INCLUDING MECHANICAL OPENINGS, MINIMUM LINTELS SHALL BE (FOR EACH 4 INCHES OF MASONRY WIDTH) ONE L3 1/2x3 1/2x5/16 FOR SPANS UP TO 4 FEET; ONE L4x3 1/2x5/16 (LLV) FOR SPANS UP TO 6 FEET; ONE L5x3 1/2x5/16 (LLV) FOR SPANS UP TO 9 FEET. FOR SPANS LESS THAN 2 FEET, PROVIDE A 5/16 INCH PLATE.  
  
FOR 8-INCH MASONRY WALLS, USE TWO L3 1/2x3 1/2x5/16 (LLV) FOR SPANS UP TO 4 FEET AND A BUILT-UP PLATE SECTION FOR SPANS UP TO 9 FEET. BUILT-UP SECTION SHALL CONSIST OF A HORIZONTAL PLATE 5/16 INCH BY 7 INCHES AND A VERTICAL PLATE 1/2 INCH BY 5 INCHES WELDED TOGETHER WITH 3/16-INCH FILLET WELDS, 3 INCHES LONG AND 6 INCHES ON CENTER ON EACH SIDE OF THE VERTICAL PLATE, TO FORM AN INVERTED TEE.
- FOR OPENINGS NOT OTHERWISE DETAILED OR SCHEDULED IN 4-INCH-THICK VENEER, INCLUDING MECHANICAL OPENINGS, MINIMUM LINTELS SHALL BE ONE L4x4x5/16 FOR SPANS UP TO 6 FEET AND ONE L6x4x5/16 (LLV) FOR SPANS UP TO 9 FEET. FOR SPANS LESS THAN 2 FEET, PROVIDE A 5/16-INCH PLATE.
- WELD TOGETHER BACK-TO-BACK LINTELS. MAXIMUM WELD SPACING SHALL NOT EXCEED 18 INCHES ON CENTER.
- BEAR LINTELS A MINIMUM OF 8 INCHES EACH END UNLESS NOTED OTHERWISE.
- HOT-DIP GALVANIZE LINTELS IN EXTERIOR WALLS.




Architect:  
**Hamlin Design Group**  
915 Broadway, Suite 101A  
Albany, New York 12207  
Tel: 518.724.5159  
Fax: 518.320.8633  
Web: hamlindesigngroup.com

Hazardous Material Consultant:



MEP Engineer:



Client:



**Peekskill City School District**  
1031 Elm St.  
Peekskill, NY 10566

#### Peekskill Reconstruction

SED Project: 66-15-00-01-0-005-020  
HDG Project: 201

**Oakside Elementary**  
200 Decatur Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-007-014  
HDG Project: 202

**Uriah Hill School**  
980 Pemart Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-008-017  
HDG Project: 203

**Woodside Elementary**  
612 Depew St.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-014-005  
HDG Project: 204

**Middle School**  
212 Ringgold St.,  
Peekskill, NY 10566

DRAWN BY:  
TG

ISSUE: 02/01/2021  
REV:



DESCRIPTION  
Details

O-A.500.00




GENERAL REMOVAL NOTES

1. THE CONTRACTOR SHALL BE SOLELY RESPONSIBLE FOR ALL MEANS, METHODS, TECHNIQUES, SEQUENCES AND PROCEDURES, AND FOR COORDINATING THE COMPLETION OF ALL PORTIONS OF THE SCOPE OF WORK WITHIN THE SPECIFIED CONSTRUCTION SCHEDULE AND AS DEFINED IN THE CONTRACT DOCUMENTS.
2. ALL ASBESTOS ABATEMENT SHALL BE PERFORMED IN ACCORDANCE WITH ALL FEDERAL, STATE, LOCAL REGULATIONS, AND THE TERMS OF THE CONTRACT. ALL ABATEMENT ACTIVITY WITHIN THE BUILDING SHALL BE PERFORMED INSIDE A CONTAINED WORK AREA THAT MEETS THE REQUIREMENTS OF OSHA 1926.1101, THE ASBESTOS HAZARD EMERGENCY RESPONSE ACT AND NEW YORK STATE DEPARTMENT OF LABOR CODE RULE 56.
3. ALL ABATEMENT ACTIVITY ON THE EXTERIOR OF THE BUILDING SHALL BE PERFORMED WITHIN THE REQUIREMENTS OF OSHA 1926.1101, THE ASBESTOS HAZARD EMERGENCY RESPONSE ACT AND NEW YORK STATE DEPARTMENT OF LABOR CODE RULE 56. ALL EXTERIOR ABATEMENT ACTIVITY THAT DISTURBS FRIABLE ASBESTOS MATERIALS OR RESULTS IN NON-FRIABLE ASBESTOS MATERIALS BEING MADE FRIABLE SHALL BE PERFORMED UNDER NEGATIVE PRESSURE WITHIN AN ISOLATED WORK AREA.
4. THE HAZARDOUS MATERIALS DRAWINGS ASSOCIATED WITH THIS PROJECT WERE PRODUCED FROM AVAILABLE FLOOR PLANS. ACCORDINGLY, VARIATIONS WITHIN THE DEMARCATED WORK AREAS ARE EXPECTED AND SHALL HAVE NO IMPACT ON THE CONTRACT PRICE OR SCHEDULE.
5. THE HAZARDOUS MATERIALS DRAWINGS DO NOT SHOW EXISTING MECHANICAL, ELECTRICAL, PLUMBING, COMMUNICATION, SECURITY SYSTEMS OR CASEWORK PRESENT WITHIN OR IN THE PROXIMITY OF THE BUILDING. REFER TO THE ARCHITECTURAL, PLUMBING, MECHANICAL AND ELECTRICAL REMOVAL AND NEW WORK DRAWINGS FOR COORDINATION. ALL LOW VOLTAGE WIRING, INCLUDING BUT NOT LIMITED TO, SPEAKER WIRING, ALARM SYSTEM WIRING, TELEPHONE, DATA AND/OR TELEVISION CABLES SHALL BE PROTECTED IN PLACE DURING ASBESTOS ABATEMENT ACTIVITIES. MATERIALS SPECIFIED FOR REMOVAL ARE QUANTIFIED IN THE MATERIALS SCHEDULE IN DOCUMENT 028213.
6. PLACEMENT OF PERSONAL AND WASTE DECONTAMINATION UNITS WILL BE COORDINATED WITH AND APPROVED BY THE OWNER'S REPRESENTATIVE.
7. ASBESTOS CONTAINING MATERIALS (ACM) HAVE BEEN IDENTIFIED IN THE AREAS INDICATED ON THIS DRAWING AND INCLUDE JOINT COMPOUND AND EXTERIOR WINDOW/LOUVER CAULK. ASBESTOS ABATEMENT WORK SHALL BE PERFORMED AS SPECIFIED IN SECTION 028213.
8. THE CONTRACTOR IS RESPONSIBLE FOR THE REMOVAL OF EXISTING NON-ASBESTOS MATERIALS INCLUDING, BUT NOT LIMITED TO, DRYWALL OR OTHER WALL CONSTRUCTION AS REQUIRED TO REMOVE AND INSTALL COMPONENTS WITHIN THE SCHEDULED REGULATED WORK AREAS. THE CONTRACTOR SHALL VERIFY FIELD CONDITIONS, MEASUREMENTS AND QUANTITIES. REPORT ANY DISCREPANCIES TO THE CONSTRUCTION MANAGER IN WRITING.
9. PCB'S HAVE BEEN IDENTIFIED IN SOME EXTERIOR WINDOW/LOUVER CAULK LOCATED AT OAKSIDE ELEMENTARY SCHOOL. PCB ABATEMENT WORK SHALL BE PERFORMED AS SPECIFIED IN SECTION 028433.
10. THE CONTRACTOR IS RESPONSIBLE FOR CONFIRMING THE LOCATIONS, TIMING AND EXTENTS OF REMOVALS AND INSTALLATIONS WITH THE APPROPRIATE CONTRACTOR.
11. THE ASBESTOS ABATEMENT CONTRACTOR IS RESPONSIBLE FOR THE REMOVAL AND LEGAL DISPOSAL OF ASBESTOS-CONTAINING AND ASBESTOS-CONTAMINATED MATERIALS AND PCB CAULK AS INDICATED IN THE PROJECT SPECIFICATIONS AND DRAWINGS.
12. THE ASBESTOS ABATEMENT CONTRACTOR IS RESPONSIBLE FOR THE REMOVAL OF ALL WALL MOUNTED ITEMS FROM DRYWALL WITH ASBESTOS CONTAINING JOINT COMPOUND INCLUDING BUT NOT LIMITED TO CLASSROOM UNIT VENTILATORS, MOLDINGS, TRIM, THERMOSTATS, WIRING, AND BACKER PLATES. ALL PATCHING OF DRYWALL SHALL BE PERFORMED BY THE ASBESTOS ABATEMENT CONTRACTOR. INSTALL NEW UNIT VENTILATOR WALL ANCHORS, BACKER PLATES FOR TEMPERATURE SENSORS OR OTHER COMPONENTS IDENTIFIED FOR INSTALLATION ON OR IN DRYWALL AS SHOWN ON THE ARCHITECTURAL AND MECHANICAL DRAWINGS.
13. THE ASBESTOS ABATEMENT CONTRACTOR IS TO NOTIFY THE ARCHITECT IN WRITING OF ANY DISCREPANCIES BETWEEN THE CONTRACT DOCUMENTS AND FIELD CONDITIONS PRIOR TO THE START OF WORK.
14. THE ASBESTOS ABATEMENT CONTRACTOR IS RESPONSIBLE FOR REVIEWING AND UNDERSTANDING THE ASSUMPTIONS AND LIMITATIONS INCLUDED IN THE ENVIRONMENTAL SERVICES REPORT INCLUDED IN THE SPECIFICATION.

KEYED REMOVAL NOTES

- 1 EXISTING UNIT VENTILATOR TO BE REMOVED AND REPLACED. THE EXISTING DRYWALL JOINT COMPOUND CONTAINS ASBESTOS. THE ABATEMENT CONTRACTOR SHALL REMOVE ALL ATTACHMENTS TO THE DRYWALL INCLUDING BUT NOT LIMITED TO UNIT VENTILATOR ANCHORS, MOLDINGS, TRIM PIECES AND PATCH THE WALL. ABATEMENT CONTRACTOR SHALL INSTALL ALL NEW ATTACHMENTS TO DRYWALL. COORDINATE WITH THE MECHANICAL CONTRACTOR.
- 2 EXISTING THERMOSTAT AND WIRING TO BE REMOVED AND REPLACED. THE EXISTING DRYWALL JOINT COMPOUND CONTAINS ASBESTOS. THE ABATEMENT CONTRACTOR SHALL REMOVE THE THERMOSTAT AND BACKER PLATE AND PATCH THE WALL. ABATEMENT CONTRACTOR SHALL INSTALL NEW BACKER PLATE AND PROVIDE ANY NECESSARY PENETRATIONS IN THE DRYWALL. COORDINATE WITH THE MECHANICAL CONTRACTOR.
- 3 THE EXISTING WINDOW/LOUVER CAULK CONTAINS ASBESTOS. THE CAULK FOR ROOMS 213, 215, AND 216 AT OAKSIDE ELEMENTARY ALSO CONTAINS PCB'S. WHERE THE LOUVERS ARE SHOWN TO BE REMOVED AND REPLACED ON THE MECHANICAL DRAWINGS, THE ABATEMENT CONTRACTOR SHALL REMOVE ALL CAULK AND CLEAN AND DISPOSE OF THE LOUVERS IN ACCORDANCE WITH SPECIFICATION SECTIONS 028213 AND 028433.



Oakside Elementary - Existing Main Level Plan

SCALE: 1/16" = 1'-0"




Architect:  
**Hamlin Design Group**  
915 Broadway, Suite 101A  
Albany, New York 12207  
Tel: 518.724.5159  
Fax: 518.320.8633  
Web: hamlindesigngroup.com

Hazardous Material Consultant:



MEP Engineer:



Client:



**Peekskill City School District**  
1031 Elm St.  
Peekskill, NY 10566

Peekskill Reconstruction

SED Project: 66-15-00-01-0-005-020

HDG Project: 201

**Oakside Elementary**

1072 Elm St.,

Peekskill, NY 10566

SED Project: 66-15-00-01-0-007-014

HDG Project: 202

**Uriah Hill School**

980 Pernart Ave.,

Peekskill, NY 10566

SED Project: 66-15-00-01-0-008-017

HDG Project: 203

**Woodside Elementary**

612 Depew St.,

Peekskill, NY 10566

SED Project: 66-15-00-01-0-014-005

HDG Project: 204

**Middle School**


212 Ringgold St.,

Peekskill, NY 10566

DRAWN BY:

KJ

ISSUE: 12/20/201



DESCRIPTION

Existing Main Level Hazardous Materials Plan

O-H.100.00



PANELBOARD SCHEDULE - LP-3

LOCATION - SWITCHGEAR ROOM			SOURCE - MDP				MOUNTING - SURFACE				SERATED <input type="checkbox"/>		FEED-THRU LUGS <input type="checkbox"/>		
RATING (AMPS) - 400A MCB			VOLTAGE - 208Y/120V				PHASE/WIRE - 3-PHASE/4-WIRE				HINGED TRIM <input type="checkbox"/>		SUB FEED LUGS <input type="checkbox"/>		
KAIC - 65			DESIGN MAKE (SQUARE D) - NQ				NEMA RATING - 1				COMPUTER GRADE <input type="checkbox"/>		SUB-FEED BREAKER <input type="checkbox"/>		
											200% NEUTRAL <input type="checkbox"/>		ISOLATED GND BUS <input type="checkbox"/>		
KVA LOAD															
CKT	DESCRIPTION		BREAKER	LTG	RCPT	MOTOR	HTG	HTG	MOTOR	RCPT	LTG	BREAKER	DESCRIPTION		CKT
1															2
3	UV-201		40A/3P			8.7			8.7			40A/3P	UV-202		4
5															6
7															8
9	UV-203		40A/3P			8.7			8.7			40A/3P	UV-204		10
11															12
13															14
15	UV-208		40A/3P			8.7			8.7			40A/3P	UV-209		16
17															18
19															20
21	UV-210		40A/3P			8.7			8.7			40A/3P	UV-211		22
23															24
25															26
27	UV-212		40A/3P			8.7			8.7			40A/3P	UV-213		28
29															30
31															32
33	UV-216		40A/3P			8.7			8.7			40A/3P	UV-304		34
35															36
37	EXISTING 1		20A/1P									20A/1P	EXISTING 1		38
39	EXISTING 1		20A/1P									20A/1P	EXISTING 1		40
41	EXISTING 1		20A/1P									20A/1P	EXISTING 1		42
43	EXISTING 1		20A/1P									20A/1P	EXISTING 1		44
45	EXISTING 1		20A/1P									20A/1P	EXISTING 1		46
47	EXISTING 1		20A/1P									20A/1P	EXISTING 1		48
49	SPARE		20A/1P									20A/1P	SPARE		50
51	SPARE		20A/1P									20A/1P	SPARE		52
53	SPARE		20A/1P									20A/1P	SPARE		54
LEFT SIDE SUB-TOTAL				-	-	51	-	-	52	-	-	RIGHT SIDE SUB-TOTAL			
CONNECTED SUB-TOTAL				-	-	103	-	-	-	-	-				
DEMAND FACTOR				1.0	10+1/2	.8	.8								
SUB-TOTAL				-	-	82	-								
TOTAL KVA				82											
TOTAL AMPS				227											

NOTES:


1 PROVIDE EXTENSION OF EXISTING BRANCH CIRCUITS FROM PANELBOARD EM

NOTES:

1 PROVIDE EXTENSION OF EXISTING BRANCH CIRCUITS FROM PANELBOARD EM.

NOTES

- A. PANELBOARDS SUPPLIED BY A FEEDER SHALL BE MARKED TO INDICATE WHERE THE POWER SUPPLY ORIGINATES PER NEC SECTION 408.4(B).
- B. PROVIDE FLASH PROTECTION LABEL PER NEC SECTION 110.16.
- C. REFER TO ELECTRICAL IDENTIFICATION SECTION 260195 FOR ADDITIONAL INFORMATION.
- D. PROVIDE IDENTIFICATION FOR ALL PANELBOARD INSTALLATIONS.



1

Panelboard Identification Detail

O-E.001.00

SCALE: NTS

GENERAL NOTES - REMOVALS

- A. THIS INFORMATION REPRESENTS EXISTING CONDITIONS BASED ON ORIGINAL DRAWINGS AND OBSERVED SITE CONDITIONS. NOT ALL CONDUIT, WIRE, FIXTURES AND DEVICES ARE SHOWN. FIELD VERIFY THE EXACT REQUIREMENTS IN ALL REMOVAL AREAS. DISCONNECT AND REMOVE ALL ELECTRICAL WORK THAT IS SHOWN DASHED ON REMOVAL PLANS AND ALL ELECTRIC WORK IN RENOVATION AREAS THAT IS NOT BEING REUSED. REMOVE ALL BRANCH CIRCUITING, LOW VOLTAGE CABLING, SUPPORTING DEVICES, RACEWAY, AND ASSOCIATED TERMINATION HARDWARE.
- B. "ERL" ADJACENT TO A DEVICE, FIXTURE OR PIECE OF EQUIPMENT INDICATES AN EXISTING ITEM TO BE RELOCATED. DISCONNECT AND REMOVE THE ITEM. REMOVE ALL UNNECESSARY RACEWAY AND WIRING. REINSTALL AND RECONNECT THE ITEM AS REQUIRED.
- C. "EXP" ADJACENT TO A DEVICE FIXTURE OR PIECE OF EQUIPMENT INDICATES AN EXISTING ITEM TO REMAIN. MAINTAIN EXISTING CONNECTIONS TO EQUIPMENT UNLESS NOTED OTHERWISE.
- D. PROVIDE FIRE STOPPING CUTTING, PATCHING AND PAINTING AS REQUIRED TO REPAIR HOLES OR OTHER PHYSICAL DEFECTS CAUSED BY THE REMOVAL OR INSTALLATION OF EQUIPMENT AND DEVICES. THE CONTRACTOR SHALL PROVIDE A QUALIFIED TRADES PERSON TO RESTORE FINISHED WALLS TO ORIGINAL CONDITIONS AND PAINT TO MATCH EXISTING COLORS.
- E. PROVIDE STAINLESS STEEL BLANK COVER PLATES ON ALL UNUSED ELECTRICAL BOXES AFTER DEMOLITION AND INSTALLATION WORK IS COMPLETE.
- F. WHERE EXISTING DEVICES ARE BEING REMOVED AND THE REMOVAL BREAKS AN EXISTING BRANCH CIRCUIT TO DOWNSTREAM DEVICE THE CONTRACTOR SHALL PROVIDE ALL WIRING TO PERMANENTLY RECONNECT THE REMAINING DEVICE EQUIPMENT OR FIXTURE.
- G. THE CONSTRUCTION MANAGER OR GENERAL CONTRACTOR WILL SCHEDULE ALL REMOVAL WORK. PRIOR TO BEGINNING REMOVAL WORK PROVIDE AN EXISTING CONDITION REPORT WITH PICTURES AND SUBMIT TO THE CONSTRUCTION MANAGER. ANY DAMAGES OR EXISTING CONDITIONS THAT ARE NOT DOCUMENTED WILL BE CORRECTED BY THE CONTRACTOR PRIOR TO FINAL COMPLETION.
- H. LEGALLY DISPOSE OF ALL ELECTRICAL WIRING, DEVICES, BALLAST, LAMPS ETC. FOLLOW ALL LOCAL, STATE AND FEDERAL REGULATIONS REGARDING DISPOSAL OF HAZARDOUS WASTE.

GENERAL NOTES - INSTALLATION

- A. COORDINATE DEVICE LOCATIONS WITH ARCHITECTURAL ELEVATIONS PRIOR TO ROUGH-IN. VERIFY DEVICE LOCATIONS ABOVE MILLWORK TO ENSURE CLEARANCE ABOVE THE COUNTER-TOP AND BACKSPLASH. DEVICES THAT INTERFERE WITH NEW CASEWORK, MILLWORK OR EQUIPMENT SHALL BE RELOCATED AT NO ADDITIONAL COST TO THE CONTRACT.
- B. WHERE DEVICES ARE SCHEDULED TO BE INSTALLED IN CASEWORK AND MILLWORK SUPPLIED BY THE GENERAL CONTRACTOR, OBTAIN A SHOP DRAWING FROM THE GENERAL CONTRACTOR PRIOR TO ROUGHING. WHERE REQUIRED, CUT OPENINGS IN MILLWORK OR COORDINATE OPENINGS WITH THE GENERAL CONTRACTOR.
- C. COORDINATE ALL CONDUIT RUNS WITH OTHER TRADES PRIOR TO ROUGH-IN. RELOCATE ANY CONDUITS AS NECESSARY TO PERMIT INSTALLATION OF DUCTWORK OR PIPING.
- D. INSTALL ALL CIRCUITING CONCEALED INSIDE WALL CAVITY WHERE EVER POSSIBLE. PROVIDE SURFACE MOUNTED BACKBOXES AND RACEWAY FOR WIRING DEVICES LOCATED ON EXISTING SOLID WALL CONSTRUCTION. PROVIDE SHALLOW TYPE BACKBOXES FOR SURFACE MOUNTED POWER AND SWITCHING APPLICATIONS. REFER TO ARCHITECTURAL PLANS FOR WALL TYPES.
- E. FIRESTOP ALL LOW VOLTAGE SLEEVES AND PENETRATIONS AFTER INSTALLATION OF CABLE.
- F. PROVIDE OPEN TOP CABLE HANGERS 4" ON CENTER SUPPORTED TO SUPPORT ALL LOW VOLTAGE CABLING ABOVE ACCESSIBLE CEILINGS. PROVIDE SEPARATE CABLE HANGERS FOR BACKBONE CABLING, HORIZONTAL CABLING, PUBLIC ADDRESS & SECURITY CABLING, AND FIRE ALARM CABLING. INSTALL ALL EXPOSED CABLES IN EMT CONDUIT OR SURFACE RACEWAY IN FINISHED AREAS.
- G. ALL LOW VOLTAGE CABLING SHALL BE PLENUM RATED.
- H. OBTAIN WIRING AND INSTALLATION DIAGRAMS FOR ALL ELECTRICAL CONNECTIONS TO EQUIPMENT PROVIDED BY THE GENERAL, MECHANICAL OR PLUMBING CONTRACTORS PRIOR TO ROUGHING. WORK THAT IS NOT PROPERLY COORDINATED WILL BE RELOCATED AT NO COST TO THE OWNER.
- I. PROVIDE HORIZONTAL AND VERTICAL RACEWAY AS REQUIRED TO TRANSITION FROM UNIT VENTILATORS TO ACCESSIBLE CEILINGS. CONTRACTOR IS TO ASSUME VERTICAL RISE IS IN THE FURTHEST CORNER AWAY FROM EQUIPMENT CONNECTION POINT AS INDICATED IN PLANS. REFER TO PLANS FOR CEILING TYPES.

GENERAL NOTES - POWER DISTRIBUTION

- A. PROVIDE (2)-#10, (1)-#10 EG WIRING FOR 120V, 20A BRANCH CIRCUITS EXCEEDING 100 FEET.
- B. THE DRAWINGS SHOW GENERAL LOCATION OF DEVICES AND CONTROL EQUIPMENT. THE CONTRACTOR SHALL INSTALL ALL DEVICES AND CONTROLS TO MEET ALL NEC REQUIREMENTS. COORDINATE THE EXACT LOCATION IN THE FIELD.
- C. THE ELECTRICAL CONTRACTOR SHALL COORDINATE ALL ELECTRICAL CONNECTIONS TO ELECTRICAL EQUIPMENT PROVIDED BY OTHERS PRIOR TO ROUGH-IN.
- D. PROVIDE DEDICATED NEUTRALS FOR ALL 120V, 20A, SINGLE PHASE BRANCH CIRCUITS.
- E. DO NOT INSTALL NORMAL AND EMERGENCY POWER IN THE SAME RACEWAY, JUNCTION BOX, OR OUTLET BOX. PROVIDE SEPARATE OR SEGREGATED RACEWAY SYSTEMS.
- F. WHERE BREAKERS ARE INSTALLED IN EXISTING PANELBOARDS, THE BREAKERS SHALL BE LISTED/LABELED FOR USE IN THE EXISTING PANEL AND THE KAIC RATING SHALL MATCH THE KAIC RATING OF THE EXISTING PANEL.

POWER

JUNCTION BOX
MOTOR CONNECTION NUMBER INDICATES ITEM REFER TO ELECTRIC EQUIPMENT AND CONTROL SCHEDULE
FUSED DISCONNECT
EXISTING SURFACE MOUNTED 208Y/120V BRANCH CIRCUIT PANELBOARD
SURFACE MOUNTED 208Y/120V BRANCH CIRCUIT PANELBOARD
PNL INDICATES HOMERUN TO PANEL CKT# PANEL NAME AND CKT NUMBERS INDICATED PROVIDE (2) #12 AWG, (1) #12 AWG EGC IN 3/4" UNLESS OTHERWISE NOTED

GENERAL

REMOVAL NOTE
INSTALLATION NOTE
OFFSET FOR CLARITY

MOUNTING HEIGHTS

UNLESS OTHERWISE NOTED, MOUNT DEVICES AND EQUIPMENT AT HEIGHTS MEASURED FROM FINISHED FLOOR TO DEVICE/ EQUIPMENT CENTERLINE AS LISTED BELOW.	
COORDINATE DEVICE LOCATIONS WITH ARCHITECTURAL ELEVATIONS PRIOR TO ROUGH-IN. WHERE STRUCTURAL OR OTHER INTERFERENCE'S PREVENT COMPLIANCE WITH MOUNTING HEIGHTS LISTED BELOW, CONSULT OWNER'S REPRESENTATIVE FOR APPROVAL TO CHANGE LOCATION BEFORE INSTALLATION.	
TOGGLE SWITCHES	46"
RECEPTACLE OUTLETS	18"
RECEPTACLE OUTLETS ABOVE HOT WATER OR STEAM BASEBOARD HEATERS	30"
RECEPTACLE OUTLETS, HAZARDOUS LOCATIONS	48"
RECEPTACLE OUTLETS, WEATHER PROOF, ABOVE GRADE	24"
CLOCKS, CLOCK	90"
BRANCH CIRCUIT PANELBOARDS, TO THE TOP OF THE BACKBOX	72"
DISCONNECT SWITCHES, MOTOR STARTERS, ENCLOSED CIRCUIT BREAKERS	48"

ABBREVIATIONS

A	AMPERE
AC	ABOVE COUNTER
AF	ABOVE FINISHED FLOOR
AFG	ABOVE FINISHED GRADE
AFCI	ARC FAULT CIRCUIT INTERRUPTER
AIC	AMPERES INTERRUPTING CAPACITY
AL	ALUMINUM
ASYM	ASYMMETRICAL
ATS	AUTOMATIC TRANSFER SWITCH
AUX	AUXILIARY CONTACTS
AWG	AMERICAN WIRE GAUGE
BD	BUS DUCT
BR	BRANCH
C	CONDUIT
CB	CIRCUIT BREAKER
CD	CANDELA
CH	CABINET HEATER
CKT	CIRCUIT
CT	CURRENT TRANSFORMER
CU	COPPER
CATV	CABLE TELEVISION
CCTV	CLOSED CIRCUIT TELEVISION
CLG	CEILING
CONT	CONTACTOR
CP	CONTROL PANEL
DC	DIRECT CURRENT
Δ	DELTA CONNECTED
DISC	DISCONNECT
DP	DRINKING FOUNTAIN
DPST	DOUBLE POLE, SINGLE THROW
DPDT	DOUBLE POLE, DOUBLE THROW
EBB	ELECTRIC BASEBOARD
EC	ELECTRICAL CONTRACTOR
EG	EQUIPMENT GROUND
EGC	EQUIPMENT GROUND CONDUCTOR
EM	EMERGENCY
EP	EXPLOSION PROOF
EPR	ETHYLENE PROPYLENE RUBBER
EQUIP	EQUIPMENT
EXR	EXISTING TO REMAIN
ERL	EXISTING TO BE RELOCATED
EXIST	EXISTING
(E)	EXISTING
EXP	EXPLOSION PROOF
ELECT	ELECTRIC
EMT	ELECTRIC METALLIC TUBING
FA	FIRE ALARM
FACP	FIRE ALARM CONTROL PANEL
FARAP	FIRE ALARM REMOTE ANNUNCIATOR PANEL
FBO	FURNISHED BY OWNER
FC	FOOTCANDLE
FCAN	FULL CAPACITY ABOVE NORMAL
FCBN	FULL CAPACITY BELOW NORMAL
FLA	FULL LOAD AMPERES
FLUOR	FLUOR
FVNR	FULL VOLTAGE, NON-REVERSING
FVR	FULL VOLTAGE, REVERSING
G	GUARD
GC	GENERAL CONTRACTOR
GEN	GENERATOR
GF	GROUND FAULT
GFI	GROUND FAULT CIRCUIT INTERRUPTER
GND	GROUND
GRS	GALVANIZED RIGID STEEL
H	HOSPITAL GRADE
HOA	HAND-OFF-AUTOMATIC
HPS	HIGH PRESSURE SODIUM
HV	HIGH VOLTAGE
HZ	HERTZ
IC	INTERCOM
IG	ISOLATED GROUND
INCAD	INCANDESCENT
IMC	INTERMEDIATE METAL CONDUIT
JB	JUNCTION BOX
KAIC	THOUSAND AMPERE INTERRUPTING CAPACITY
KV	KILOVOLT
KVA	KILOVOLT-AMPERE
KW	KILOWATT
K	KILO (THOUSAND)
KCM	THOUSAND CIRCULAR MILS
KCML	THOUSAND CIRCULAR MILS
LTG	LIGHTING
LSIG	LONG TIME-SHORT TIME-INSTANTANEOUS-GROUND FAULT
LV	LOW VOLTAGE
M	MEGA ( MILLION)
MATV	MASTER ANTENNA TELEVISION
MFS	MAIN FUSED SWITCH
MC	MECHANICAL CONTRACTOR
MCB	MAIN CIRCUIT BREAKER
MCC	MOTOR CONTROL CENTER
MH	METAL HALIDE
MLO	MAIN LUGS ONLY
MM	MULTIMODE FIBER
MM	MEDIUM VOLTAGE
MVA	MEGAVOLT-TAMPERE
NEC	NATIONAL ELECTRICAL CODE
NC	NORMALLY CLOSED
NO	NORMALLY OPEN
NL	NIGHT LIGHT
N	NEUTRAL
NF	NONFUSED
NIC	NOT IN CONTRACT
NTS	NOT TO SCALE
OCPO	OVER CURRENT PROTECTION DEVICE
OH	OVERHEAD
OL	OVERLOAD
PB	PULLBOX
PC	PLUMBING CONTRACTOR
PF	POWER FACTOR
PHL	PANEL
PT	POTENTIAL TRANSFORMER
PVC	POLYVINYL CHLORIDE
Ø	PHASE
PH	PHASE
P	POLE
PL	PILOT LIGHT
PM	PLUGMOLD
PP	POWER PANEL
PWR	POWER
RVNR	REDUCED VOLTAGE, NON-REVERSING
RM	ROOM
RMS	ROOT MEAN SQUARED
RTU	ROOF TOP UNIT
SM	SINGLE MODE FIBER
SS	SURGE SUPPRESSION
ST	SOLID-STATE TRIP DEVICE
ST	SHUNT-TRIP
SW	SWITCH
SWBD	SWITCHBOARD
SYM	SYMMETRICAL
T	TAMPER RESISTANT
TDR	TIME DELAY RELAY
TYP	TYPICAL
TCP	TEMPERATURE CONTROL PANEL
TSTAT	THERMOSTAT
TV	TELEVISION
UG	UNDERGROUND
UH	UNIT HEATER
USB	UNIVERSAL SERIAL BUS
V	VOLT
VR	VOLT-AMPERE
VP	VAPORPROOF
W	WATT
WG	WIRE GUARD
WM	WREMOLD
WP	WEATHERPROOF
XFMR	TRANSFORMER
XLP	CROSS LINKED POLYETHYLENE
EXP	EXPLOSION PROOF
Y	WYE CONNECTED

Architect:

Hamlin Design Group

915 Broadway, Suite 101A

Albany, New York 12207

Tel: 518.724.5159


Fax: 518.320.8633

Web: hamlindesigngroup.com

Hazardous Material Consultant:



MEP Engineer:



Client:



Peekskill City School District

1031 Elm St.

Peekskill, NY 10566

Peekskill Reconstruction

SED Project: 66-15-00-01-0-005-020

HDG Project: 201

Oakside Elementary

200 Decatur Ave.,

Peekskill, NY 10566

SED Project: 66-15-00-01-0-007-014

HDG Project: 202

Uriah Hill School

980 Pemart Ave.,

Peekskill, NY 10566

SED Project: 66-15-00-01-0-008-017

HDG Project: 203

Woodside Elementary

612 Depew St.,

Peekskill, NY 10566

SED Project: 66-15-00-01-0-014-005

HDG Project: 204

Middle School

212 Ringgold St.,

Peekskill, NY 10566

DRAWN BY:

SDK

ISSUE: 02/01/2021

REV:




DESCRIPTION

Legend, General Notes, Schedules and Details


O-E.001.00






REMOVAL NOTES: ○

1. DISCONNECT & REMOVE FUSED DISCONNECT, PANELBOARD, WIREWAY AND FEEDER IN THEIR ENTIRETY. MAINTAIN (12)-20A, 1-POLE BRANCH CIRCUITS FOR RECONNECTION TO REPLACEMENT PANELBOARD.
2. REMOVE & REINSTALL GROUNDING ELECTRODE CONDUCTOR AS REQUIRED TO ACCOMMODATE WATER SERVICE REPLACEMENT.




Architect:  
**Hamlin Design Group**  
915 Broadway, Suite 101A  
Albany, New York 12207  
Tel: 518.724.5159  
Fax: 518.320.8633  
Web: hamlindesigngroup.com

Hazardous Material Consultant:



MEP Engineer:



Client:



**Peekskill City School District**  
1031 Elm St.  
Peekskill, NY 10566

**Peekskill Reconstruction**

SED Project: 66-15-00-01-0-005-020  
HDG Project: 201

**Oakside Elementary**

200 Decatur Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-007-014  
HDG Project: 202

**Uriah Hill School**

980 Pemart Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-008-017  
HDG Project: 203

**Woodside Elementary**

612 Depew St.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-014-005  
HDG Project: 204

**Middle School**

212 Ringgold St.,  
Peekskill, NY 10566

DRAWN BY:

SDK


ISSUE: 02/01/2021

REV:




DESCRIPTION  
Lower Level Removal Plan

O-E.201.00




**1** Oakside School - Lower Level Removal Plan  
O-E.201.00 SCALE: 1/16" = 1'-0"




KEY PLAN






REMOVAL NOTES:


1. DISCONNECT & REMOVE HVAC BRANCH CIRCUIT IN ITS ENTIRETY.



1 Oakside School - Main Level Removal Plan  
Q-E.202.00 SCALE: 1/16" = 1'-0"




KEY PLAN



Architect:  
**Hamlin Design Group**  
915 Broadway, Suite 101A  
Albany, New York 12207  
Tel: 518.724.5159  
Fax: 518.320.8633  
Web: hamlindesigngroup.com

Hazardous Material Consultant:



MEP Engineer:



Client:



**Peekskill City School District**  
1031 Elm St.  
Peekskill, NY 10566

**Peekskill Reconstruction**

SED Project: 66-15-00-01-0-005-020  
HDG Project: 201

**Oakside Elementary**

200 Decatur Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-007-014  
HDG Project: 202

**Uriah Hill School**

980 Pemart Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-008-017  
HDG Project: 203

**Woodside Elementary**

612 Depew St.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-014-005  
HDG Project: 204

**Middle School**

212 Ringgold St.,  
Peekskill, NY 10566

DRAWN BY:  
SDK

ISSUE: 02/01/2021  
REV:




DESCRIPTION

Main Level Removal Plans

O-E.202.00






- DRAWING NOTES:** ⬡
1. PROVIDE (4)-600 KCM, (1)-#2 AWG EGC IN 4" C FOR PANEL BOARD LP-3. PROVIDE BUS TAP AND LUGS IN EXISTING MDP.


CEILING SCHEDULE	
DESIGNATION	DESCRIPTION
⬡	ACCESSIBLE CEILING
⬢	INACCESSIBLE CEILING
⬣	EXPOSED STRUCTURE

Architect:  
**Hamlin Design Group**  
915 Broadway, Suite 101A  
Albany, New York 12207  
Tel: 518.724.5159  
Fax: 518.320.8633  
Web: hamlindesigngroup.com

Hazardous Material Consultant:



MEP Engineer:



Client:



**Peekskill City School District**  
1031 Elm St.  
Peekskill, NY 10566

**Peekskill Reconstruction**

SED Project: 66-15-00-01-0-005-020  
HDG Project: 201

**Oakside Elementary**

200 Decatur Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-007-014  
HDG Project: 202

**Uriah Hill School**

980 Pemart Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-008-017  
HDG Project: 203

**Woodside Elementary**

612 Depew St.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-014-005  
HDG Project: 204

**Middle School**

212 Ringgold St.,  
Peekskill, NY 10566


DRAWN BY:  
SDK

ISSUE: 02/01/2021  
REV:




DESCRIPTION  
Lower Level Power Plan

O-E.401.00




1 Oakside School - Lower Level Power Plan  
O-E.401.00 SCALE: 1/16" = 1'-0"



KEY PLAN






- DRAWING NOTES:** ⬡
1. PROVIDE 120V BRANCH CIRCUIT FOR TEMPERATURE CONTROLS CONTRACTOR (TC). TC TO PROVIDE POWER FROM THIS LOCATION TO THEIR EQUIPMENT, COORDINATE FINAL LOCATION WITH TC.
  2. PROVIDE (1)-20A, 1-POLE BRANCH CIRCUIT BREAKER "CUTLER-HAMMER PRL1A" SERIES.

**CEILING SCHEDULE**

DESIGNATION	DESCRIPTION
⬡	ACCESSIBLE CEILING
⬢	INACCESSIBLE CEILING
⬢	EXPOSED STRUCTURE



1  
O-E.402.00

**Oakeside School - Main Level Power Plan**

SCALE: 1/16" = 1'-0"


KEY PLAN



Architect:


**Hamlin Design Group**  
915 Broadway, Suite 101A  
Albany, New York 12207  
Tel: 518.724.5159  
Fax: 518.320.8633  
Web: hamlindesigngroup.com

Hazardous Material Consultant:



Ambient Environmental, Inc.  
Comprehensive Building Science solutions  
NYS/NAS Certified WBE  
E SEA EDW058 & DBE

MEP Engineer:



**Engineered Solutions**  
648 Plank Road #104  
Clifton Park, NY 12061  
phone: (518) 280-2410  
fax: (518) 280-2481  
www.engineered-solutions.net  
Electrical  
Communications  
Mechanical  
ES # 19071

Client:



**Peekskill City School District**  
1031 Elm St.  
Peekskill, NY 10566

**Peekskill Reconstruction**

SED Project: 66-15-00-01-0-005-020  
HDG Project: 201

**Oakside Elementary**

200 Decatur Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-007-014  
HDG Project: 202

**Uriah Hill School**

980 Pemart Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-008-017  
HDG Project: 203

**Woodside Elementary**

612 Depew St.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-014-005  
HDG Project: 204

**Middle School**

212 Ringgold St.,  
Peekskill, NY 10566

DRAWN BY:  
SDK

ISSUE: 02/01/2021  
REV:



DESCRIPTION  
Main Level Power Plans

**O-E.402.00**




UNIT VENTILATOR SCHEDULE																										
TAG	LOCATION	TYPE	AIRSIDE PERFORMANCE			HYDRONIC PERFORMANCE								COOLING PERFORMANCE										MANUFACTURER & MODEL NO.	NOTES	
			FAN SPEED SETTING	SUPPLY (CFM)	MIN. O.A. (CFM)	CAPACITY (MBH)	E.A.T. (°F)	L.A.T. (°F)	E.W.T. (°F)	L.W.T. (°F)	FLOW RATE (GPM)	W.P.D. (FT.)	FLUID	ROWS	TOTAL MBH	SENSIBLE MBH	EAT (DB/WB)	LAT (DB/WB)	COIL TYPE	REFRIGERANT	VOLT	PHASE	MCA			MAX FUSE
UV-201	SECOND FL	FLOOR	MED	1250	448	72	42	100	180	107.3	2	3.5	HW	3	41	26	80/67	55/54	DX	R-410A	208	3	30.1	45	DAIKIN — AZQ 054	1,2,3,4,5,6,7,8
UV-202	SECOND FL	FLOOR	MED	1250	448	72	42	100	180	107.3	2	3.5	HW	3	41	26	80/67	55/54	DX	R-410A	208	3	30.1	45	DAIKIN — AZQ 054	1,2,3,4,5,6,7,8
UV-203	SECOND FL	FLOOR	MED	1250	448	72	42	100	180	107.3	2	3.5	HW	3	41	26	80/67	55/54	DX	R-410A	208	3	30.1	45	DAIKIN — AZQ 054	1,2,3,4,5,6,7,8
UV-204	SECOND FL	FLOOR	MED	1250	448	72	42	100	180	107.3	2	3.5	HW	3	41	26	80/67	55/54	DX	R-410A	208	3	30.1	45	DAIKIN — AZQ 054	1,2,3,4,5,6,7,8
UV-208	SECOND FL	FLOOR	MED	1250	448	72	42	100	180	107.3	2	3.5	HW	3	41	26	80/67	55/54	DX	R-410A	208	3	30.1	45	DAIKIN — AZQ 054	1,2,3,4,5,6,7,8
UV-209	SECOND FL	FLOOR	MED	1250	448	72	42	100	180	107.3	2	3.5	HW	3	41	26	80/67	55/54	DX	R-410A	208	3	30.1	45	DAIKIN — AZQ 054	1,2,3,4,5,6,7,8
UV-210	SECOND FL	FLOOR	MED	1250	448	72	42	100	180	107.3	2	3.5	HW	3	41	26	80/67	55/54	DX	R-410A	208	3	30.1	45	DAIKIN — AZQ 054	1,2,3,4,5,6,7,8
UV-211	SECOND FL	FLOOR	MED	1250	448	72	42	100	180	107.3	2	3.5	HW	3	41	26	80/67	55/54	DX	R-410A	208	3	30.1	45	DAIKIN — AZQ 054	1,2,3,4,5,6,7,8
UV-212	SECOND FL	FLOOR	HIGH	1500	797	104	35	100	180	110.4	3	3.5	HW	3	48	34	80/67	55/54	DX	R-410A	208	3	30.1	45	DAIKIN — AZQ 054	1,2,3,4,5,6,7,8
UV-213	SECOND FL	FLOOR	HIGH	1500	770	104	35	100	180	110.4	3	3.5	HW	3	48	34	80/67	55/54	DX	R-410A	208	3	30.1	45	DAIKIN — AZQ 054	1,2,3,4,5,6,7,8
UV-216	SECOND FL	FLOOR	MED	1250	413	72	42	100	180	107.3	2	3.5	HW	3	41	26	80/67	55/54	DX	R-410A	208	3	30.1	45	DAIKIN — AZQ 054	1,2,3,4,5,6,7,8
UV-304	SECOND FL	FLOOR	MED	1250	403	72	42	100	180	107.3	2	3.5	HW	3	41	26	80/67	55/54	DX	R-410A	208	3	30.1	45	DAIKIN — AZQ 054	1,2,3,4,5,6,7,8

- REMARKS:
1. PROVIDE MANUFACTURERS DISCONNECT, FACTORY MOUNTED AND WIRED.
  2. PROVIDE UNIT WITH MANUFACTURERS THREE SPEED SWITCH SET TO AIRFLOW INDICATED.
  3. PROVIDE UNIT WITH FACE AND BYPASS.
  4. PROVIDE ANTIQUE IVORY COLOR.
  5. UNIT TO COME WITH FACTORY MICROTECH CONTROLLER.
  6. PROVIDE BASIC WALL MOUNTED ROOM SENSOR, PT # 910247450.
  7. PROVIDE SS DRAIN PAN.
  8. PROVIDE MANUFACTURERS WALL SLEEVE.


Architect:

**Hamlin Design Group**  
915 Broadway, Suite 101A  
Albany, New York 12207  
Tel: 518.724.5159  
Fax: 518.320.8633  
Web: hamlindesigngroup.com

Hazardous Material Consultant:



MEP Engineer:



Client:



**Peekskill City School District**  
1031 Elm St.  
Peekskill, NY 10566

**Peekskill Reconstruction**

SED Project: 66-15-00-01-0-005-020  
HDG Project: 201

**Oakside Elementary**  
200 Decatur Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-007-014  
HDG Project: 202

**Uriah Hill School**  
980 Pemart Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-008-017  
HDG Project: 203

**Woodside Elementary**  
612 Depew St.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-014-005  
HDG Project: 204

**Middle School**  
212 Ringgold St.,  
Peekskill, NY 10566

DRAWN BY:  
MLB


ISSUE: 02/01/2021  
REV:





DESCRIPTION  
HVAC Schedules

O-M.002.00






- DRAWING NOTES:**
1. REMOVE UNIT VENT WITH ALL CONTROLS, PIPING, DUCTWORK, LOUVER, SLEEVE AND ALL ACCESSORIES.
  2. REMOVE THERMOSTAT WITH ALL WIRING. PATCH WALL AS REQUIRED.
  3. CUT AND CAP PIPING THAT GOES TO THIS SIDE UNIT VENT. THE NEW UNIT WILL HAVE NEW PIPING.
  4. CUT AND CAP PIPING BELOW FLOOR. SEE 400 SERIES FOR NEW PIPING.




KEY PLAN

**1** Removal Plan  
O-M.201.00 SCALE: 1/8" = 1'-0"



Architect:  
**Hamlin Design Group**  
915 Broadway, Suite 101A  
Albany, New York 12207  
Tel: 518.724.5159  
Fax: 518.320.8633  
Web: hamlindesigngroup.com

Hazardous Material Consultant:



MEP Engineer:



Client:



**Peekskill City School District**  
1031 Elm St.  
Peekskill, NY 10566

**Peekskill Reconstruction**

SED Project: 66-15-00-01-0-005-020  
HDG Project: 201

**Oakside Elementary**  
200 Decatur Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-007-014  
HDG Project: 202

**Uriah Hill School**  
980 Pemart Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-008-017  
HDG Project: 203

**Woodside Elementary**  
612 Depew St.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-014-005  
HDG Project: 204

**Middle School**  
212 Ringgold St.,  
Peekskill, NY 10566

DRAWN BY:  
MLB


ISSUE: 02/01/2021  
REV:



DESCRIPTION  
Removal Plan

**O-M.201.00**







1 HVAC Plan  
O-M.401.00 SCALE: 1/8" = 1'-0"

GENERAL NOTES:

- A. THE INSTALLATION OF THE UNIT VENTILATORS (WITH THE EXCEPTION OF ELECTRICAL) WILL BE PART OF A SINGLE CONTRACT. DRAWING O-A.500.00 WILL BE PART OF THE MC CONTRACT. THIS CONTRACTOR SHALL HIRE A LICENSED CONTRACTOR TO PERFORM THE EXTERIOR WORK ON THE BUILDING TO THE SATISFACTION OF THE OWNER.
- B. THIS CONTRACTOR SHALL BE RESPONSIBLE TO ENSURE THAT NO OUTSIDE AIR ENTERS THE ROOM OR EITHER OF THE END COMPARTMENTS OF THE UNIT VENTILATOR.
- C. EXTEND THE WATER PIPING TO THE NEW LOCATIONS FOR THE NEW LONGER UNIT VENT IN THE FLOOR BELOW. THE UNIT DOES NOT HAVE A PIPE TUNNEL FOR CROSSOVER PIPING.
- D. ALL LOUVERS ARE TO BE MEASURED AND FIELD VERIFIED BEFORE ANY SUBMITTALS. ANY INCONSISTENCIES ARE TO BE COORDINATED PRIOR TO ANY SUBMITTALS.
- E. ALL LOUVERS ARE TO BE A DIVIDED LOUVER THAT WILL PREVENT THE AIR STREAMS FROM CROSSING.
- F. LOUVERS ARE TO BE A CLEAR ANODIZED AND NON-FLANGED.
- G. PROVIDE (2) 30"x30" ACCESS DOORS IN THE LOWER LEVEL CEILING TO ACCESS THE PIPING FOR ALL UNITS.
- H. PROVIDE NEW CORE HOLES FOR PIPING AS REQUIRED.

DRAWING NOTES:

- 1. INSTALL NEW UNIT VENT IN LOCATION SHOWN. EXTEND AND CONNECT EXISTING HWS&R PIPING TO NEW UNIT VENT. PROVIDE ALL NEW WATER SPECIALTIES PER DETAIL ON 600 SERIES.
- 2. PROVIDE 2" VERTICAL SUPPORT BETWEEN LOUVERS. SUPPORT SHALL BE THE ALUMINUM WITH ANODIZED ALUMINUM COLOR TO EXACTLY MATCH LOUVER.
- 3. PROVIDE SHEETMETAL AND INSULATION BEHIND LOVER PER DETAIL.
- 4. REMOVE LOUVER AND PART OF THE WALL SLEEVE TO VERIFY WALL CONSTRUCTION PRIOR TO SUBMITTALS TO VERIFY FINAL HEIGHT OF NEW LOUVER AND THICKNESS OF SLEEVE. RE-INSTALL LOUVER AFTER REVIEW.




KEY PLAN




Architect:  
**Hamlin Design Group**  
915 Broadway, Suite 101A  
Albany, New York 12207  
Tel: 518.724.5159  
Fax: 518.320.8633  
Web: hamlindesigngroup.com

Hazardous Material Consultant:



MEP Engineer:



Client:



**Peekskill City School District**  
1031 Elm St.  
Peekskill, NY 10566

**Peekskill Reconstruction**  
SED Project: 66-15-00-01-0-005-020  
HDG Project: 201  
**Oakside Elementary**  
200 Decatur Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-007-014  
HDG Project: 202  
**Uriah Hill School**  
980 Pemart Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-008-017  
HDG Project: 203  
**Woodside Elementary**  
612 Depew St.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-014-005  
HDG Project: 204  
**Middle School**  
212 Ringgold St.,  
Peekskill, NY 10566

DRAWN BY:  
MLB


ISSUE: 02/01/2021  
REV:




DESCRIPTION  
HVAC Plan

O-M.401.00





FOR ROOMS: 201, 20, 203, 204, 208, 209, 210, 211




### 1 TYPICAL UV COIL PIPING DIAGRAM

SCALE : NONE

#### NOTES:


1. COIL SIZED TO MATCH FLOW.
2. PROVIDE UNIONS ON COIL AND CONTROL VALVE CONNECTIONS.
3. AREAS SHOWN IN DASHED BOXES WILL BE ALLOWED FOR COIL KITS.
4. COILS KITS THAT ARE SUPPLIED WITH FLEXIBLE HOSES WILL BE REJECTED WITHOUT REVIEW.



### 2 LOUVER AND INSULATION DETAIL

SCALE : NONE

BLANK OFF INACTIVE LOUVER AS SHOWN.



#### ELEVATION VIEW

#### NOTE:

1. UNIT IS TO BE INSTALLED TIGHT AGAINST OUTSIDE WALL WITH MANUFACTURERS WALL SLEEVE FULLY INTO ROOM. PROVIDE CUSTOM WALL SLEEVE FROM UNIT VENT TO LOUVER. SLEEVE TO HAVE DIVIDER IN IT TO PREVENT THE AIR STREAMS FROM CROSSING. UNIT TO BE SEALED AGAINST OUTSIDE WALL SO NO OUTSIDE AIR ENTERS UNIT OR ROOM.
2. INSTALL PER MANUFACTURERS RECOMMENDATIONS.


#### FOR ALL UNITS

### 3 UNIT VENTILATOR DETAIL

SCALE : NONE


#### GENERAL UNIT VENTILATOR INSTALLATION NOTES

1. IT IS THE RESPONSIBILITY OF THIS CONTRACTOR TO INSURE THAT ALL AREAS OF THE UNIT VENTILATOR ARE COMPLETELY SEALED AND INSULATED TO THE OUTSIDE AIR INTAKE.
2. AS WALL CONDITIONS VARY AT EACH INDIVIDUAL UNIT THIS CONTRACTOR MUST PROVIDE SAFING, INSULATION, SHEET METAL, AND ACCESSORIES REQUIRED TO SEAT UNIT VENTILATOR FIRMLY AGAINST THE WALL.
3. REFER TO PIPING DETAIL FOR WATER SPECIALTIES.
4. THE END COMPARTMENTS OF EACH UNIT VENTILATOR MUST BE COMPLETELY SEALED-OFF AND RE-INSULATED TO PERMIT ANY OUTSIDE AIR FROM ENTERING THE UNIT OR THE ROOM.
5. THE CONTRACTOR IS RESPONSIBLE TO VERIFY AND ORDER THE CORRECT SIZE LOUVER
6. THIS CONTRACTOR IS RESPONSIBLE TO ENSURE THAT NO WATER ENTERS BUILDING AROUND NEW LOUVER. CAULK AS REQUIRED. IF JOINT IS LARGER THAN 1/4" CONTRACTOR SHALL PROVIDE A METAL BACKING MATERIAL BETWEEN LOUVER AND WALL AND THEN CAULK WEATHERTIGHT.
7. INSTALL PER MANUFACTURERS INSTRUCTIONS.



#### ELEVATION VIEW


#### FOR ALL UNITS



Architect:

**Hamlin Design Group**  
915 Broadway, Suite 101A  
Albany, New York 12207  
Tel: 518.724.5159  
Fax: 518.320.8633  
Web: hamlindesigngroup.com

Hazardous Material Consultant:



MEP Engineer:



Client:



**Peekskill City School District**  
1031 Elm St.  
Peekskill, NY 10566

#### Peekskill Reconstruction

SED Project: 66-15-00-01-0-005-020  
HDG Project: 201

#### Oakside Elementary

200 Decatur Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-007-014

HDG Project: 202

#### Uriah Hill School

980 Pemart Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-008-017

HDG Project: 203

#### Woodside Elementary

612 Depew St.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-014-005

HDG Project: 204

#### Middle School

212 Ringgold St.,  
Peekskill, NY 10566

DRAWN BY:

MLB

ISSUE: 02/01/2021

REV:



#### DESCRIPTION

HVAC Details and Diagrams

O-M.601.00



GENERAL NOTES - REMOVALS			
<div>1. AVOID DEAD ENDS OF 24" LONG OR GREATER WHEN REMOVING SANITARY OR STORM WATER PIPING. PROVIDE SUITABLE PLUG OR CAP ON PIPING TO REMAIN. (INFILL OF THE PIPING WITH CONCRETE OR OTHER MATERIALS SHALL NOT BE ACCEPTABLE)</div> <div>2. REMOVE ALL COLD WATER, HOT WATER, RE-CIRCULATION PIPING, AS INDICATED ON PLANS. REMOVE ALL PIPING BACK TO BRANCH CONNECTION. PROVIDE TEMPORARY OR PERMANENT CAPPED END ON PIPING. PIPING SHALL NOT BE LEFT OPEN ENDED.</div> <div>3. WHERE PIPING BELOW GRADE IS TO BE REMOVED. PROVIDE SUITABLE SHORING OF TRENCH WALLS AND DE-WATERING EQUIPMENT AS NECESSARY. TRENCHES SHALL BE PROPERLY SHORED AND DE WATERED THROUGHOUT THE REMOVAL PROCESS.</div> <div>4. WHERE PIPING IS BEING REMOVED THROUGH AND EXISTING WALL, THE CORE-DRILLED HOLE OR SLEEVE SHALL BE SEALED WITH A SUITABLE METHOD OF SEALING.</div> <div>5. ALL REMOVAL WORK SHALL BE COORDINATED WITH THE WORK OF THE OTHER TRADES.</div> <div>6. THROUGHOUT THE REMOVAL PROCESS, IT IS OF PARAMOUNT IMPORTANCE THAT ANY AND ALL SYSTEMS SHALL BE MAINTAINED IN PROPER WORKING ORDER FOR AS LONG AS PRACTICAL.</div> <div>7. THROUGHOUT THE REMOVAL PROCESS ALL AREAS OF WORK SHALL BE KEPT FREE OF DEBRIS AND IN A CLEAN AND ORDERLY STATE.</div> <div>8. WHERE VENT TERMINALS AND ROOF DRAINS ARE REMOVED, THE ROOF OPENING SHALL BE PATCHED AND REPAIRED SO THE BUILDING ROOF WILL SHED WATER.</div> <div>9. WHERE PIPING IS REMOVED THROUGH FIRE RATED CONSTRUCTION THE ABANDONED WALL PENETRATIONS SHALL BE SEALED WITH THE APPROPRIATE FIRE RATED SEALING ELEMENTS.</div> <div>10. WHERE PIPING TO BE REMOVED IS DISCOVERED TO BE IN AN UNSAFE LOCATION OR IS IN A STATE WHICH MAY POSE A HEALTH CARE RISK, THE ARCHITECT AND THE ENGINEER SHALL BE INFORMED IMMEDIATELY. DIRECTION AS TO HOW TO PROCEED SHALL BE DETERMINED ON A CASE BY CASE BASIS.</div> <div>11. ALL CUTTING AND PATCHING REQUIRED TO SAFELY AND PROPERLY REMOVE PIPING ETC... SHALL BE PERFORMED BY THIS CONTRACTOR, UNLESS SPECIFICALLY CALLED OUT BY OTHERS.</div> <div>12. ALL NATURAL GAS AND LIQUEFIED PROPANE SHALL BE REMOVED AS INDICATED, THE PIPING SHALL FIRST BE PURGED OF GAS PER THE REQUIREMENTS OF NFPA 54.</div>			

GENERAL NOTES - NEW INSTALLATIONS			
<div>1. IN ALL AREAS WHERE PATCHING IS REQUIRED, THE CONTRACTOR SHALL PATCH THE SUBSURFACE WHERE THE NEW SURFACE IS TO BE FINISHED BY THE GENERAL CONTRACTOR. THIS SUBSURFACE MUST BE PROVIDED SO THAT IT DOES NOT INHIBIT THE INSTALLATION OF OR AFFECT THE APPEARANCE OF THE NEW FINISH. IF A NEW FINISH WILL NOT BE PROVIDED BY THE GENERAL CONTRACTOR, THE CONTRACTOR IS RESPONSIBLE TO PATCH TO MATCH THE SURROUNDING SURFACE. (UNLESS NOTED BY THE GENERAL CONTRACTORS PLANS)</div> <div>2. THE CONTRACTOR SHALL CHECK AND VERIFY ALL CONDITIONS AND DIMENSIONS AT THE SITE BEFORE PROCEEDING WITH THE WORK. HE SHALL REPORT ANY DISCREPANCIES TO THE ARCHITECT/ENGINEER FOR CORRECTION PRIOR TO BEGINNING ANY WORK. DISCOVERY OF ANY DISCREPANCIES AFTER WORK HAS COMMENCED SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR. PROVIDE VALVING, PIPING AND TEMPORARY CONNECTIONS TO EXISTING SYSTEMS AS NECESSARY FOR CONTINUATION OF OPERATIONS.</div> <div>3. DO NOT SCALE THESE DRAWING FOR EXACT DIMENSIONS, VERIFY ALL FIGURES, CONDITIONS, DIMENSIONS, ETC. AT THE JOB SITE.</div> <div>4. THE OWNER SHALL HAVE THE OPTION TO RETAIN ANY FIXTURES, CONTROLS, PIPING, AND ACCESSORIES SCHEDULED TO BE REMOVED.</div> <div>5. ALL EXISTING SYSTEMS NOT IN THE CONSTRUCTION PHASE SHALL REMAIN IN SERVICE. ALL SYSTEM SHUTDOWNS SHALL BE COORDINATED AND OCCUR ONLY WITH THE APPROVAL OF THE FACILITY.</div> <div>6. SHUTDOWN OF SERVICES SHALL BE COORDINATED AND SCHEDULED WITH THE OWNER AND SHALL ONLY OCCUR WITH THE WRITTEN APPROVAL OF THE FACILITY.</div> <div>7. THIS CONTRACTOR IS RESPONSIBLE FOR CUTTING AND PATCHING MADE NECESSARY BY HIS WORK. REMOVALS SHALL BE TO BEYOND FINISHED SURFACES TO ALLOW PATCHING AND FINISHING TO MATCH ADJACENT SURFACES.</div> <div>8. VERIFY LOCATIONS OF NEW WORK REQUIRED FOR CONSTRUCTION WITH EXISTING STRUCTURE AND FIELD CONDITIONS. MODIFY POINTS OF CONNECTION TO EXISTING SYSTEMS AS NECESSARY FOR JOB CONDITIONS. PROVIDE VALVING, PIPING AND TEMPORARY CONNECTIONS TO NEW SYSTEMS AS NECESSARY FOR WORK CONTINUATION.</div> <div>9. COORDINATE ALL WORK WITH THE FUNCTIONS OF ADJACENT AREAS.</div> <div>10. PROVIDE SLAB CUTTING AND PATCHING AS NECESSARY TO MAKE CONNECTIONS TO UNDER FLOOR SANITARY PIPING. NECESSARY TO MAKE CONNECTIONS TO UNDER FLOOR SANITARY PIPING. (UNLESS NOTED ON THE GENERAL CONTRACT PLANS)</div> <div>11. CEILINGS THAT NEED TO BE TEMPORARILY REMOVED TO ALLOW FOR THE INSTALLATION OF PIPING OR EQUIPMENT AND ARE NOT SCHEDULED TO BE REMOVED ON THE ARCHITECTURAL DRAWINGS SHALL BE REMOVED AND REPLACED BY THIS CONTRACTOR. COORDINATE THE REMOVAL AND THE REPLACEMENT WITH THE ELECTRICAL CONTRACTOR AND THE FIRE PROTECTION CONTRACTOR.</div> <div>12. DO NOT INSTALL ANY PLUMBING WORK ABOVE ELECTRICAL PANELS. DO NOT INSTALL ANY PLUMBING WORK ABOVE OR THROUGH ELEVATOR EQUIPMENT ROOM, UNLESS SPECIFICALLY SERVING EQUIPMENT ROOM.</div> <div>13. SLEEVE AND SEAL ALL PIPE PENETRATIONS OF WALL AND FLOORS. PACK VOID BETWEEN PIPE AND SLEEVE WITH INSULATION IN NON-RATED WALL AND FLOORS. PACK VOID BETWEEN PIPE AND SLEEVE WITH INSULATION IN FIRE-RATED WALLS AND FLOORS, APPLY INTUMESCENT FIRE SAFING COMPOUND AT PENETRATION, MAINTAINING INTEGRITY AND RATING OF FIRE SEPARATION. SLEEVES THROUGH FLOORS SHALL EXTEND 2" ABOVE FLOOR, BE GROUTED INTO PLACE AND WATERPROOFED. PIPING THROUGH EXTERIOR WALLS SHALL BE SLEEVED AND SEALED WEATHER TIGHT.</div>			

### INSULATION SCHEDULE

SERVICE	TEMP °F	MATERIAL	PIPE DIA / THK'S
DOMESTIC COLD WATER	ALL	GLASS FIBER	1" THICK
DOMESTIC HWS & RECIRC	105-140	GLASS FIBER	<1 1/2" 1" THK 1 1/2" < 2" THK
DOMESTIC HWS & RECIRC	141-200	GLASS FIBER	<1 1/2" 1 1/2" THK 1 1/2" < 2" THK
ROOF DRAIN & PIPING	---	GLASS FIBER	1" ALL SIZES
A/C COND PIPING	---	GLASS FIBER	1" ALL SIZES

### REMARKS

1. JACKET MATERIAL FINISH SHALL BE AS SPECIFIED FOR ALL EXPOSED AND CONCEALED APPLICATIONS
2. PROVIDE ZESTON (PVC) COVERS FOR ALL EXPOSED PIPE AND PIPE FITTINGS, OTHER THAN MECHANICAL ROOMS.
3. INSTALL COVER SYSTEM FROM FLOOR TO CEILINGS.

PIPING	
	PIPING BEING REMOVED
	DOMESTIC COLD WATER
	DOMESTIC HOT WATER
	DOMESTIC HOT WATER RETURN
	SANITARY ABOVE FLOOR
	SANITARY BELOW FLOOR
	SANITARY VENT
	STORM ABOVE FLOOR
	STORM BELOW FLOOR
	NATURAL GAS
	LIQUIFIED PETROLEUM GAS
	CONDENSATE DRAIN
	COMPRESSED AIR
	ACID WASTE ABOVE FLOOR
	ACID WASTE BELOW FLOOR
	ACID VENT

DRAINAGE	
	FLOOR DRAIN
	ROOF DRAIN
	FLOOR CLEANOUT
	GRADE CLEANOUT
	VENT THOUGH ROOF
	PIPE CAPPED END
	ELBOW DOWN
	TEE DOWN
	CONNECTION
	BASE CLEANOUT
	END OF LINE CLEANOUT
	RUNNING TRAP
	SUMP PUMP

VALVES	
	BALL VALVE
	GATE VALVE
	OS & Y GATE VALVE
	BALANCING VALVE
	PLUG VALVE
	SOLENOID VALVE
	CHECK VALVE
	BUTTERFLY / WAFER VALVE
	PRESSURE REDUCING VALVE
	GAS TURRET ( COUNTER MTD)

FITTINGS	
	SHOCK ARRESTOR
	STRAINER
	FREEZE PROOF WALL HYDRANT
	HOSE BIBB
	HOSE BIBB ANGLED
	PRIMER VALVE
	UNION
	REDUCER
	PRESSURE GAUGE
	AQUASTAT CONTROLLER
	THERMOSTAT


ABBREVIATIONS	
AC AD AFF AFG AP	AIR CHAMBER ACCESS DOOR ABOVE FINISHED FLOOR ABOVE FINISHED GRADE ACCESS PANEL
BCO BF BFF BFP	BASE CLEANOUT BELOW FLOOR BELOW FINISHED FLOOR BACKFLOW PROTECTOR
CI CLG CO COND CT CW CTE CI CONC	CAST IRON CEILING CLEAN OUT CONDUCTOR COUNTER TOP COLD WATER CONNECT TO EXISTING CAST IRON CONCRETE
DF DIA DN DHW DHW DPCO DWG	DRINKING FOUNTAIN DIAMETER DOWN DOMESTIC HOT WATER DOMESTIC HOT WATER RETURN DECK PLATE CLEANOUT DRAWING
ECO EWC EXR	END OF LINE CLEANOUT ELECTRIC WATER COOLER EXISTING TO REMAIN
FAI FCO FD FLR FF FFE	FRESH AIR INLET FLUSH FLOOR CLEANOUT FLOOR DRAIN FLOOR FINISH FLOOR FINISHED FLOOR ELEVATION
G GA GC	GAS GAUGE GENERAL CONTRACTOR
HB HW HWR	HOSE BIBB HOT WATER HOT WATER RE-CIRCULATION
INV EL IW	INVERT ELEVATION INDIRECT WASTE
LAV LDR LPG	LAVATORY LEADER LIQUIFIED PETROLEUM GAS
MAX MB MC MFR MH MIN	MAXIMUM MOP BASIN MECHANICAL CONTRACTOR MANUFACTURER MAN HOLE MINIMUM
OS&Y O2	OUTSIDE SPINDLE & YOKE OXYGEN
PC PG PRV PS PSI PO	PLUMBING CONTRACTOR PRESSURE GAUGE PRESSURE REDUCING VALVE PRESSURE SWITCH POUNDS PER SQ IN PLUGGED OUTLET
RD RPZ	ROOF DRAIN REDUCED PRESSURE ZONE
SA SAN SH SK SS ST	SHOCK ARRESTOR SANITARY SHOWER SINK STAINLESS STEEL STRAINER
TEMP TYP	TEMPERATURE TYPICAL
UR	URINAL
VA V VCT VIF VTR	VALVE VENT VITRIFIED CLAY TILE VERIFY IN FIELD VENT THRU ROOF
W W&V WC WCO WF WHA	WASTE WASTE & VENT WATER CLOSET WALL CLEANOUT WASH FOUNTAIN WATER HAMMER ARRESTOR

GENERAL	
	REMOVE / CONNECT TO
	REMOVAL NOTE TAG
	INSTALLATION NOTE TAG
	PIPING BREAK
	EDGE BREAK LINE
	ADA FIXTURE




Architect:  
**Hamlin Design Group**  
915 Broadway, Suite 101A  
Albany, New York 12207  
Tel: 518.724.5159  
Fax: 518.320.8633  
Web: hamlindesigngroup.com

Hazardous Material Consultant:



MEP Engineer:



Client:



**Peekskill City School District**  
1031 Elm St.  
Peekskill, NY 10566

### Peekskill Reconstruction

SED Project: 66-15-00-01-0-005-020  
HDG Project: 201  
**Oakside Elementary**  
200 Decatur Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-007-014  
HDG Project: 202  
**Uriah Hill School**  
980 Pemart Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-008-017  
HDG Project: 203  
**Woodside Elementary**  
612 Depew St.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-014-005  
HDG Project: 204  
**Middle School**  
212 Ringgold St.,  
Peekskill, NY 10566


DRAWN BY:  
DAR

ISSUE: 02/01/2021

DESCRIPTION  
Symbols, Abbreviations & Notes


O-P.001.00





REMOVAL NOTES: ○


1. REMOVE THE 3" WATER SERVICE ENTRANCE, FROM THE FLANGE ON TOP OF THE MAIN SHUT OFF VALVE. REMOVE THE OLD ASSEMBLY INCLUDING THE WATER METER.




1 Removal Plan  
O-P.301.00 SCALE: 1/8" = 1'-0"

DRAWING NOTES: ○

1. PROVIDE FOR NEW 3" WATER SERVICE AS SHOWN. PROVIDE NEW WATER METER AND DOUBLE CHECK VALVE BACKFLOW PREVENTOR. REFER TO DETAILS THIS SHEET. REFER TO SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS.





2 New Plumbing Plan  
O-P.301.00 SCALE: 1/8" = 1'-0"



3 WATER SERVICE PIPING DIAGRAM  
M-P.301.00 SCALE: NONE

1. PROVIDE SUPPORT FOR PIPING ON WALL MAINTAIN MIN CLEARANCE OF 8" BEHIND BACK FLOW PREVENTOR BFP-1
2. ALL MATERIALS UPSTREAM OF THE WATER METER & BACKFLOW PREVENTOR SHALL BE DUCTILE IRON , COPPER, OR BRASS
3. THE FOLLOWING CLEARANCES SHALL BE MAINTAINED FOR THE WATER METER AND BACKFLOW PREVENTER, 30" CLEAR IN FRONT, 8" FROM THE BACK WALL & 12" ABOVE



Architect:  
**Hamlin Design Group**  
915 Broadway, Suite 101A  
Albany, New York 12207  
Tel: 518.724.5159  
Fax: 518.320.8633  
Web: hamlindesigngroup.com

Hazardous Material Consultant:



MEP Engineer:



Client:



**Peekskill City School District**  
1031 Elm St.  
Peekskill, NY 10566

**Peekskill Reconstruction**

SED Project: 66-15-00-01-0-005-020  
HDG Project: 201

**Oakside Elementary**  
200 Decatur Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-007-014  
HDG Project: 202

**Uriah Hill School**  
980 Pemart Ave.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-008-017  
HDG Project: 203

**Woodside Elementary**  
612 Depew St.,  
Peekskill, NY 10566

SED Project: 66-15-00-01-0-014-005  
HDG Project: 204

**Middle School**  
212 Ringgold St.,  
Peekskill, NY 10566

DRAWN BY:  
DAR

ISSUE: 02/01/2021

DESCRIPTION  
Removal & New Plumbing Plan

O-P.301.00