

Air Cooled Condensing Unit Schedule

Unit No.	Service	Location	Capacity (MBH)	Comp.	Ref.	Electrical Data			Weight (lbs)	Manufacturer & Model No.	Remarks
				Qty.		Volt/Phase	MCA	MOCP (Amps)			
ACC-1	CH-1	Roof	892	2	R-410A	460/3	16	20	2063	DAIKIN LAVF23312M	----
ACC-2	CH-2	Roof	892	2	R-410A	460/3	16	20	2063	DAIKIN LAVF23312M	----

1

1

FELLENZER 
ENGINEERING LLP

www.fellp.com

22 Mulberry St., Suite 2A,
Middletown, NY 10940
t 845-343-1481 fx 855-320-8735

181 Church St., Suite 100,
Poughkeepsie, NY 12601
t 845-454-9704; fx 855-320-8735

PROJECT TITLE: **Montebello Realty, GP LLC**
Braemar at Montebello Assisted
Living Residence

FE PROJECT No:
15-345

SCALE: NTS

DESIGNED BY:
PMC

DRAWN BY:
AH

CHECKED BY:
EDF

REF. DWG.:
H8.1

SKETCH TITLE:
GENERAL REVISION

REF. DWG. TITLE:
**HVAC:
SCHEDULES**

SKETCH No:
SKH8.1.3

ISSUE DATE:
2-11-20