

**LONGO ARCHITECTS
& ASSOCIATES LLC**

WILLIAM R. RYAN AIA
VINCENT F. WOLK AIA

ASSOCIATE
MITCHELL C. BOBYACK RA

September 15, 2021

ADDENDUM #2
TO CONTRACT DOCUMENTS
FOR WELLS FARGO
NEW BRANCH INTERIOR FIT-OUT
1130 EAST BOSTON POST ROAD, MAMARONECK, NY 10543

All bidders are advised that this Addendum and its contents are to be added to the original Specifications for the project and may alter, amend or clarify the original Specifications and Drawings for the project, taking precedence where in conflict.

Clarifications/Updates:

1. This is a LEED project.
2. Model # for condenser units: Model number for the 18" high stand is "QSMS1801M"
 - a. There are no existing concrete pads for these units. The unit shall be installed on the stand to prevent snow from blocking outdoor unit fan.

Submitted By:



Vincent F. Wolk, AIA, NCARB
VFW/mlw