



City of Yonkers/Yonkers Public Schools  
One Larkin Center – 3<sup>rd</sup> Floor  
Yonkers, New York 10701  
(914) 377-6930  
Fax: (914) 377-6032  
Email: [debra.censi@yonkersny.gov](mailto:debra.censi@yonkersny.gov)

**CITY OF YONKERS**

***Purchasing***

***Mike Spano, Mayor***

***Tom Collich, Director***

**TO:** PROSPECTIVE BIDDERS

**(1) - Page + pdf attachments:**

- Warranty (6) Pages
- Drawing M100
- Drawing A101

**DATE:** 4/13/2021

**FROM:** Debra Censi, Purchasing Department

**RE: IFB-6602: CAFETERIA & 3<sup>RD</sup> FLOOR EMERGENCY EGRESS IMPROVEMENT AT THE ROSEMARIE ANN SIRAGUSA SCHOOL – PS14**

**ADDENDUM No. 3: INFORMATIONAL/Request for Information (RFI) – Response to RFI's received**

The contents of this addendum alter and amend the original Bid requirements and take precedence over the related items therein. This addendum forms a part of the contract documents. Bidders must acknowledge receipt of all addenda when submitting their bids. Failure to acknowledge receipt may render your bid non-responsive and ineligible for award. Bidders are responsible for ensuring that they receive all addenda. All addenda will be posted on the Empire State Purchasing Group System (<http://www.empirestatebidsystem.com/>).

**PLEASE NOTE THE FOLLOWING:**

Response to RFI's received:

1. RFI: Please provide length of new W8 x 31 steel beams as shown on Drawing A115, Detail 5.

**Response:** Beam is approximately 9'-3". Contractor shall verify location of existing bearing wall and coordinate length of new beam.

2. RFI: The EPDM roof is under warranty according to note WS4 on drawing A111. Please provide manufacturer and warranty information.

**Response:** Refer to warranty information.

3. Requesting the info for section 5 of the specifications for Bid no. IFB-6602. Section 5 - 055305 appears to be missing an end of section page. Please provide this section.

**Response:** There are no missing pages or missing data. "End of Section" designation failed to print after paragraph 3.3 B.

4. Attached are revised drawings A-101 and M-100 indicating revisions to steam piping within the existing Gym to be included in the addendum.

**\*\*END OF ADDENDUM NO. 3\*\***

The **BID DUE DATE** remains Friday, April 23, 2021 at 2:00 P.M.

**IFB-6602: ADDENDUM No. 3 – ACKNOWLEDGEMENT – Return this document with your sealed bid.**

**Bidding Firm:** \_\_\_\_\_

**Address:** \_\_\_\_\_

**Bidder's Representative:** \_\_\_\_\_ **Title:** \_\_\_\_\_

**E-mail:** \_\_\_\_\_ **Signature:** \_\_\_\_\_ **Date:** \_\_\_\_\_