



City of Yonkers/Yonkers Public Schools
One Larkin Center – 3rd Floor
Yonkers, New York 10701
(914) 377-6035
Email: thomas.collich@yonkersny.gov

CITY OF YONKERS/YONKERS PUBLIC SCHOOLS
Purchasing

Mike Spano, Mayor
Tom Collich, Director

TO: PROSPECTIVE BIDDERS **JANUARY 20, 2021**
FROM: TOM COLLICH, PURCHASING DIRECTOR **1 PAGE & 3 UPLOADED DOCUMENTS**
RE: BID 6569A – SCHOOL 9 HVAC RE-BID
ADDENDUM NO. 3 CLARIFICATIONS TO SPECIFICATIONS & DRAWINGS

The contents of this addendum alter and amend the original Bid requirements and take precedence over the related items therein. This addendum forms a part of the contract documents. Bidders must acknowledge receipt of all addenda **when submitting their bids**. Failure to acknowledge receipt may render a bid non-responsive and ineligible for award. Vendors are responsible for ensuring that they receive all addenda. All addenda is posted on the Empire State Purchasing Group System (<http://www.empirestatebidsystem.com/>).

ADDENDUM #3

1. Replace Drawing M101 with attached Drawing M101 issued for Addendum #3 dated 1/20/2021. Drawing M101 was revised to include alterations to the existing Auditorium HV Unit Supply & Return ductwork, diffusers, and grills, replacement of supply ductwork insulation, air balancing, and replacement of existing perimeter radiator covers and cleaning of fin-tube.
2. Replace Technical Specifications Section 011000 Summary & Scope of Work with attached Section 011000 Summary & Scope of Work issued for Addendum #3 dated 1/20/2021. Deletes previous notes for 2 bids. The HVAC Contractor shall include all HVAC work in M drawings and technical specifications in their Base Bid.
3. Insert missing Technical Specifications Section 023 0713 Duct Insulation issued for Addendum #3 dated 1/20/2021.

SEE SEPARATE DOCUMENTS UPLOADED TO THE BIDNET EMPIRE STATE PURCHASING GROUP WEBSITE AT:
<http://www.empirestatebidsystem.com/>

1. Drawing M101.pdf – 364 KB – 1 sheet
2. Technical Specifications Section 01 1000 Summary of Scope of Work.doc.pdf – 77 KB – 2 pages
3. Technical Specifications Section 23 0713 Duct Insulation.pdf – 14 KB – 1 page

THE OPENING DATE REMAINS FRIDAY, FEBRUARY 5, 2021 AT 2:00 PM

BID 6569A - ADDENDUM NO. 3 – ACKNOWLEDGEMENT

Legal Name of Bidder: _____

Address: _____

Bidder's Representative: _____ **Title:** _____

E-mail: _____

Signature: _____ **Telephone:** _____

Date: _____