



PARTIAL BASEMENT FLOOR PLAN - NEW WORK SCALE: 1/8"=1'-0"

ELECTRICAL NEW WORK NOTES:

PROVIDE NEW CABINET HEATER AND APPURTENANCES AS SCHEDULED.

CABINET HEATER SCHEDULE — HOT WATER 180F EWT														
UNIT NO.	LOCATION	TYPE	CFM	CAPACITY MBH	GPM	TEMP DROP DEG F	PRESS DROP FT HD	E.A.T. DEG F	L.A.T. DEG	FAN MOTOR				DESIGN EQUIPMENT/REMARKS
										RPM	HP	VOLTS	PHASE	DESIGN EQUIL WENTY REMARKS
CH-1														NOT USED
CH-2														NOT USED
CH-3														NOT USED
CH-4														NOT USED
CH-5	SEE M100A	VERTICAL	220	10	1.0	20	0.5	60	130	1050	1/60	120	1	RF-200-03

REMARKS:

(1) MANUFACTURED BY ZEHNDER RITTLING OR APPROVED EQUAL(2) PROVIDE HANGERS AND SUPPORTS, ANCHORS AS REQUIRED FROM STRUCTURE ABOVE

ADDENDUM #4 IFB-6569A

M100A