

**22 1119 DOMESTIC WATER PIPING SPECIALTIES**  
**PAGE 1**

**PART 1 - GENERAL**

**1.01 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

**1.02 SUMMARY**

- A. This Section includes the following domestic water piping specialties:
  - 1. Vacuum breakers.
  - 2. Backflow preventers.
  - 3. Water pressure-reducing valves.
  - 4. Balancing valves.
  - 5. Temperature-actuated water mixing valves.
  - 6. Strainers.
  - 7. Outlet boxes.
  - 8. Hose bibbs.
  - 9. Drain valves.
  - 10. Water hammer arresters.
  - 11. Air vents.
  - 12. Trap-seal primer valves.
  - 13. Trap-seal primer systems.
- B. Related Sections include the following:
  - 1. Division 22 Section "Meters and Gages for Plumbing Piping" for thermometers, pressure gages, and flow meters in domestic water piping.
  - 2. Division 22 Section "Domestic Water Piping" for water meters.
  - 3. Division 22 Section "Emergency Plumbing Fixtures" for water tempering equipment.
  - 4. Division 22 Section "Drinking Fountains and Water Coolers" for water filters for water coolers.

**1.03 PERFORMANCE REQUIREMENTS**

- A. Minimum Working Pressure for Domestic Water Piping Specialties: 125 psig (860 kPa), unless otherwise indicated.

**1.04 SUBMITTALS**

- A. Product Data: For each type of product indicated.
- B. Shop Drawings: Diagram power, signal, and control wiring.
- C. Field quality-control test reports.

**22 1119 DOMESTIC WATER PIPING SPECIALTIES**  
**PAGE 2**

- D. Operation and Maintenance Data: For domestic water piping specialties to include in emergency, operation, and maintenance manuals.

**1.05 QUALITY ASSURANCE**

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- B. NSF Compliance:
1. Comply with NSF 14, "Plastics Piping Components and Related Materials," for plastic domestic water piping components.
  2. Comply with NSF 61, "Drinking Water System Components - Health Effects; Sections 1 through 9."

**PART 2 - PRODUCTS**

**2.01 VACUUM BREAKERS**

- A. Pipe-Applied, Atmospheric-Type Vacuum Breakers
1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Ames Co.
    - b. Cash Acme.
    - c. Conbraco Industries, Inc.
    - d. FEBCO; SPX Valves & Controls.
    - e. Rain Bird Corporation.
    - f. Toro Company (The); Irrigation Div.
    - g. Watts Industries, Inc.; Water Products Div.
    - h. Zurn Plumbing Products Group; Wilkins Div.
  3. Standard: ASSE 1001.
  4. Size: NPS 1/4 to NPS 3 (DN 8 to DN 80), as required to match connected piping.
  5. Body: Bronze.
  6. Inlet and Outlet Connections: Threaded.
  7. Finish: Rough bronze.
- B. Hose-Connection Vacuum Breakers:
1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

**22 1119 DOMESTIC WATER PIPING SPECIALTIES**  
**PAGE 3**

- a. Arrowhead Brass Products, Inc.
  - b. Cash Acme.
  - c. Conbraco Industries, Inc.
  - d. Legend Valve.
  - e. MIFAB, Inc.
  - f. Prier Products, Inc.
  - g. Watts Industries, Inc.; Water Products Div.
  - h. Woodford Manufacturing Company.
  - i. Zurn Plumbing Products Group; Light Commercial Operation.
  - j. Zurn Plumbing Products Group; Wilkins Div.
3. Standard: ASSE 1011.
  4. Body: Bronze, nonremovable, with manual drain.
  5. Outlet Connection: Garden-hose threaded complying with ASME B1.20.7.
  6. Finish: Chrome or nickel plated.

**C. Pressure Vacuum Breakers :**

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
  - a. Ames Co.
  - b. Conbraco Industries, Inc.
  - c. FEBCO; SPX Valves & Controls.
  - d. Flomatic Corporation.
  - e. Toro Company (The); Irrigation Div.
  - f. Watts Industries, Inc.; Water Products Div.
  - g. Zurn Plumbing Products Group; Wilkins Div.
4. Standard: ASSE 1020.
5. Operation: Continuous-pressure applications.
6. Pressure Loss: 5 psig (35 kPa) maximum, through middle 1/3 of flow range.
7. Size: As shown.
8. Design Flow Rate As Shown
9. Selected Unit Flow Range Limits As Shown:
10. Pressure Loss at Design Flow Rate: Accessories: As Shown
  - a. Valves: Ball type, on inlet and outlet.

**D. Laboratory-Faucet Vacuum Breakers**

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Conbraco Industries, Inc.
  - b. Watts Industries, Inc.; Water Products Div.

**22 1119 DOMESTIC WATER PIPING SPECIALTIES**  
**PAGE 4**

- c. Woodford Manufacturing Company.
  - d. Zurn Plumbing Products Group; Wilkins Div.
- 3. Standard: ASSE 1035.
  - 4. Size: NPS 1/4 or NPS 3/8 (DN 8 or DN 10) matching faucet size.
  - 5. Body: Bronze.
  - 6. End Connections: Threaded.
  - 7. Finish: Chrome plated.

**2.02 BACKFLOW PREVENTERS**

A. Intermediate Atmospheric-Vent Backflow Preventers:

- 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
- 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Cash Acme.
  - b. Conbraco Industries, Inc.
  - c. FEBCO; SPX Valves & Controls.
  - d. Honeywell Water Controls.
  - e. Legend Valve.
  - f. Watts Industries, Inc.; Water Products Div.
  - g. Zurn Plumbing Products Group; Wilkins Div.
- 3. Standard: ASSE 1012.
- 4. Operation: Continuous-pressure applications.
- 5. Size: As Shown.
- 6. Body: Bronze.
- 7. End Connections: Union, solder joint.
- 8. Finish: Chrome plated.

B. Reduced-Pressure-Principle Backflow Preventers:

- 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
- 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
- 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
  - a. Ames Co.
  - b. Conbraco Industries, Inc.
  - c. FEBCO; SPX Valves & Controls.
  - d. Flomatic Corporation.
  - e. Watts Industries, Inc.; Water Products Div.
  - f. Zurn Plumbing Products Group; Wilkins Div.
- 4. Standard: ASSE 1013.
- 5. Operation: Continuous-pressure applications.

**22 1119 DOMESTIC WATER PIPING SPECIALTIES**  
**PAGE 5**

6. Pressure Loss: 12 psig (83 kPa) maximum, through middle 1/3 of flow range.
  7. Size: As Shown.
  8. Design Flow Rate: As Shown
  9. Selected Unit Flow Range Limits: As Shown.
  10. Pressure Loss at Design Flow Rate: As shown for sizes NPS 2 (DN 50) and smaller; as shown for NPS 2-1/2 (DN 65) and larger.
  11. Body: Bronze for NPS 2 (DN 50) and smaller; cast iron with interior lining complying with AWWA C550 or that is FDA approved for NPS 2-1/2 (DN 65) and larger.
  12. End Connections: Threaded for NPS 2 (DN 50) and smaller; flanged for NPS 2-1/2 (DN 65) and larger.
  13. Configuration: Designed for horizontal, straight through flow.
  14. Accessories:
    - a. Valves: Ball type with threaded ends on inlet and outlet of NPS 2 (DN 50) and smaller; outside screw and yoke gate-type with flanged ends on inlet and outlet of NPS 2-1/2 (DN 65) and larger.
    - b. Air-Gap Fitting: ASME A112.1.2, matching backflow-preventer connection.
- C. Double-Check Backflow-Prevention Assemblies :
1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
    - a. Ames Co.
    - b. Conbraco Industries, Inc.
    - c. FEBCO; SPX Valves & Controls.
    - d. Flomatic Corporation.
    - e. Watts Industries, Inc.; Water Products Div.
    - f. Zurn Plumbing Products Group; Wilkins Div.
  4. Standard: ASSE 1015.
  5. Operation: Continuous-pressure applications, unless otherwise indicated.
  6. Pressure Loss: 5 psig (35 kPa) maximum, through middle 1/3 of flow range.
  7. Size: As Shown.
  8. Design Flow Rate: As Shown.
  9. Selected Unit Flow Range Limits: As Shown.
  10. Pressure Loss at Design Flow Rate: As Shown.for sizes NPS 2 (DN 50) and smaller; As Shown.for NPS 2-1/2 (DN 65) and larger.
  11. Body: Bronze for NPS 2 (DN 50) and smaller; cast iron with interior lining complying with AWWA C550 or that is FDA approved for NPS 2-1/2 (DN 65) and larger.
  12. End Connections: Threaded for NPS 2 (DN 50) and smaller; flanged for NPS 2-1/2 (DN 65) and larger.
  13. Configuration: Designed for horizontal, straight through.
  14. Accessories:
    - a. Valves: Ball type with threaded ends on inlet and outlet of NPS 2 (DN 50) and smaller; outside screw and yoke gate-type with flanged ends on inlet and outlet of NPS 2-1/2 (DN 65) and larger.

**22 1119 DOMESTIC WATER PIPING SPECIALTIES**  
**PAGE 6**

**D. Dual-Check-Valve Backflow Preventers:**

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Cash Acme.
  - b. Conbraco Industries, Inc.
  - c. FEBCO; SPX Valves & Controls.
  - d. Flomatic Corporation.
  - e. Ford Meter Box Company, Inc. (The).
  - f. Honeywell Water Controls.
  - g. Legend Valve.
  - h. McDonald, A. Y. Mfg. Co.
  - i. Mueller Co.; Water Products Div.
  - j. Watts Industries, Inc.; Water Products Div.
  - k. Zurn Plumbing Products Group; Wilkins Div.
3. Standard: ASSE 1024.
4. Operation: Continuous-pressure applications.
5. Size: As Shown.
6. Body: Bronze with union inlet.

**E. Reduced-Pressure-Detector, Fire-Protection Backflow-Preventer Assemblies:**

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
  - a. Ames Co.
  - b. Conbraco Industries, Inc.
  - c. FEBCO; SPX Valves & Controls.
  - d. Watts Industries, Inc.; Water Products Div.
  - e. Zurn Plumbing Products Group; Wilkins Div.
4. Standard: ASSE 1047 and FMG approved or UL listed.
5. Operation: Continuous-pressure applications.
6. Pressure Loss: 12 psig (83 kPa) maximum, through middle 1/3 of flow range.
7. Size: As Shown.
8. Design Flow Rate: As Shown.
9. Selected Unit Flow Range Limits: As Shown.
10. Pressure Loss at Design Flow Rate: As Shown.
11. Body: Cast iron with interior lining complying with AWWA C550 or that is FDA approved.
12. End Connections: Flanged.
13. Configuration: Designed for horizontal, straight through flow.
14. Accessories:
  - a. Valves: Outside screw and yoke gate-type with flanged ends on inlet and outlet.

**22 1119 DOMESTIC WATER PIPING SPECIALTIES**  
**PAGE 7**

- b. Air-Gap Fitting: ASME A112.1.2, matching backflow-preventer connection.
- c. Bypass: With displacement-type water meter, shutoff valves, and reduced-pressure backflow preventer.

**F. Double-Check, Detector-Assembly Backflow Preventers:**

- 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
- 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
- 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
  - a. Ames Co.
  - b. Conbraco Industries, Inc.
  - c. FEBCO; SPX Valves & Controls.
  - d. Watts Industries, Inc.; Water Products Div.
  - e. Zurn Plumbing Products Group; Wilkins Div.
- 4. Standard: ASSE 1048 and FMG approved or UL listed.
- 5. Operation: Continuous-pressure applications.
- 6. Pressure Loss: 5 psig (35 kPa) maximum, through middle 1/3 of flow range.
- 7. Size: As Shown.
- 8. Design Flow Rate: As Shown.
- 9. Selected Unit Flow Range Limits: As Shown.
- 10. Pressure Loss at Design Flow Rate: As Shown.
- 11. Body: Cast iron with interior lining complying with AWWA C550 or that is FDA approved.
- 12. End Connections: Flanged.
- 13. Configuration: Designed for horizontal, straight through flow.
- 14. Accessories:
  - a. Valves: Outside screw and yoke gate-type with flanged ends on inlet and outlet.
  - b. Bypass: With displacement-type water meter, shutoff valves, and reduced-pressure backflow preventer.

**G. Hose-Connection Backflow Preventers :**

- 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
- 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Conbraco Industries, Inc.
  - b. Watts Industries, Inc.; Water Products Div.
  - c. Woodford Manufacturing Company.
- 3. Standard: ASSE 1052.
- 4. Operation: Up to 10-foot head of water (30-kPa) back pressure.
- 5. Inlet Size: NPS 1/2 or NPS 3/4 (DN 15 or DN 20).
- 6. Outlet Size: Garden-hose thread complying with ASME B1.20.7.
- 7. Capacity: At least 3-gpm (0.19-L/s) flow.

**22 1119 DOMESTIC WATER PIPING SPECIALTIES**  
**PAGE 8**

H. Backflow-Preventer Test Kits:

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
  - a. Conbraco Industries, Inc.
  - b. FEBCO; SPX Valves & Controls.
  - c. Flomatic Corporation.
  - d. Watts Industries, Inc.; Water Products Div.
  - e. Zurn Plumbing Products Group; Wilkins Div.
4. Description: Factory calibrated, with gages, fittings, hoses, and carrying case with test-procedure instructions.

**2.03 WATER PRESSURE-REDUCING VALVES**

A. Water Regulators:

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Cash Acme.
  - b. Conbraco Industries, Inc.
  - c. Honeywell Water Controls.
  - d. Watts Industries, Inc.; Water Products Div.
  - e. Zurn Plumbing Products Group; Wilkins Div.
3. Standard: ASSE 1003.
4. Pressure Rating: Initial working pressure of 150 psig (1035 kPa).
5. Size: As Shown.
6. Design Flow Rate: As Shown.
7. Design Inlet Pressure: As Shown.
8. Design Outlet Pressure Setting: As Shown.
9. Body: Bronze with chrome-plated finish for NPS 2 (DN 50) and smaller; cast iron with interior lining complying with AWWA C550 or that is FDA approved for NPS 2-1/2 and NPS 3 (DN 65 and DN 80).
10. Valves for Booster Heater Water Supply: Include integral bypass.
11. End Connections: Threaded for NPS 2 (DN 50) and smaller; flanged for NPS 2-1/2 and NPS 3 (DN 65 and DN 80).

B. Water Control Valves:

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:



**22 1119 DOMESTIC WATER PIPING SPECIALTIES**  
**PAGE 9**

2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
  - a. CLA-VAL Automatic Control Valves.
  - b. Flomatic Corporation.
  - c. OCV Control Valves.
  - d. Watts Industries, Inc.; Ames Fluid Control Systems.
  - e. Watts Industries, Inc.; Watts ACV.
  - f. Zurn Plumbing Products Group; Wilkins Div.
4. Description: Pilot-operation, diaphragm-type, single-seated main water control valve.
5. Pressure Rating: Initial working pressure of 150 psig (1035 kPa) minimum with AWWA C550 or FDA-approved, interior epoxy coating. Include small pilot-control valve, restrictor device, specialty fittings, and sensor piping.
6. Main Valve Body: Cast- or ductile-iron body with AWWA C550 or FDA-approved, interior epoxy coating; or stainless-steel body.
  - a. Size: As Shown.
  - b. Pattern: Angle-valve design.
  - c. Trim: Stainless steel.
7. Design Flow: As Shown.
8. Design Inlet Pressure: As Shown.
9. Design Outlet Pressure Setting: As Shown.
10. End Connections: Threaded for NPS 2 (DN 50) and smaller; flanged for NPS 2-1/2 (DN 65) and larger.

**2.04 BALANCING VALVES**

A. Copper-Alloy Calibrated Balancing Valves:

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
  - a. Armstrong International, Inc.
  - b. Flo Fab Inc.
  - c. ITT Industries; Bell & Gossett Div.
  - d. NIBCO INC.
  - e. TAC Americas.
  - f. Taco, Inc.
  - g. Watts Industries, Inc.; Water Products Div.
4. Type: Ball or Y-pattern globe valve with two readout ports and memory setting indicator.
5. Body: Brass or bronze,
6. Size: Same as connected piping, but not larger than NPS 2 (DN 50).
7. Accessories: Meter hoses, fittings, valves, differential pressure meter, and carrying case.

**22 1119 DOMESTIC WATER PIPING SPECIALTIES**  
**PAGE 10**

**B. Cast-Iron Calibrated Balancing Valves :**

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
  - a. Armstrong International, Inc.
  - b. Flo Fab Inc.
  - c. ITT Industries; Bell & Gossett Div.
  - d. NIBCO INC.
  - e. TAC Americas.
  - f. Watts Industries, Inc.; Water Products Div.
4. Type: Adjustable with Y-pattern globe valve, two readout ports, and memory-setting indicator.
5. Size: Same as connected piping, but not smaller than NPS 2-1/2 (DN 65).

**C. Accessories: Meter hoses, fittings, valves, differential pressure meter, and carrying case.**

**D. Memory-Stop Balancing Valves**

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Conbraco Industries, Inc.
  - b. Crane Co.; Crane Valve Group; Crane Valves.
  - c. Crane Co.; Crane Valve Group; Jenkins Valves.
  - d. Crane Co.; Crane Valve Group; Stockham Div.
  - e. Hammond Valve.
  - f. Milwaukee Valve Company.
  - g. NIBCO INC.
  - h. Red-White Valve Corp.
3. Standard: MSS SP-110 for two-piece, copper-alloy ball valves.
4. Pressure Rating: 400-psig (2760-kPa) minimum CWP.
5. Size: NPS 2 (DN 50) or smaller.
6. Body: Copper alloy.
7. Port: Standard or full port.
8. Ball: Chrome-plated brass.
9. Seats and Seals: Replaceable.
10. End Connections: Solder joint or threaded.
11. Handle: Vinyl-covered steel with memory-setting device.

**2.05 TEMPERATURE-ACTUATED WATER MIXING VALVES**

**A. Water-Temperature Limiting Devices**

**22 1119 DOMESTIC WATER PIPING SPECIALTIES**  
**PAGE 11**

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
    - a. Armstrong International, Inc.
    - b. Cash Acme.
    - c. Conbraco Industries, Inc.
    - d. Honeywell Water Controls.
    - e. Legend Valve.
    - f. Leonard Valve Company.
    - g. Powers; a Watts Industries Co.
    - h. Symmons Industries, Inc.
    - i. Taco, Inc.
    - j. Watts Industries, Inc.; Water Products Div.
    - k. Zurn Plumbing Products Group; Wilkins Div.
  4. Standard: ASSE 1017.
  5. Pressure Rating: 125 psig (860 kPa).
  6. Type: Thermostatically controlled water mixing valve.
  7. Material: Bronze body with corrosion-resistant interior components.
  8. Connections: Threaded inlets and outlet.
  9. Accessories: Check stops on hot- and cold-water supplies, and adjustable, temperature-control handle.
  10. Tempered-Water Setting: As Shown.
  11. Tempered-Water Design Flow Rate: As Shown.
  12. Valve Finish: Chrome plated.
- B. Primary, Thermostatic, Water Mixing Valves:
1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
    - a. Armstrong International, Inc.
    - b. Lawler Manufacturing Company, Inc.
    - c. Leonard Valve Company.
    - d. Powers; a Watts Industries Co.
    - e. Symmons Industries, Inc.
  4. Standard: ASSE 1017.
  5. Pressure Rating: 125 psig (860 kPa).
  6. Type: Cabinet-type, thermostatically controlled water mixing valve.
  7. Material: Bronze body with corrosion-resistant interior components.
  8. Connections: Threaded union inlets and outlet.
  9. Accessories: Manual temperature control, check stops on hot- and cold-water supplies, and adjustable, temperature-control handle.

**22 1119 DOMESTIC WATER PIPING SPECIALTIES**  
**PAGE 12**

10. Valve Pressure Rating: 125 psig (860 kPa) minimum, unless otherwise indicated.
11. Tempered-Water Setting: As Shown.
12. Tempered-Water Design Flow Rate: As Shown.
13. Selected Valve Flow Rate at 45-psig (310-kPa) Pressure Drop: As Shown.
14. Pressure Drop at Design Flow Rate: As Shown.
15. Valve Finish: Chrome plated.
16. Piping Finish: Chrome plated.
17. Cabinet: Factory-fabricated, stainless steel, for recessed or surface mounting and with hinged, stainless-steel door.

C. Manifold, Thermostatic, Water-Mixing-Valve Assemblies :

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
  - a. Leonard Valve Company.
  - b. Powers; a Watts Industries Co.
  - c. Symmons Industries, Inc.
4. Description: Factory-fabricated, cabinet-type, thermostatically controlled, water-mixing-valve assembly in three-valve parallel arrangement.
5. Large-Flow Parallel: Thermostatic water mixing valve and downstream pressure regulator with pressure gages on inlet and outlet.
6. Intermediate-Flow Parallel: Thermostatic water mixing valve and downstream pressure regulator with pressure gages on inlet and outlet.
7. Small-Flow Parallel: Thermostatic water mixing valve.
8. Thermostatic Mixing Valves: Comply with ASSE 1017. Include check stops on hot- and cold-water inlets and shutoff valve on outlet.
9. Water Regulator(s): Comply with ASSE 1003. Include pressure gage on inlet and outlet.
10. Component Pressure Ratings: 125 psig (860 kPa) minimum, unless otherwise indicated.
11. Cabinet: Factory-fabricated, stainless steel, for recessed or surface mounting and with hinged, stainless-steel door.
12. Selected Large Flow, Tempered Water Valve Size: As Shown.
13. Tempered-Water Setting: As Shown.
14. Unit Tempered-Water Design Flow Rate: As Shown.
15. Unit Minimum Tempered-Water Design Flow Rate: As Shown.
16. Selected Unit Flow Rate at 45-psig (310-kPa) Pressure Drop As Shown.:
17. Unit Pressure Drop at Design Flow Rate: As Shown.
18. Unit Tempered-Water Outlet Size: As Shown. end connection.
19. Unit Hot- and Cold-Water Inlet Size: As Shown. end connections.
20. Thermostatic Mixing Valve and Water Regulator Finish: Chrome plated.
21. Piping Finish: Chrome plated.

D. Individual-Fixture, Water Tempering Valves :

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:

**22 1119 DOMESTIC WATER PIPING SPECIALTIES**  
**PAGE 13**

2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Cash Acme.
  - b. Conbraco Industries, Inc.
  - c. Honeywell Water Controls.
  - d. Lawler Manufacturing Company, Inc.
  - e. Leonard Valve Company.
  - f. Powers; a Watts Industries Co.
  - g. Watts Industries, Inc.; Water Products Div.
  - h. Zurn Plumbing Products Group; Wilkins Div.
3. Standard: ASSE 1016, thermostatically controlled water tempering valve.
4. Pressure Rating: 125 psig (860 kPa) minimum, unless otherwise indicated.
5. Body: Bronze body with corrosion-resistant interior components.
6. Temperature Control: Adjustable.
7. Inlets and Outlet: Threaded.
8. Finish: Rough or chrome-plated bronze.
9. Tempered-Water Setting: As Shown.
10. Tempered-Water Design Flow Rate: As Shown.

**E. Primary Water Tempering Valves :**

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Heat-Timer Corporation.
  - b. Holby Valve Co., Inc.
3. Standard: ASSE 1017, thermostatically controlled tempering valve, listed as tempering valve.
4. Pressure Rating: 125 psig (860 kPa) minimum, unless otherwise indicated.
5. Body: Bronze.
6. Temperature Control: Manual.
7. Inlets and Outlet: Threaded. As Shown.
8. Selected Primary Water Tempering Valve Size As Shown.:
9. Tempered-Water Setting: As Shown.
10. Tempered-Water Design Flow Rate: As Shown.
11. Pressure Drop at Design Flow Rate: As Shown.
12. Tempered-Water Outlet Size: end connection. As Shown.
13. Cold-Water Inlet Size: As Shown. end connection.
14. Hot-Water Inlet Size: As Shown. end connection.
15. Valve Finish: Rough bronze.

**2.06 STRAINERS FOR DOMESTIC WATER PIPING**

**A. Y-Pattern Strainers :**

1. Pressure Rating: 125 psig (860 kPa) minimum, unless otherwise indicated.

**22 1119 DOMESTIC WATER PIPING SPECIALTIES**  
**PAGE 14**

2. Body: Bronze for NPS 2 (DN 50) and smaller; cast iron with interior lining complying with AWWA C550 or FDA-approved, epoxy coating and for NPS 2-1/2 (DN 65) and larger.
3. End Connections: Threaded for NPS 2 (DN 50) and smaller; flanged for NPS 2-1/2 (DN 65) and larger.
4. Screen: Stainless steel with round perforations, unless otherwise indicated.
5. Perforation Size:
  - a. Strainers NPS 2 (DN 50) and Smaller: 0.020 inch (0.51 mm).
  - b. Strainers NPS 2-1/2 to NPS 4 (DN 65 to DN 100): 0.045 inch (1.14 mm)
  - c. Strainers NPS 5 (DN 125) and Larger: 0.10 inch (2.54 mm).
6. Drain: Factory-installed, hose-end drain valve.

**2.07 OUTLET BOXES**

**A. Clothes Washer Outlet Boxes :**

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Acorn Engineering Company.
  - b. Guy Gray Manufacturing Co., Inc.
  - c. IPS Corporation.
  - d. LSP Products Group, Inc.
  - e. Oatey.
  - f. Plastic Oddities; a division of Diverse Corporate Technologies.
  - g. Symmons Industries, Inc.
  - h. Watts Industries, Inc.; Water Products Div.
  - i. Whitehall Manufacturing; a div. of Acorn Engineering Company.
  - j. Zurn Plumbing Products Group; Light Commercial Operation.
3. Mounting: Recessed.
4. Material and Finish: Enameled-steel or epoxy-painted-steel or plastic box and faceplate.
5. Faucet: Combination, valved fitting or separate hot- and cold-water, valved fittings complying with ASME A112.18.1. Include garden-hose thread complying with ASME B1.20.7 on outlets.
6. Supply Shutoff Fittings: NPS 1/2 (DN 15) gate, globe, or ball valves and NPS 1/2 (DN 15) copper, water tubing.
7. Drain: NPS 2 (DN 50) standpipe and P-trap for direct waste connection to drainage piping.
8. Inlet Hoses: Two 60-inch- (1500-mm-) long, rubber household clothes washer inlet hoses with female, garden-hose-thread couplings. Include rubber washers.
9. Drain Hose: One 48-inch- (1200-mm-) long, rubber household clothes washer drain hose with hooked end.

**B. Icemaker Outlet Boxes:**

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:

**22 1119 DOMESTIC WATER PIPING SPECIALTIES**  
**PAGE 15**

2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Acorn Engineering Company.
  - b. IPS Corporation.
  - c. LSP Products Group, Inc.
  - d. Oatey.
  - e. Plastic Oddities; a division of Diverse Corporate Technologies.
3. Mounting: Recessed.
4. Material and Finish: Enameled-steel or epoxy-painted-steel or plastic box and faceplate.
5. Faucet: Valved fitting complying with ASME A112.18.1. Include NPS 1/2 (DN 15) or smaller copper tube outlet.
6. Supply Shutoff Fitting: NPS 1/2 (DN 15) gate, globe, or ball valve and NPS 1/2 (DN 15) copper, water tubing.

**2.08 HOSE BIBBS**

A. Hose Bibbs :

1. Standard: ASME A112.18.1 for sediment faucets.
2. Body Material: Bronze.
3. Seat: Bronze, replaceable.
4. Supply Connections: NPS 1/2 or NPS 3/4 (DN 15 or DN 20) threaded or solder-joint inlet.
5. Outlet Connection: Garden-hose thread complying with ASME B1.20.7.
6. Pressure Rating: 125 psig (860 kPa).
7. Vacuum Breaker: Integral or field-installation, nonremovable, drainable, hose-connection vacuum breaker complying with ASSE 1011.
8. Finish for Equipment Rooms: Rough bronze, or chrome or nickel plated.
9. Finish for Service Areas: Rough bronze.
10. Finish for Finished Rooms: Chrome or nickel plated.
11. Operation for Equipment Rooms: Wheel handle or operating key.
12. Operation for Service Areas: Wheel handle.
13. Operation for Finished Rooms: Wheel handle.
14. Include operating key with each operating-key hose bibb.
15. Include integral wall flange with each chrome- or nickel-plated hose bibb.

**2.09 WALL HYDRANTS**

A. Nonfreeze Wall Hydrants:

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Josam Company.
  - b. MIFAB, Inc.
  - c. Prier Products, Inc.
  - d. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.

**22 1119 DOMESTIC WATER PIPING SPECIALTIES**  
**PAGE 16**

- e. Tyler Pipe; Wade Div.
  - f. Watts Drainage Products Inc.
  - g. Woodford Manufacturing Company.
  - h. Zurn Plumbing Products Group; Light Commercial Operation.
  - i. Zurn Plumbing Products Group; Specification Drainage Operation.
- 3. Standard: ASME A112.21.3M for concealed-outlet, self-draining wall hydrants.
  - 4. Pressure Rating: 125 psig (860 kPa).
  - 5. Operation: Loose key.
  - 6. Casing and Operating Rod: Of length required to match wall thickness. Include wall clamp.
  - 7. Inlet: NPS 3/4 or NPS 1 (DN 20 or DN 25).
  - 8. Outlet: Concealed, with integral vacuum breaker and garden-hose thread complying with ASME B1.20.7.
  - 9. Box: Deep, flush mounting with cover.
  - 10. Box and Cover Finish: Polished nickel bronze.
  - 11. Outlet: Exposed, with integral vacuum breaker and garden-hose thread complying with ASME B1.20.7.
  - 12. Nozzle and Wall-Plate Finish: Polished nickel bronze.
  - 13. Operating Keys(s): Two with each wall hydrant.

**B. Vacuum Breaker Wall Hydrants :**

- 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Arrowhead Brass Products, Inc.
    - b. Mansfield Plumbing Products LLC.
    - c. McDonald, A. Y. Mfg. Co.
    - d. Prier Products, Inc.
    - e. Smith, Jay. R. Mfg. Co.; Division of Smith Industries, Inc.
    - f. Watts Industries, Inc.; Water Products Div.
    - g. Woodford Manufacturing Company.
    - h. Zurn Plumbing Products Group; Light Commercial Operation.
- 3. Standard: ASSE 1019, Type A or Type B.
  - 4. Type: Freeze-resistant, automatic draining with integral air-inlet valve.
  - 5. Classification: Type B, for automatic draining with hose removed or with hose attached and nozzle closed.
  - 6. Pressure Rating: 125 psig (860 kPa).
  - 7. Operation: Loose key or wheel handle.
  - 8. Casing and Operating Rod: Of length required to match wall thickness. Include wall clamp.
  - 9. Inlet: NPS 1/2 or NPS 3/4 (DN 15 or DN 20).
  - 10. Outlet: Exposed with garden-hose thread complying with ASME B1.20.7.

**2.10 DRAIN VALVES**

**A. Ball-Valve-Type, Hose-End Drain Valves:**



**22 1119 DOMESTIC WATER PIPING SPECIALTIES**  
**PAGE 17**

1. Standard: MSS SP-110 for standard-port, two-piece ball valves.
2. Pressure Rating: 400-psig (2760-kPa) minimum CWP.
3. Size: NPS 3/4 (DN 20).
4. Body: Copper alloy.
5. Ball: Chrome-plated brass.
6. Seats and Seals: Replaceable.
7. Handle: Vinyl-covered steel.
8. Inlet: Threaded or solder joint.
9. Outlet: Threaded, short nipple with garden-hose thread complying with ASME B1.20.7 and cap with brass chain.

**B. Gate-Valve-Type, Hose-End Drain Valves:**

1. Standard: MSS SP-80 for gate valves.
2. Pressure Rating: Class 125.
3. Size: NPS 3/4 (DN 20).
4. Body: ASTM B 62 bronze.
5. Inlet: NPS 3/4 (DN 20) threaded or solder joint.
6. Outlet: Garden-hose thread complying with ASME B1.20.7 and cap with brass chain.

**C. Stop-and-Waste Drain Valves :**

1. Standard: MSS SP-110 for ball valves or MSS SP-80 for gate valves.
2. Pressure Rating: 200-psig (1380-kPa) minimum CWP or Class 125.
3. Size: NPS 3/4 (DN 20).
4. Body: Copper alloy or ASTM B 62 bronze.
5. Drain: NPS 1/8 (DN 6) side outlet with cap.

**2.11 WATER HAMMER ARRESTERS**

**A. Water Hammer Arresters :**

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. AMTROL, Inc.
  - b. Josam Company.
  - c. MIFAB, Inc.
  - d. PPP Inc.
  - e. Sioux Chief Manufacturing Company, Inc.
  - f. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.
  - g. Tyler Pipe; Wade Div.
  - h. Watts Drainage Products Inc.
  - i. Zurn Plumbing Products Group; Specification Drainage Operation.
3. Standard: ASSE 1010 or PDI-WH 201.
4. Type: Copper tube with piston.
5. Size: ASSE 1010, Sizes AA and A through F or PDI-WH 201, Sizes A through F.

**2.12 AIR VENTS**

A. Bolted-Construction Automatic Air Vents :

1. Body: Bronze.
2. Pressure Rating: 125-psig (860-kPa) minimum pressure rating at 140 deg F (60 deg C).
3. Float: Replaceable, corrosion-resistant metal.
4. Mechanism and Seat: Stainless steel.
5. Size: NPS 1/2 (DN 15) minimum inlet.
6. Inlet and Vent Outlet End Connections: Threaded.

B. Welded-Construction Automatic Air Vents:

1. Body: Stainless steel.
2. Pressure Rating: 150-psig (1035-kPa) minimum pressure rating.
3. Float: Replaceable, corrosion-resistant metal.
4. Mechanism and Seat: Stainless steel.
5. Size: NPS 3/8 (DN 10) minimum inlet.
6. Inlet and Vent Outlet End Connections: Threaded.

**2.13 TRAP-SEAL PRIMER VALVES**

A. Supply-Type, Trap-Seal Primer Valves:

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. MIFAB, Inc.
  - b. PPP Inc.
  - c. Sioux Chief Manufacturing Company, Inc.
  - d. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.
  - e. Watts Industries, Inc.; Water Products Div.
3. Standard: ASSE 1018.
4. Pressure Rating: 125 psig (860 kPa) minimum.
5. Body: Bronze.
6. Inlet and Outlet Connections: NPS 1/2 (DN 15) threaded, union, or solder joint.
7. Gravity Drain Outlet Connection: NPS 1/2 (DN 15) threaded or solder joint.
8. Finish: Chrome plated, or rough bronze for units used with pipe or tube that is not chrome finished.

B. Drainage-Type, Trap-Seal Primer Valves:

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.

**22 1119 DOMESTIC WATER PIPING SPECIALTIES**  
**PAGE 19**

3. Standard: ASSE 1044, lavatory P-trap with NPS 3/8 (DN 10) minimum, trap makeup connection.
4. Size: NPS 1-1/4 (DN 32) minimum.
5. Material: Chrome-plated, cast brass.

**2.14 TRAP-SEAL PRIMER SYSTEMS**

A. Trap-Seal Primer Systems :

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
  - a. PPP Inc.
4. Standard: ASSE 1044,
5. Piping: NPS 3/4, ASTM B 88, Type L (DN 20, ASTM B 88M, Type B); copper, water tubing.
6. Cabinet: Recessed or Surface-mounting steel box with stainless-steel cover.
7. Electric Controls: 24-hour timer, solenoid valve, and manual switch for 120-V ac power.
8. Vacuum Breaker: ASSE 1001.
9. Number Outlets: As Shown.
10. Size Outlets: NPS 1/2 (DN 15).

**PART 3 - EXECUTION**

**3.01 INSTALLATION**

- A. Refer to Division 22 Section "Common Work Results for Plumbing" for piping joining materials, joint construction, and basic installation requirements.
- B. Install backflow preventers in each water supply to mechanical equipment and systems and to other equipment and water systems that may be sources of contamination. Comply with authorities having jurisdiction.
  1. Locate backflow preventers in same room as connected equipment or system.
  2. Install drain for backflow preventers with atmospheric-vent drain connection with air-gap fitting, fixed air-gap fitting, or equivalent positive pipe separation of at least two pipe diameters in drain piping and pipe to floor drain. Locate air-gap device attached to or under backflow preventer. Simple air breaks are not acceptable for this application.
  3. Do not install bypass piping around backflow preventers.
- C. Install water regulators with inlet and outlet shutoff valves and bypass with memory-stop balancing valve. Install pressure gages on inlet and outlet.
- D. Install water control valves with inlet and outlet shutoff valves and bypass with globe valve. Install pressure gages on inlet and outlet.

**22 1119 DOMESTIC WATER PIPING SPECIALTIES**  
**PAGE 20**

- E. Install balancing valves in locations where they can easily be adjusted.
- F. Install temperature-actuated water mixing valves with check stops or shutoff valves on inlets and with shutoff valve on outlet.
  - 1. Install thermometers and water regulators if specified.
  - 2. Install cabinet-type units recessed in or surface mounted on wall as specified.
- G. Install Y-pattern strainers for water on supply side of each control valve.
- H. Install outlet boxes recessed in wall. Install 2-by-4-inch (38-by-89-mm) fire-retardant-treated-wood blocking wall reinforcement between studs. Fire-retardant-treated-wood blocking is specified in Division 06 Section "Rough Carpentry."
- I. Install water hammer arresters in water piping according to PDI-WH 201.
- J. Install air vents at high points of water piping. Install drain piping and discharge onto floor drain.
- K. Install supply-type, trap-seal primer valves with outlet piping pitched down toward drain trap a minimum of 1 percent, and connect to floor-drain body, trap, or inlet fitting. Adjust valve for proper flow.
- L. Install drainage-type, trap-seal primer valves as lavatory trap with outlet piping pitched down toward drain trap a minimum of 1 percent, and connect to floor-drain body, trap, or inlet fitting.
- M. Install trap-seal primer systems with outlet piping pitched down toward drain trap a minimum of 1 percent, and connect to floor-drain body, trap, or inlet fitting. Adjust system for proper flow.

**3.02 CONNECTIONS**

- A. Piping installation requirements are specified in other Division 22 Sections. Drawings indicate general arrangement of piping and specialties.
- B. Ground equipment according to Division 26 Section "Grounding and Bonding for Electrical Systems."
- C. Connect wiring according to Division 26 Section "Low-Voltage Electrical Power Conductors and Cables."

**3.03 LABELING AND IDENTIFYING**

- A. Equipment Nameplates and Signs: Install engraved plastic-laminate equipment nameplate or sign on or near each of the following:
  - 1. Pressure vacuum breakers.
  - 2. Intermediate atmospheric-vent backflow preventers.
  - 3. Reduced-pressure-principle backflow preventers.
  - 4. Double-check backflow-prevention assemblies.
  - 5. Dual-check-valve backflow preventers.
  - 6. Reduced-pressure-detector, fire-protection backflow-preventer assemblies.
  - 7. Double-check, detector-assembly backflow preventers.
  - 8. Water pressure-reducing valves.

**22 1119 DOMESTIC WATER PIPING SPECIALTIES**  
**PAGE 21**

9. Calibrated balancing valves.
  10. Primary, thermostatic, water mixing valves.
  11. Manifold, thermostatic, water-mixing-valve assemblies.
  12. Primary water tempering valves.
  13. Outlet boxes.
  14. Supply-type, trap-seal primer valves.
  15. Trap-seal primer systems.
- B. Distinguish among multiple units, inform operator of operational requirements, indicate safety and emergency precautions, and warn of hazards and improper operations, in addition to identifying unit. Nameplates and signs are specified in Division 22 Section "Identification for Plumbing Piping and Equipment."

**3.04 FIELD QUALITY CONTROL**

- A. Perform the following tests and prepare test reports:
1. Test each device according to authorities having jurisdiction and the device's reference standard.
- B. Remove and replace malfunctioning domestic water piping specialties and retest as specified above.

**3.5 ADJUSTING**

- A. Set field-adjustable pressure set points of water pressure-reducing valves.
- B. Set field-adjustable flow set points of balancing valves.
- C. Set field-adjustable temperature set points of temperature-actuated water mixing valves.

**\*\* END OF SECTION \*\***