

22 4500 EMERGENCY PLUMBING FIXTURES
PAGE 1

PART 1 - GENERAL

1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.02 SUMMARY

- A. Section Includes:
 - 1. Eyewash equipment.
 - 2. Supplemental equipment.
 - 3. Water-tempering equipment.

1.03 DEFINITIONS

- A. Accessible Fixture: Emergency plumbing fixture that can be approached, entered, and used by people with disabilities.
- B. Plumbed Emergency Plumbing Fixture: Fixture with fixed, potable-water supply.
- C. Self-Contained Emergency Plumbing Fixture: Fixture with flushing-fluid-solution supply.
- D. Tepid: Moderately warm.

1.04 SUBMITTALS

- A. Product Data: For each type of product indicated. Include flow rates and capacities, furnished specialties, and accessories.
- B. Shop Drawings: Diagram power, signal, and control wiring.
- C. Product Certificates: Submit certificates of performance testing specified in "Source Quality Control" Article.
- D. Field quality-control test reports.
- E. Operation and Maintenance Data: For emergency plumbing fixtures to include in operation and maintenance manuals.

1.05 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. ANSI Standard: Comply with ANSI Z358.1, "Emergency Eyewash and Shower Equipment."

22 4500 EMERGENCY PLUMBING FIXTURES
PAGE 2

- C. NSF Standard: Comply with NSF 61, "Drinking Water System Components - Health Effects," for fixture materials that will be in contact with potable water.
- D. Regulatory Requirements: Comply with requirements in ICC/ANSI A117.1, "Accessible and Usable Buildings and Facilities"; Public Law 90-480, "Architectural Barriers Act"; and Public Law 101-336, "Americans with Disabilities Act"; for plumbing fixtures for people with disabilities.

1.06 EXTRA MATERIALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
 - 1. Flushing-Fluid Solution: Separate lot and equal to at least 200 percent of amount of solution installed for each self-contained unit.

PART 2 - PRODUCTS

- A. Accessible, Wall-Mounted, Plumbed Eyewash Units :
 - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - 2. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following:
 - a. Acorn Safety; a division of Acorn Engineering Company.
 - b. Bradley Corporation.
 - c. Encon Safety Products.
 - d. Guardian Equipment Co.
 - e. Haws Corporation.
 - f. Speakman Company.
 - 3. Capacity: Not less than 0.4 gpm (1.5 L/min.) for at least 15 minutes.
 - 4. Supply Piping: NPS 1/2 (DN 15) chrome-plated brass or stainless steel with flow regulator and stay-open control valve.
 - 5. Control-Valve Actuator: Paddle.
 - 6. Spray-Head Assembly: Two receptor-mounted spray heads.
 - 7. Receptor: Chrome-plated brass or stainless-steel bowl.
 - 8. Drain Piping: NPS 1-1/4 (DN 32) minimum, chrome-plated brass, receptor drain, P-trap, waste to wall, and wall flange complying with ASME A112.18.2/CSA B125.2.
 - 9. Mounting: Wall bracket.
 - 10. Special Construction: Comply with ICC/ANSI A117.1.
- B. Sink, Fixed-Position, Plumbed Eyewash Unit, :
 - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - 2. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following:

22 4500 EMERGENCY PLUMBING FIXTURES
PAGE 3

- a. Acorn Safety; a division of Acorn Engineering Company.
 - b. Bradley Corporation.
 - c. Encon Safety Products.
 - d. Guardian Equipment Co.
 - e. Haws Corporation.
 - f. Sellstrom Manufacturing Company.
 - g. Speakman Company.
 - h. WaterSaver Faucet Co.
3. Capacity: Not less than 0.4 gpm (1.5 L/min.) for at least 15 minutes.
 4. Supply Piping: NPS 1/2 (DN 15) chrome-plated brass or stainless steel with flow regulator and stay-open control valve.
 5. Control-Valve Actuator: Paddle.
 6. Spray-Head Assembly: Two spray heads positioned over sink.
 7. Mounting: Attached to sink receptor.

2.01 SUPPLEMENTAL EQUIPMENT

A. Wall-Mounted, Plumbed Drench Hoses, :

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following:
 - a. Acorn Safety; a division of Acorn Engineering Company.
 - b. Bradley Corporation.
 - c. Encon Safety Products.
 - d. Guardian Equipment Co.
 - e. Haws Corporation.
 - f. Sellstrom Manufacturing Company.
 - g. Speakman Company.
 - h. WaterSaver Faucet Co.
3. Capacity: Not less than 3.0 gpm (11.4 L/min.) for at least 15 minutes.
4. Supply Fitting: NPS 1/2 (DN 15) brass with flow regulator.
5. Drench Hose: Hand-held spray head with squeeze-handle actuation and hose.
6. Mounting: Wall bracket.

2.02 WATER-TEMPERING EQUIPMENT

A. Hot- and Cold-Water, Water-Tempering Equipment, :

1. Manufacturers: Subject to compliance with requirements, [available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following:
 - a. Acorn Safety; a division of Acorn Engineering Company.
 - b. Armstrong International, Inc.
 - c. Bradley Corporation.

22 4500 EMERGENCY PLUMBING FIXTURES
PAGE 4

- d. Encon Safety Products.
- e. Guardian Equipment Co.
- f. Haws Corporation.
- g. Lawler Manufacturing Co., Inc.
- h. Leonard Valve Company.
- i. Powers; a division of Watts Water Technologies, Inc.
- j. Speakman Company.

3. Description: Factory-fabricated equipment with thermostatic mixing valve.

- a. Thermostatic Mixing Valve: Designed to provide 85 deg F (29 deg C) tepid, potable water at emergency plumbing fixtures, to maintain temperature at plus or minus 5 deg F (3 deg C) throughout required 15-minute test period, and in case of unit failure to continue cold-water flow, with union connections, controls, metal piping, and corrosion-resistant enclosure.
- b. Supply Connections: For hot and cold water.

2.03 SOURCE QUALITY CONTROL

- A. Certify performance of emergency plumbing fixtures by independent testing organization acceptable to authorities having jurisdiction.

PART 3 - EXECUTION

3.01 EXAMINATION

- A. Examine roughing-in for water and waste piping systems to verify actual locations of piping connections before plumbed emergency plumbing fixture installation.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.02 EMERGENCY PLUMBING FIXTURE INSTALLATION

- A. Assemble emergency plumbing fixture piping, fittings, control valves, and other components.
- B. Install fixtures level and plumb.
- C. Fasten fixtures to substrate.
- D. Install shutoff valves in water-supply piping to fixtures. Use ball, gate, or globe valve if specific type valve is not indicated. Install valves chained or locked in open position if permitted. Install valves in locations where they can easily be reached for operation. Comply with requirements for valves specified in Division 22 Section "General-Duty Valves for Plumbing Piping."
 - 1. Exception: Omit shutoff valve on supply to group of plumbing fixtures that includes emergency equipment.
 - 2. Exception: Omit shutoff valve on supply to emergency equipment if prohibited by authorities having jurisdiction.

22 4500 EMERGENCY PLUMBING FIXTURES
PAGE 5

- E. Install shutoff valve and strainer in steam piping and shutoff valve in condensate return piping. Comply with requirements for steam and condensate piping specified in Division 23 Section "Steam and Condensate Heating Piping."
- F. Install dielectric fitting in supply piping to emergency equipment if piping and equipment connections are made of different metals. Comply with requirements for dielectric fittings specified in Division 22 Section "Domestic Water Piping."
- G. Install thermometers in supply and outlet piping connections to water-tempering equipment. Comply with requirements for thermometers specified in Division 22 Section "Meters and Gages for Plumbing Piping."
- H. Install trap and waste piping on drain outlet of emergency equipment receptors that are indicated to be directly connected to drainage system. Comply with requirements for waste piping specified in Division 22 Section "Sanitary Waste and Vent Piping."
- I. Install indirect waste piping on drain outlet of emergency equipment receptors that are indicated to be indirectly connected to drainage system. Comply with requirements for waste piping specified in Division 22 Section "Sanitary Waste and Vent Piping."
- J. Install escutcheons on piping wall and ceiling penetrations in exposed, finished locations. Comply with requirements for escutcheons specified in Division 22 Section "Escutcheons for Plumbing Piping."
- K. Fill self-contained fixtures with flushing fluid.

3.03 CONNECTIONS

- A. Connect cold-water-supply piping to plumbed emergency plumbing fixtures not having water-tempering equipment. Comply with requirements for cold-water piping specified in Division 22 Section "Domestic Water Piping."
- B. Connect hot- and cold-water-supply piping to hot- and cold-water, water-tempering equipment. Connect output from water-tempering equipment to emergency plumbing fixtures. Comply with requirements for hot- and cold-water piping specified in Division 22 Section "Domestic Water Piping."
- C. Directly connect emergency plumbing fixture receptors with trapped drain outlet to sanitary waste and vent piping. Comply with requirements for waste piping specified in Division 22 Section "Sanitary Waste and Vent Piping."
- D. Indirectly connect emergency plumbing fixture receptors without trapped drain outlet to sanitary waste or storm drainage piping.
- E. Where installing piping adjacent to emergency plumbing fixtures, allow space for service and maintenance of fixtures.

3.04 IDENTIFICATION

- A. Install equipment nameplates or equipment markers on emergency plumbing fixtures and equipment and equipment signs on water-tempering equipment. Comply with requirements for identification materials specified in Division 22 Section "Identification for Plumbing Piping and Equipment."

3.05 FIELD QUALITY CONTROL

- A. Mechanical-Component Testing: After plumbing connections have been made, test for compliance with requirements. Verify ability to achieve indicated capacities.
- B. Tests and Inspections:
 - 1. Perform each visual and mechanical inspection.
 - 2. Leak Test: After installation, charge system and test for leaks. Repair leaks and retest until no leaks exist.
 - 3. Operational Test: After electrical circuitry has been energized, start units to confirm proper unit operation.
 - 4. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- C. Emergency plumbing fixtures and water-tempering equipment will be considered defective if they do not pass tests and inspections.
- D. Prepare test and inspection reports.

3.06 ADJUSTING

- A. Adjust or replace fixture flow regulators for proper flow.
- B. Adjust equipment temperature settings.

****END OF SECTION****