

SYMBOL KEY $\times \times \times \times$ EXISTING PIPING TO BE REMOVED NEW PIPING 1" ARM-OVER TO NEW SPRINKLER FROM EXISTING 1" OUTLET CONNECT TO EXISTING PIPE AND/OR FITTING EXISTING SPRINKLER AND ARM-OVER TO BE DEMOLISHED BACK TO OUTLET ON BRANCH LINE UNLESS SHOWN OTHERWISE ORD/5.6/SR ORD/5.6/SR ORD/5.6/QR NEW DRY CHROME PENDENT ON 2-PIECE INT/5.6/QR TELESCOPING ESCUTCHEON WITH FREEZER APPROXIMATE CENTER LINE ELEVATION OF EXISTING PIPE ABOVE RECOMMENDED CENTER LINE ELEVATION OF NEW RISE FROM LEFT TO RIGHT AND DROP FROM RIGHT TO LEFT

SEE SHEET FP2 FOR NOTES, DETAILS, AND SPECIFICATION

ALL ARM-OVERS TO NEW SPRINKLERS ARE 1" DIAMETER

3216 MV MV

Architects Incorporated Architecture & Interior Design 7 Kimball Lane Suite E6 Lynnfield MA 01940 p: 781.397.8092 f: 781.397.8094 www.deanassoc.com

Dean Associates

ENGINEER OF RECORD JAMES L. KINSLOHR, PE LICENSE NO. 103971 CODE CONSULTANTS
PROFESSIONAL ENGINEERS, PC
215 WEST 40TH ST., 10TH FLOOR
NEW YORK, NY 10018
PHONE: 212-216-9596
CORPORATE CERTIFICATE OF AUTHORITY WARNING: IT IS A VIOLATION OF THE NEW YORK STATE EDUCATION LAW, ARTICLE 145, SECTION 7209 FOR ANY PERSON, UNLESS ACTING UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER, TO ALTER THIS DOCUMENT IN ANY WAY.

FP1