

BID ADDENDUM NO. 3

Date of Addendum: January 3, 2022
Issued for Bid Date: December 10, 2021
Client Name: Eastchester Union Free School District
Project Name: 2021-2022 Middle School Gymnasium Renovations and Roof Replacements
SED Project No.: Eastchester High School: 66-03-01-03-0-003-028
MEMASI Project No.: 102-2101
Contracts: Contract 1: General Construction Contract
Contract 2: Mechanical Contract
Contract 3: Electrical Contract

This Bid Addendum forms part of the Contract Documents and modifies the original Issued for Bid Documents dated December 10, 2021. Where provisions of the following supplementary information differ from those of the original Bid Documents, this Addendum shall govern and take precedence.

The Bid Documents are modified and clarified as follows:

Not Used.

Attachements:**Responses to RFI's:**

Jennings Co, Inc RFI #1
Jennings Co, Inc RFI #3

Specifications:

Not Used.

Drawings:

Not Used

END OF BID ADDENDUM NO. 3



AIA[®] Document G716[™] – 2004

Request for Information (“RFI”)

TO:
MEMASI
2 Lyon Place
White Plains, NY 10601

FROM: Jennings Construction

PROJECT:
2021-2022 Middle School Gymnasiums Renovations
and Middle School Roof Replacements Project
Eastchester Union Free School District
Eastchester Middle School
550 White Plains Road
Eastchester, New York 10709

ISSUE DATE: 12/28/2021 **RFI No.** 1

PROJECT NUMBERS: MEMASI / 102-2101

REQUESTED REPLY DATE:
COPIES TO:

RFI DESCRIPTION: *(Fully describe the question or type of information requested.)*

Please confirm that the specification for the wall pads will meet the impact rating specified

REFERENCES/ATTACHMENTS: *(List specific documents researched when seeking the information requested.)*

SPECIFICATIONS: 116623.53

DRAWINGS:

OTHER:

SENDER'S RECOMMENDATION: *(If RFI concerns a site or construction condition, the sender may provide a recommended solution, including cost and/or schedule considerations.)*

RECEIVER'S REPLY: *(Provide answer to RFI, including cost and/or schedule considerations.)*

Provide a 2" thick XX-Firm High Impact Fire Resistant Foam with a density of 5.5pcf to 7.0pcf. This is an acceptable range for foam density for wall mats in a middle school gym per the manufacturer.

MEMASI
BY

01/03/2022
DATE

COPIES TO

Note: This reply is not an authorization to proceed with work involving additional cost, time or both. If any reply requires a change to the Contract Documents, a Change Order, Construction Change Directive or a Minor Change in the work must be executed in accordance with the Contract Documents.



AIA[®] Document G716[™] – 2004

Request for Information (“RFI”)

TO:
MEMASI
2 Lyon Place
White Plains, NY 10601

FROM: Jennings Construction

PROJECT:
2021-2022 Middle School Gymnasiums Renovations
and Middle School Roof Replacements Project
Eastchester Union Free School District
Eastchester Middle School
550 White Plains Road
Eastchester, New York 10709

ISSUE DATE: 12/30/2021 **RFI No.** 3

PROJECT NUMBERS: MEMASI / 102-2101

REQUESTED REPLY DATE:
COPIES TO:

RFI DESCRIPTION: *(Fully describe the question or type of information requested.)*

- Please confirm who is responsible for the installation of the Roof Drains.

REFERENCES/ATTACHMENTS: *(List specific documents researched when seeking the information requested.)*

SPECIFICATIONS:

DRAWINGS: A-102

OTHER:

SENDER'S RECOMMENDATION: *(If RFI concerns a site or construction condition, the sender may provide a recommended solution, including cost and/or schedule considerations.)*

RECEIVER'S REPLY: *(Provide answer to RFI, including cost and/or schedule considerations.)*

See Addendum #1.

MEMASI

BY

01.03.2022

DATE

COPIES TO

Note: This reply is not an authorization to proceed with work involving additional cost, time or both. If any reply requires a change to the Contract Documents, a Change Order, Construction Change Directive or a Minor Change in the work must be executed in accordance with the Contract Documents.