



1 ELECTRICAL DEMOLITION SITE PART PLAN
SCALE: 1" = 10'-0"


Rockland County
Facilities Management
Robert H. Gruffi, P.E., LEED AP
Director Facilities Management
Dr. Robert L. Yeager Health Center
50 Sanatorium Road
Building A, 2nd Floor
Pomona, NY 10970

OLA Consulting Engineers
50 Broadway
Hawthorne, NY 10532
914.747.2800
8 West 38th Street,
Suite 501
New York, NY 10018
646.849.4110
olace.com

BROOKER ENGINEERING, PLLC
74 Lafayette Avenue, Suite 501
Suffern, NY 10901
945.357.4411
brookerengineering.com

QuES&T
Quality Environmental Solutions & Technologies, Inc.
1376 Route 9, Wappingers
Falls, NY 12590
845.298.6031
qualityenv.com

DACK
CONSULTING SOLUTIONS, INC.
2 William St, suite 202
White Plains, NY 10601
914.686.7102
dackconsulting.com



2	RE-ISSUED FOR BID	07/24/2022
1	ISSUED FOR BID	11/01/2021
NO.	DESCRIPTION	DATE

No use, reproduction or dissemination may be made of this drawing and the concepts set forth without the prior written consent of OLA Consulting Engineers, P.C. Copyright © 2021.

PROJECT
CAPITAL PROJECT 4466
BUILDING E UTILITY PLANT
RENOVATION & IMPROVEMENTS
DR. ROBERT L. YEAGER HEALTH CENTER
50 SANATORIUM ROAD,
POMONA, NY 10970

DRAWING TITLE
ELECTRICAL DEMO & TEMP
WORK SITE PART PLAN

SEAL	SCALE AS NOTED	PROJECT NO. NRCK0016.00
DRAWN BY VB	DRAWING NO.	
CHECKED BY ML		E0.2
DATE 04-28-2020		



1


ELECTRICAL SITE PART PLAN

SCALE: 1" = 10'-0"

CLIENT

Rockland County
Facilities Management
Robert H. Gruffi, P.E., LEED AP
Director Facilities Management
Dr. Robert L. Yeager Health Center
50 Sanatorium Road
Building A, 2nd Floor
Pomona, NY 10970

MEP ENGINEER



OLA Consulting Engineers
50 Broadway
Hawthorne, NY 10532
914.747.2800
8 West 38th Street,
Suite 501
New York, NY 10018
646.849.4110
olace.com

STRUCTURAL ENGINEER



BROOKER ENGINEERING, PLLC
74 Lafayette Avenue, Suite 501
Suffern, NY 10901
945.357.4411
brookerengineering.com

ASBESTOS ABATEMENT

QuES&T
Quality Environmental Solutions & Technologies, Inc.
1376 Route 9, Wappingers
Falls, NY 12590
845.298.6031
qualityenv.com

ESTIMATING

DACK
CONSULTING SOLUTIONS, INC.
2 William St, suite 202
White Plains, NY 10601
914.686.7102
dackconsulting.com

KEYPLAN

CAMPUS - KEYPLAN

2	RE-ISSUED FOR BID	07/24/2022
1	ISSUED FOR BID	11/01/2021
NO.	DESCRIPTION	DATE

No use, reproduction or dissemination may be made of this drawing and the concepts set forth without the prior written consent of OLA Consulting Engineers, P.C. Copyright © 2021.


PROJECT
CAPITAL PROJECT 4466
BUILDING E UTILITY PLANT
RENOVATION & IMPROVEMENTS
DR. ROBERT L. YEAGER HEALTH CENTER
50 SANATORIUM ROAD,
POMONA, NY 10970

DRAWING TITLE

**ELECTRICAL SITE PART PLAN
- POWER**

SEAL	SCALE AS NOTED	PROJECT NO. NRCK0016.00
DRAWN BY VB	DRAWING NO.	
CHECKED BY ML		E0.3
DATE 04-28-2020		

MATCH LINE -
SEE DRAWING
E3.3 FOR
CONTINUATION



ELECTRICAL PHASING CONCEPT NOTES

1. INSTALL THE NEW GENERATOR OUTSIDE OF THE BUILDING AND MAKE OPERATIONAL.
2. REMOVE EXISTING GENERATOR AND PREP THE ROOM TO BE A NEW ELECTRICAL ROOM.
3. INSTALL NEW 480-VOLT FEEDER FROM GENERATOR TO BLDG. D. IN BLDG. D ELECTRICAL ROOM, INSTALL NEW STEP-DOWN TRANSFORMER AND 208-VOLT EMERGENCY DISTRIBUTION BOARD. REPLACE EXISTING 3 POLE ATSS WITH 4 POLE ATSS. ENERGIZE BLDG. D ATSS. TEMP FEED ATSS LOADS FROM NORMAL POWER SWITCHBOARD WHILE NEW EQUIPMENT IS INSTALLED IN BLDG. D. ELECTRICAL ROOM.
4. EXTEND NORMAL POWER AND LOAD CIRCUITRY TO NEW ATSS. MAKE OPERATIONAL. INSTALL TEMPORARY SERVICE CONDUCTORS AND CONDUIT FROM THE EXISTING 750KVA PAD MOUNTED TRANSFORMER TO EXISTING SWITCHBOARD MSU. PENETRATE SIDE OF 750KVA TRANSFORMER ENCLOSURE ABOVE GRADE FOR TEMPORARY SERVICE CONDUIT. ELECTRICAL SHUTDOWN #1:
 - MODIFY 750KVA TRANSFORMER SECONDARY COPPER DETAIL TERMINAL POINTS AS REQUIRED TO LAND TEMPORARY SERVICE CONDUCTORS. REMOVE SECONDARY CONDUCTORS BETWEEN 1000KVA TRANSFORMER AND MSU. TERMINATE BOTH ENDS OF TEMPORARY SERVICE CONDUCTORS. DISCONNECT PRIMARY SERVICE FROM 1000KVA TRANSFORMER. REMOVE 1000KVA TRANSFORMER PRIMARY CONDUCTORS BACK TO MV LINEUP AND MAKE SAFE. RE-ENERGIZE ELECTRICAL SERVICE.
5. REMOVE EXISTING 1000KVA, 208-VOLT PAD MOUNTED TRANSFORMER.
6. INSTALL ALL NEW 480-VOLT AND 208-VOLT ELECTRICAL EQUIPMENT IN NEW MAIN ELECTRICAL ROOM.
7. INSTALL NEW 480-VOLT MOTOR CONTROL CENTERS, NEW PANELBOARDS AND ASSOCIATED FEEDERS IN THE UTILITY PLANT.
8. INSTALL NEW 2000KVA, 480-VOLT PAD MOUNTED TRANSFORMER. INSTALL UNDERGROUND PRIMARY BETWEEN MV LINEUP AND TRANSFORMER. INSTALL SECONDARY SERVICE TO NEW ELECTRICAL ROOM. MAKE TERMINATIONS AT THE 2000KVA TRANSFORMER AND WITHIN THE NEW ELECTRICAL ROOM.
9. ELECTRICAL SHUTDOWN #2:
 - TERMINATE PRIMARY SERVICE CONDUCTORS FOR 2000KVA TRANSFORMER WITHIN MV LINEUP. RE-ENERGIZE ELECTRICAL SERVICE.
10. ENERGIZE ELECTRICAL ROOM EQUIPMENT, MCCS AND NEW PANELBOARDS THROUGHOUT THE UTILITY PLANT.
11. PER MECHANICAL PHASING PLAN, INSTALL NEW MECHANICAL EQUIPMENT AND POWER EQUIPMENT FROM NEW 480-VOLT ELECTRICAL SYSTEM. DEMO EXISTING MECHANICAL EQUIPMENT THAT IS BEING REPLACED, INCLUDING ASSOCIATED ELECTRICAL CIRCUITRY.
12. ONCE ALL OF THE EXISTING MECHANICAL EQUIPMENT AND CIRCUITRY HAS BEEN REMOVED AND REPLACED, REMOVE THE EXISTING 208-VOLT ELECTRICAL DISTRIBUTION EQUIPMENT, INCLUDING UTILITY PLANT PANELBOARDS, MCCS AND EMERGENCY SWITCHBOARD.
13. FEED SHOP AND LAUNDRY PANELS FROM NEW UTILITY PLANT 208-VOLT SYSTEM.
14. ELECTRICAL SHUTDOWN #3:
 - DISCONNECT PRIMARY AND SECONDARY SERVICE FROM 750KVA TRANSFORMER. REMOVE 750KVA TRANSFORMER PRIMARY CONDUCTORS BACK TO MV LINEUP AND MAKE SAFE. RE-ENERGIZE ELECTRICAL SERVICE. BUILDING SHALL RUN ON GENERATOR POWER WHILE WORK DURING SHUTDOWN #3 IS PERFORMED.
15. REMOVE EXISTING 750KVA, 208-VOLT TRANSFORMER AND SWITCHBOARD MSU.
16. INSTALL NEW 225KVA, 208-VOLT PAD MOUNTED UTILITY TRANSFORMER. INSTALL UNDERGROUND PRIMARY BETWEEN MV LINEUP AND TRANSFORMER. INSTALL SECONDARY SERVICE TO ELECTRICAL ROOM. INSTALL SHOP DISTRIBUTION BOARD DBS MAKE TERMINATIONS AT THE 225KVA TRANSFORMER AND WITHIN THE NEW ELECTRICAL ROOM.
17. ELECTRICAL SHUTDOWN #4:
 - TERMINATE PRIMARY SERVICE CONDUCTORS FOR 225KVA TRANSFORMER WITHIN MV LINEUP. RE-ENERGIZE ELECTRICAL SERVICE.

ELECTRICAL EX. EQUIPMENT NOTES

1. EXISTING MEDIUM VOLTAGE SWITCHGEAR TO REMAIN.
2. EXISTING 13.2KV PULL BOX FOR BUILDING D ELECTRIC SERVICE TO REMAIN.
3. EXISTING PAD MOUNTED UTILITY TRANSFORMER FOR BUILDING D TO REMAIN. SEE SITE PLAN FOR LOCATION.
4. EXISTING OVERHEAD 13.2KV FEEDER TO BUILDING D TO REMAIN.
5. EXISTING DISTRIBUTION BOARD IN LAUNDRY TO REMAIN.

ELECTRICAL DEMOLITION PHASE 1A NOTES

- 1A. DEMOLISH 1000KVA PAD MOUNTED UTILITY TRANSFORMER. SEE SITE PLAN FOR LOCATION.
- 2A. DEMOLISH 500KW DIESEL GENERATOR AND DAY TANK.
- 3A. DEMOLISH 3-POLE AUTOMATIC TRANSFER SWITCH IN BUILDING D.

ELECTRICAL DEMOLITION PHASE 1B NOTES

- 1B. DEMOLISH EXISTING STEAM BOILERS, ASSOCIATED DISCONNECT SWITCH, CONTROLS AND CIRCUITRY BACK TO SOURCE.
- 2B. DEMOLISH EXISTING BURNER, BURNER CONTROLS, ASSOCIATED DISCONNECT AND CIRCUITRY BACK TO SOURCE.
- 3B. DEMOLISH EXISTING CHILLERS, ASSOCIATED DISCONNECT SWITCH, CONTROLS AND CIRCUITRY BACK TO SOURCE.
- 4B. DEMOLISH EXISTING CONDENSATE RETURN, BOILER FEED TANKS, ASSOCIATED DISCONNECT SWITCH, CONTROLS AND CIRCUITRY BACK TO SOURCE.
- 5B. DEMOLISH EXISTING MOTORIZED DAMPERS, ASSOCIATED DISCONNECT SWITCH, CONTROLS AND CIRCUITRY BACK TO SOURCE.
- 6B. DEMOLISH EXISTING COOLING TOWER PUMPS, ASSOCIATED DISCONNECT SWITCH, CONTROLS AND CIRCUITRY BACK TO SOURCE.
- 7B. DEMOLISH EXISTING PUMP, ASSOCIATED DISCONNECT SWITCH, CONTROLS AND CIRCUITRY BACK TO SOURCE.
- 8B. DEMOLISH EXISTING UNIT HEATERS, ASSOCIATED DISCONNECT SWITCH, CONTROLS AND CIRCUITRY BACK TO SOURCE.
- 9B. DEMOLISH PUMP CIRCUITRY BACK TO MCC-1. CONTRACTOR SHALL MAKE PROVISIONS TO TEMP. REFEED PUMPS UNTIL PUMPS ARE DEMOLISHED IN PHASE 2. SEE NEW WORK.
- 10B. DEMOLISH ORIGINAL BUILDING MCC-1.

ELECTRICAL DEMOLITION PHASE 2 NOTES

- 1C. DEMOLISH EXISTING DUEL TEMPERATURE BUILDING PUMPS, ASSOCIATED DISCONNECT SWITCH, CONTROLS AND CIRCUITRY BACK TO SOURCE.
- 2C. DEMOLISH EXISTING EXPANSION TANKS, ASSOCIATED DISCONNECT SWITCH, CONTROLS AND CIRCUITRY BACK TO SOURCE.
- 3C. DEMOLISH 750KVA PAD MOUNTED UTILITY TRANSFORMER.
- 4C. DEMOLISH EM SWITCHBOARD AND 2000A SERVICE SWITCH FOR NON-ESSENTIAL MCC.
- 5C. DEMOLISH ESSENTIAL MCC.
- 6C. DEMOLISH NON-ESSENTIAL MCC.
- 7C. NOT USED.
- 8C. REMOVE BUILDING C&L MCC.
- 9C. DEMOLISH BUILDING A DOMESTIC HOT WATER CIRCULATORS MCC.
- 10C. DEMOLISH SWITCHBOARD MSU.
- 11C. DEMOLISH EXISTING UNIT HEATERS, ASSOCIATED DISCONNECT SWITCH, CONTROLS AND CIRCUITRY BACK TO SOURCE.

Rockland County



Facilities Management
Robert H. Gruffi, P.E., LEED AP
Director Facilities Management
Dr. Robert L. Yeager Health Center
50 Sanatorium Road
Building A, 2nd Floor
Pomona, NY 10970

MEP ENGINEER
OLA Consulting Engineers
50 Broadway
Hawthorne, NY 10532
914.747.2800
8 West 38th Street,
Suite 501
New York, NY 10018
646.849.4110
olace.com

STRUCTURAL ENGINEER
BROOKER ENGINEERING, PLLC
74 Lafayette Avenue, Suite 501
Suffern, NY 10901
945.357.4411
brookerengineering.com

ASBESTOS ABATEMENT
QuES&T
Quality Environmental Solutions & Technologies, Inc.
1376 Route 9, Wappingers
Falls, NY 12590
845.298.6031
qualityenv.com

ESTIMATING
DACK
CONSULTING SOLUTIONS, INC.
2 William St, suite 202
White Plains, NY 10601
914.686.7102
dackconsulting.com




NO.	DESCRIPTION	DATE
2	RE-ISSUED FOR BID	07/24/2022
1	ISSUED FOR BID	11/01/2021
NO.	DESCRIPTION	DATE

PROJECT
CAPITAL PROJECT 4466
BUILDING E UTILITY PLANT
RENOVATION & IMPROVEMENTS
DR. ROBERT L. YEAGER HEALTH CENTER
50 SANATORIUM ROAD,
POMONA, NY 10970

ELECTRICAL DEMOLITION PLAN

SCALE: 1/4" = 1'-0"
DRAWN BY: VB
CHECKED BY: ML
DATE: 04-28-2020
PROJECT NO: NRCK0016.00
DRAWING NO: E1.1



ELECTRICAL DEMOLITION NOTES

1. DEMOLISH EXISTING COOLING TOWERS, ASSOCIATED DISCONNECT SWITCH, CONTROLS AND CIRCUITRY BACK TO SOURCE.
2. DEMOLISH EXISTING EXHAUST FANS, ASSOCIATED DISCONNECT SWITCH, CONTROLS AND CIRCUITRY BACK TO SOURCE.

CLIENT

Rockland County
Facilities Management
Robert H. Gruffi, P.E., LEED AP
Director Facilities Management
Dr. Robert L. Yeager Health Center
50 Sanatorium Road
Building A, 2nd Floor
Pomona, NY 10970

MEP ENGINEER

OLA Consulting Engineers
50 Broadway
Hawthorne, NY 10532
914.747.2800
8 West 38th Street,
Suite 501
New York, NY 10018
646.849.4110
olace.com

STRUCTURAL ENGINEER

BROOKER ENGINEERING, PLLC
74 Lafayette Avenue, Suite 501
Suffern, NY 10901
845.357.4411
brookerengineering.com


ASBESTOS ABATEMENT

QuES&T
Quality Environmental Solutions & Technologies, Inc.
1376 Route 9, Wappingers
Falls, NY 12590
845.298.6031
qualityenv.com


ESTIMATING

DACK
CONSULTING SOLUTIONS, INC.
2 William St, suite 202
White Plains, NY 10601
914.686.7102
dackconsulting.com

KEYPLAN



CAMPUS - KEYPLAN



2	RE-ISSUED FOR BID	07/24/2022
1	ISSUED FOR BID	11/01/2021
NO.	DESCRIPTION	DATE

No use, reproduction or dissemination may be made of this drawing and the concepts set forth without the prior written consent of OLA Consulting Engineers, PC. Copyright © 2021

PROJECT

CAPITAL PROJECT 4466
BUILDING E UTILITY PLANT
RENOVATION & IMPROVEMENTS
DR. ROBERT L. YEAGER HEALTH CENTER
50 SANATORIUM ROAD,
POMONA, NY 10970

DRAWING TITLE

**ELECTRICAL DEMOLITION
ROOF PLAN**


SCALE 1/4" = 1'-0"	PROJECT NO. NRCK0016.00
DRAWN BY VB	DRAWING NO.
CHECKED BY ML	E1.2
DATE 04-28-2020	



1

ELECTRICAL DEMOLITION ROOF PLAN - PHASE 1B

SCALE: 1/4" = 1'-0"



LIGHTING CONTROL LEGEND

1. LIGHTING CIRCUITS SHALL BE WIRED THROUGH CONTACTOR. MANUAL ON/OFF WALL SWITCHES SHALL CONTROL CONTACTOR. WALL MOUNTED LINEAR LED FIXTURES SHALL BE CONTROLLED LOCALLY WHERE INDICATED.
2. MANUAL ON/OFF WALL SWITCHES.
3. PHOTOCELL AND TIMECLOCK CONTROLLED WITH MANUAL OVERRIDE SWITCH.

CLIENT

Rockland County
Facilities Management
Robert H. Gruffi, P.E., LEED AP
Director Facilities Management
Dr. Robert L. Yeager Health Center
50 Sanatorium Road
Building A, 2nd Floor
Pomona, NY 10970

MEP ENGINEER

OLA Consulting Engineers
50 Broadway
Hawthorne, NY 10532
914.747.2800
8 West 38th Street,
Suite 501
New York, NY 10018
646.849.4110
olace.com

STRUCTURAL ENGINEER

BROOKER ENGINEERING, PLLC
74 Lafayette Avenue, Suite 501
Suffern, NY 10901
845.357.4411
brookerengineering.com


ASBESTOS ABATEMENT

QuES&T
Quality Environmental Solutions & Technologies, Inc.
1376 Route 9, Wappingers
Falls, NY 12590
845.298.6031
qualityenv.com


ESTIMATING

DACK
CONSULTING SOLUTIONS, INC.
2 William St, suite 202
White Plains, NY 10601
914.686.7102
dackconsulting.com

KEYPLAN



CAMPUS - KEYPLAN



NO.	DESCRIPTION	DATE
2	RE-ISSUED FOR BID	07/24/2022
1	ISSUED FOR BID	11/01/2021


No use, reproduction or dissemination may be made of this drawing and the concepts set forth without the prior written consent of OLA Consulting Engineers, PC. Copyright © 2021

PROJECT
CAPITAL PROJECT 4466
BUILDING E UTILITY PLANT
RENOVATION & IMPROVEMENTS
DR. ROBERT L. YEAGER HEALTH CENTER
50 SANATORIUM ROAD,
POMONA, NY 10970

DRAWING TITLE

ELECTRICAL LIGHTING PLAN


SCALE 1/4" = 1'-0"	PROJECT NO. NRCK0016.00
DRAWN BY VB	DRAWING NO.
CHECKED BY ML	E2.1
DATE 04-28-2020	



ELECTRICAL NEW WORK LIGHTING PLAN

SCALE: 1/4" = 1'-0"

NOTES:
1) CONTRACTOR SHALL COORDINATE LIGHT FIXTURE LOCATION WITH MECHANICAL AND PLUMBING PIPING.



ELECTRICAL PHASING NOTES - GENERAL

- SEE DRAWING E1.1 FOR GENERAL ELECTRICAL PHASING CONCEPT NOTES.

ELECTRICAL EXISTING EQUIPMENT NOTES

- EXISTING MEDIUM VOLTAGE SWITCHGEAR.
- EXISTING 13.2KV PULL BOX FOR BUILDING D ELECTRIC SERVICE.
- EXISTING PANELBOARD IN SHOP. SEE DRAWING E3.3 FOR LOCATION.
- NOT USED.
- EXISTING OVERHEAD 13.2KV FEEDER TO BUILDING D. CONNECT TO NEW MEDIUM VOLTAGE SWITCHGEAR.
- EXISTING DISTRIBUTION BOARD IN LAUNDRY. SEE DRAWING E3.3 FOR LOCATION.

ELECTRICAL NEW WORK PHASE 1A NOTES

- NEW 1000KVA PAD MOUNTED TRANSFORMER FOR 480 VOLT ELECTRICAL SERVICE FOR UTILITY PLANT. SEE SITE PLAN FOR LOCATION.
- NEW MAIN SWITCHBOARD 'MSB' FOR UTILITY PLANT - 2500 AMP, 480Y/277 VOLT, 3 PHASE WITH MAIN SERVICE SWITCH, INTEGRAL ATS, DISTRIBUTION SECTIONS AND SPD.
- NEW 112.5KVA DRY TYPE TRANSFORMER FOR 208Y/120 VOLT, 3 PHASE LOADS FOR UTILITY PLANT.
- NEW UTILITY PLANT DISTRIBUTION BOARD 'DBP' - 400 AMP, 208Y/120 VOLT, 3 PHASE.
- NEW MOTOR CONTROL CENTER FOR UTILITY PLANT - (2) 800 AMP, 480Y/277 VOLT.
- NEW DIESEL GENERATOR TO PROVIDE BACKUP POWER FOR ENTIRE UTILITY PLANT - 2 MW, 480Y/277 VOLT, 3 PHASE. SEE SITE PLAN FOR LOCATION.
- NEW 4-POLE AUTOMATIC TRANSFER SWITCH IN BUILDING D.
- NEW 112.5KVA DRY TYPE TRANSFORMER FOR 208Y/120 VOLT, 3 PHASE EMERGENCY POWER TO BUILDING D AUTOMATIC TRANSFER SWITCHES.
- NEW BUILDING D EMERGENCY DISTRIBUTION BOARD 'EMDBD' - 400 AMP, 208Y/120 VOLT.

ELECTRICAL NEW WORK PHASE 1B NOTES

- NEW DUEL FUEL CONDENSING BOILERS WITH INLINE PRIMARY PUMP.
- NEW ELECTRIC 2-STAGE CENTRIFUGAL CHILLER.
- NEW BUILDING SECONDARY AND CONDENSER WATER PUMPS.
- NEW HOT WATER HEATERS AND PUMPS.
- NEW COOLING TOWERS ON ROOF.
- NEW GENERAL EXHAUST FANS ON ROOF.
- CHILLED WATER PRIMARY PUMP.
- FUEL OIL TRANSFER PUMP.

ELECTRICAL NEW WORK PHASE 2 NOTES

- NEW 225KVA PAD MOUNTED TRANSFORMER FOR 208 VOLT ELECTRICAL SERVICE FOR SHOP. SEE SITE PLAN FOR LOCATION.
- NEW SERVICE DISTRIBUTION BOARD 'DBS' FOR SHOP - 800 AMP, 208Y/120 VOLT, 3 PHASE.

Rockland County
Facilities Management
Robert H. Gruffi, P.E., LEED AP
Director Facilities Management
50 Sanatorium Road
Building A, 2nd Floor
Pomona, NY 10970

OLA Consulting Engineers
50 Broadway
Hawthorne, NY 10532
914.747.2800
8 West 38th Street,
Suite 501
New York, NY 10018
646.849.4110
olace.com

BROOKER ENGINEERING, PLLC
74 Lafayette Avenue, Suite 501
Suffern, NY 10901
945.357.4411
brookerengineering.com

QuES&T
Quality Environmental Solutions & Technologies, Inc.
1376 Route 9, Wappingers
Falls, NY 12590
845.298.6031
qualityenv.com

DACK
CONSULTING SOLUTIONS, INC.
2 William St, suite 202
White Plains, NY 10601
914.686.7102
dackconsulting.com

KEYPLAN

CAMPUS KEYPLAN

2	RE-ISSUED FOR BID	07/24/2022
1	ISSUED FOR BID	11/01/2021
NO.	DESCRIPTION	DATE


PROJECT

CAPITAL PROJECT 4466
BUILDING E UTILITY PLANT
RENOVATION & IMPROVEMENTS
DR. ROBERT L. YEAGER HEALTH CENTER
50 SANATORIUM ROAD,
POMONA, NY 10970

DRAWING TITLE

**ELECTRICAL NEW WORK
POWER FLOOR PLAN**

SEAL	SCALE 1/4" = 1'-0"	PROJECT NO. NRCK0016.00
DRAWN BY VB		DRAWING NO.
CHECKED BY ML		E3.1
DATE 04-28-2020		



1 ELECTRICAL NEW WORK ROOF POWER PLAN
SCALE: 1/4" = 1'-0"

NOTES:
1. SEE PHASING AND EQUIPMENT NOTES ON E3.1.



Rockland County
Facilities Management
Robert H. Gruffi, P.E., LEED AP
Director Facilities Management
Dr. Robert L. Yeager Health Center
50 Sanatorium Road
Building A, 2nd Floor
Pomona, NY 10970

OLA Consulting Engineers
50 Broadway
Hawthorne, NY 10532
914.747.2800
8 West 38th Street,
Suite 501
New York, NY 10018
646.849.4110
olace.com

BROOKER ENGINEERING, PLLC
74 Lafayette Avenue, Suite 501
Suffern, NY 10901
945.357.4411
brookerengineering.com

QuES&T
Quality Environmental Solutions & Technologies, Inc.
1376 Route 9, Wappingers
Falls, NY 12590
845.298.6031
qualityenv.com

DACK CONSULTING SOLUTIONS, INC.
2 William St, suite 202
White Plains, NY 10601
914.686.7102
dackconsulting.com




2	RE-ISSUED FOR BID	07/24/2022
1	ISSUED FOR BID	11/01/2021
NO.	DESCRIPTION	DATE

No use, reproduction or dissemination may be made of this drawing and the concepts set forth without the prior written consent of OLA Consulting Engineers, P.C. Copyright © 2021.

PROJECT
CAPITAL PROJECT 4466
BUILDING E UTILITY PLANT
RENOVATION & IMPROVEMENTS
DR. ROBERT L. YEAGER HEALTH CENTER
50 SANATORIUM ROAD,
POMONA, NY 10970

DRAWING TITLE
**ELECTRICAL NEW WORK
ROOF POWER PLAN**

SEAL	SCALE 1/4" = 1'-0"	PROJECT NO. NRCK0016.00
DRAWN BY VB	DRAWING NO.	
CHECKED BY ML		E3.2
DATE 04-28-2020		



1 ELECTRICAL NEW WORK POWER FLOOR PLAN - CONTINUED

SCALE: 1/4" = 1'-0"

- NOTES:
1. SEE PHASING AND EQUIPMENT NOTES ON E3.1.

CLIENT

Rockland County
Facilities Management
Robert H. Gruffi, P.E., LEED AP
Director Facilities Management
Dr. Robert L. Yeager Health Center
50 Sanatorium Road
Building A, 2nd Floor
Pomona, NY 10970

MEP ENGINEER

OLA
CONSULTING ENGINEERS

OLA Consulting Engineers
50 Broadway
Hawthorne, NY 10532
914.747.2800
8 West 38th Street,
Suite 501
New York, NY 10018
646.849.4110
olace.com

STRUCTURAL ENGINEER

BROOKER ENGINEERING, PLLC

74 Lafayette Avenue, Suite 501
Suffern, NY 10901
945.357.4411
brookerengineering.com

ASBESTOS ABATEMENT



QuES&T
Quality Environmental Solutions & Technologies, Inc.

1376 Route 9, Wappingers
Falls, NY 12590
845.298.6031
qualityenv.com

ESTIMATING

DACK
CONSULTING SOLUTIONS, INC.

2 William St, suite 202
White Plains, NY 10601
914.686.7102
dackconsulting.com



2	RE-ISSUED FOR BID	07/24/2022
1	ISSUED FOR BID	11/01/2021
NO.	DESCRIPTION	DATE

No use, reproduction or dissemination may be made of this drawing and the concepts set forth without the prior written consent of OLA Consulting Engineers, P.C. Copyright © 2021.



PROJECT

CAPITAL PROJECT 4466
BUILDING E UTILITY PLANT
RENOVATION & IMPROVEMENTS
DR. ROBERT L. YEAGER HEALTH CENTER
50 SANATORIUM ROAD,
POMONA, NY 10970

DRAWING TITLE

**ELECTRICAL NEW WORK
POWER FLOOR PLAN -
CONTINUED**

SEAL	SCALE 1/4" = 1'-0"	PROJECT NO. NRCK0016.00
DRAWN BY VB	DRAWING NO.	E3.3
CHECKED BY ML		
DATE 04-28-2020		



ELECTRICAL NEW WORK FIRE ALARM PLAN

SCALE: 1/4" = 1'-0"

CLIENT

Rockland County
Facilities Management
Robert H. Gruffi, P.E., LEED AP
Director Facilities Management
Dr. Robert L. Yeager Health Center
50 Sanatorium Road
Building A, 2nd Floor
Pomona, NY 10970

MEP ENGINEER

OLA Consulting Engineers
50 Broadway
Hawthorne, NY 10532
914.747.2800
8 West 38th Street,
Suite 501
New York, NY 10018
646.849.4110
olace.com

STRUCTURAL ENGINEER

BROOKER ENGINEERING, PLLC
74 Lafayette Avenue, Suite 501
Suffern, NY 10901
845.357.4411
brookerengineering.com

ASBESTOS ABATEMENT

QuES&T
Quality Environmental Solutions & Technologies, Inc.
1376 Route 9, Wappingers
Falls, NY 12590
845.298.6031
qualityenv.com

ESTIMATING

DACK
CONSULTING SOLUTIONS, INC.
2 William St, suite 202
White Plains, NY 10601
914.686.7102
dackconsulting.com

KEYPLAN

BUILDING E
AREA OF WORK

CAMPUS KEYPLAN

NORTH

A, B, C, D, E, F, G

2	RE-ISSUED FOR BID	07/24/2022
1	ISSUED FOR BID	11/01/2021
NO.	DESCRIPTION	DATE

No use, reproduction or dissemination may be made of this drawing and the concepts set forth without the prior written consent of OLA Consulting Engineers, PC. Copyright © 2021


PROJECT

CAPITAL PROJECT 4466
BUILDING E UTILITY PLANT
RENOVATION & IMPROVEMENTS
DR. ROBERT L. YEAGER HEALTH CENTER
50 SANATORIUM ROAD,
POMONA, NY 10970

DRAWING TITLE

ELECTRICAL FIRE ALARM PLAN

SEAL	SCALE 1/4" = 1'-0"	PROJECT NO. NRCK0016.00
	DRAWN BY VB	DRAWING NO.
	CHECKED BY ML	E4.1
	DATE 04-28-2020	



1 ELECTRICAL DEMOLITION AND TEMPORARY WORK ONE-LINE DIAGRAM - PHASE 1
SCALE: NONE

NOTES:
1. ALL CIRCUIT BREAKERS AND SWITCHES ARE 3 POLE, U.O.N.

BUILDING D - MENTAL HEALTH BLDG

OUTSIDE

DEM. MAIN ELECTRICAL ROOM - MSU,
3000A, 208Y/120V, 3Ø, 4W.

DEM. TEMP. DISTRIBUTION
BOARD 'DBT': 600A, 208Y/120V,
3Ø, 4W.

EXISTING MAIN EMERGENCY
SWITCHBOARD 'EMSW', 2000A,
208Y/120V, 3Ø, 4W.

EX. PANELBOARDS 'LP-2F' AND
'LP-2B' ARE FED FROM NEW
ELECTRICAL DISTRIBUTION DURING
PHASE 1. SEE NEW WORK FOR
LP-2F AND LP-2B SCOPE.

2 ELECTRICAL DEMOLITION AND TEMPORARY WORK ONE-LINE DIAGRAM - PHASE 2
SCALE: NONE

KEYPLAN

CAMPUS - KEYPLAN

2	RE-ISSUED FOR BID	07/24/2022
1	ISSUED FOR BID	11/01/2021
NO.	DESCRIPTION	DATE

No use, reproduction or dissemination may be made of this drawing and the concepts set forth without the prior written consent of OLA Consulting Engineers, P.C. Copyright © 2021.

CAPITAL PROJECT 4466
BUILDING E UTILITY PLANT
RENOVATION & IMPROVEMENTS
DR. ROBERT L. YEAGER HEALTH CENTER
50 SANATORIUM ROAD,
POMONA, NY 10970

ELECTRICAL PHASE 1&2
DEMOLITION ONE-LINE
DIAGRAMS


SEAL	SCALE NONE	PROJECT NO. NRCK0018.00
DRAWN BY VB	DRAWING NO.	E5.1
CHECKED BY ML	DATE 04-28-2020	

WIRING/CONDUIT LEGEND:


- 7 SETS OF 4-#500 MCM IN 9-4" (2 SPARE).
- 4-#2 & 1-#6 GND IN 1-1/4".
- 4-#3/0 & 1-#6 GND IN 2".
- 3-#6 & 1-#10 GND IN 3/4".
- 3-#2/0 & 1-#6 GND IN 2".
- 4-#600MCM & 1-#1/0 GND IN 3-1/2".
- 2 SETS OF 3-#600MCM & 1-#1/0 GND IN (2) 3-1/2".
- 2 SETS OF 4-#600 MCM IN 3-4" (1 SPARE).
- 3-#500 MCM & 1-#1/0 GND IN 2-4" (1 SPARE TO BUILDING E).
- 3-#1 & 1-#6 GND IN 1-1/2".
- 2 SETS OF 4-#600 MCM & 1-#1/0 GND IN 2-4".
- 2 SETS OF 4-#600 MCM & 1-#3/0 GND IN 2-4".
- 3-#500 MCM & 1-#1/0 GND IN 4".
- 3-#10 & 1-#6 GND IN 2".
- 4-#250 MCM & 1-#4 GND IN 2-1/2".
- 4-#10 & 1-#6 GND IN 1-1/2".
- 7 SETS OF 4-#500 MCM & 1-#3/0 GND IN 9-4" (2 SPARE).
- 2 SETS OF 4-#500 MCM & 1-#1 GND IN (2) 3".
- 3-#4 & 1-#10 GND IN 1-1/4".
- 2 SETS OF 3-#600MCM & 1-#3/0 GND IN (3) 3-1/2".
- 3-#600MCM & 1-#1/0 GND IN 3-1/2".
- 3-#10 & 1-#10 GND IN 3/4".
- 4-#500 MCM & 1-#2 GND IN 4".
- 3-#12 & 1-#12 GND IN 3/4".

RISER NOTES:

- THIS IS NOT A POINT-TO-POINT WIRING DIAGRAM. PRIOR TO STARTING ANY WORK, A WORKING POINT-TO-POINT WIRING DIAGRAM SHALL BE OBTAINED FROM FIRE ALARM SYSTEM VENDOR AND PERFORM ALL WORK IN ACCORDANCE WITH THAT DIAGRAM.
- ELECTRICAL CONTRACTOR SHALL INCLUDE IN THE BASE BID ALL 120V CIRCUITS THAT ARE REQUIRED TO SUPPORT THE OPERATION OF THE FIRE ALARM SYSTEM. COORDINATE REQUIREMENTS WITH THE FIRE ALARM VENDOR.
- QUANTITY OF STROBE BOOSTER POWER SUPPLY PANELS AND ASSOCIATED 120V CIRCUITS SHALL BE COORDINATED WITH SELECTED FIRE ALARM SYSTEM MANUFACTURER AND/OR FIRE ALARM VENDOR.
- PROVIDE ALL NECESSARY WIRING, MODULES, COMPONENTS, EXTENDER CABINET, AND PROGRAMMING REQUIRED TO CONNECT NEW DEVICES TO EXISTING SYSTEM.
- PROVIDE ALL NECESSARY HARDWARE AND PROGRAMMING TO PROVIDE THE CLIENT WITH 20% SPARE CAPACITY ON ALL INITIATING AND INDICATING CIRCUITS.
- PROVIDE AS PART OF THE BASE CONTRACT ALL LABOR AND MATERIALS TO INSTALL TEN (10) ADDITIONAL FIRE ALARM DEVICES DURING CONSTRUCTION. THE ADDITIONAL FIRE ALARM DEVICES CAN BE BUT NOT LIMITED TO SMOKE DETECTOR, HEAT DETECTOR, DOOR HOLDER, DUCT DETECTOR, FAN SHUTDOWN, TAMPER SWITCHES, FLOW SWITCHES, ETC. INCLUDE ALL LABOR AND MATERIALS INCLUDING WIRE, BOXES, CONDUIT, TERMINATIONS, HARDWARE, SOFTWARE, PROGRAMMING AND TESTING.
- CARBON MONOXIDE DETECTORS SHALL BE SUPERVISED BY FIRE ALARM SYSTEM AND SHALL NOT SEND AN ALARM SIGNAL TO THE SYSTEM. THESE DETECTORS SHALL BE MOUNTED ON SOUNDER BASES WHICH PROVIDE LOCAL ALARM ONLY IN A TEMPORAL 4 PATTERN OR CONSTANT TONE.
- ALL VISUAL ALARM DEVICES SHALL BE ADA COMPLIANT.
- PROVIDE REMOTE LED INDICATORS FOR ALL CONCEALED FIRE ALARM DEVICES SUCH AS DUCT SMOKE DETECTORS, ABOVE CEILING SMOKE DETECTORS, ELEVATOR SHAFT DETECTORS, MONITORING AND CONTROL MODULES, ETC. LED INDICATORS FOR DEVICES MOUNTED ABOVE DROP CEILINGS SHALL BE MOUNTED BELOW ASSOCIATED DEVICES. LABEL INDICATORS TO INDICATE DEVICE SERVED.
- CONTRACTOR TO PROVIDE SMOKE DETECTOR(S) IN ALL LOCATIONS CONTAINING FIRE ALARM CONTROL PANELS, DATA GATHERING PANELS, BOOSTER POWER SUPPLIES, OR ANY OTHER FIRE ALARM SYSTEM PANEL, WHETHER SHOWN ON PLANS OR NOT.
- CONTROL MODULES USED TO INITIATE EMERGENCY CONTROL FUNCTIONS THAT DO NOT FAIL IN A SAFE POSITION SHALL BE LOCATED WITHIN 3 FEET OF THE COMPONENT CONTROLLING THE EMERGENCY CONTROL FUNCTION PER NFPA 72. THIS INCLUDES, BUT IS NOT LIMITED TO, CONTROL MODULES CONNECTED TO FAN MOTOR CONTROLLERS, ELEVATOR CONTROLLERS, ETC.
- BATTERY BACKUP FOR FACP SHALL PROVIDE A MINIMUM OF 24 HOURS OF STAND BY POWER FOLLOWED BY 45 MINUTES OF ALARM.
- ALL FIRE ALARM PANELS, JUNCTION BOX COVERS, ETC SHALL BE PAINTED "FIRE DEPARTMENT RED".



2 FIRE ALARM RISER DIAGRAM - BUILDING E
SCALE: NONE



1 ELECTRICAL NEW WORK ONE-LINE DIAGRAM
SCALE: NONE

- NOTES:
- ALL CIRCUIT BREAKERS AND SWITCHES ARE 3 POLE, U.O.N.
 - PROVIDE 4" CONCRETE HOUSEKEEPING PAD FOR ALL TRANSFORMERS.

Rockland County
Facilities Management
Robert H. Gruffi, P.E., LEED AP
Director Facilities Management
Dr. Robert L. Yeager Health Center
50 Sanatorium Road
Building A, 2nd Floor
Pomona, NY 10970

MEP ENGINEER
OLA CONSULTING ENGINEERS
OLA Consulting Engineers
50 Broadway
Hawthorne, NY 10532
914.747.2800
8 West 38th Street,
Suite 501
New York, NY 10018
646.849.4110
olace.com

STRUCTURAL ENGINEER
BROOKER ENGINEERING, PLLC
74 Lafayette Avenue, Suite 501
Suffern, NY 10901
945.357.4411
brookerengineering.com

ASBESTOS ABATEMENT
QuES&T
Quality Environmental Solutions & Technologies, Inc.
1376 Route 9, Wappingers
Falls, NY 12590
845.298.6031
qualityenv.com

ESTIMATING
DACK
CONSULTING SOLUTIONS, INC.
2 William St, suite 202
White Plains, NY 10601
914.686.7102
dackconsulting.com

KEYPLAN

CAMPUS - KEYPLAN

2	RE-ISSUED FOR BID	07/24/2022
1	ISSUED FOR BID	11/01/2021
NO.	DESCRIPTION	DATE





No use, reproduction or dissemination may be made of this drawing and the concepts set forth without the prior written consent of OLA Consulting Engineers, P.C. Copyright © 2021.

PROJECT
CAPITAL PROJECT 4466
BUILDING E UTILITY PLANT
RENOVATION & IMPROVEMENTS
DR. ROBERT L. YEAGER HEALTH CENTER
50 SANATORIUM ROAD,
POMONA, NY 10970

DRAWING TITLE

ELECTRICAL NEW WORK
ONE-LINE AND FIRE ALARM
RISER DIAGRAMS

SCALE NONE	PROJECT NO. NRCK0016.00
DRAWN BY VB	DRAWING NO.
CHECKED BY ML	E5.2
DATE 04-28-2020	

LIGHTING FIXTURE SCHEDULE						
FIXTURE DESIGNATION	MANUFACTURER	CATALOG NUMBER	LAMPS	VOLTS	MOUNTING	REMARKS
A 	HOLOPHANE	PHZ-40L-4K-70CRI-AS-P-277-W-E10WCP	(1) 288W LED	277	PENDANT	PHUZON LED HIGH BAY FIXTURE WITH 40,000 LUMEN OUTPUT. PROVIDE EM OPTION WHERE INDICATED FOR 90 MINUTES OF BATTERY BACKUP TIME, MINIMUM.
B 	LITHONIA LIGHTING	FEM-L48-4000LM-IMACD-277-35K-80CRI-BSL722	(1) 23.8W LED	277	SURFACE	4' LED LINEAR LIGHT FIXTURE WITH 4000 LUMEN OUTPUT. WHERE INDICATED "EM" ON PLAN PROVIDE EMERGENCY OPTION FOR 90 MINUTES OF BATTERY BACKUP TIME, MINIMUM.
B1 	LITHONIA LIGHTING	FEM-L96-15000LM-IMACD-277-35K-80CRI-BSL722	(1) 94.3W LED	277	SURFACE	8' LED LINEAR LIGHT FIXTURE WITH 15000 LUMEN OUTPUT. WHERE INDICATED "EM" ON PLAN PROVIDE EMERGENCY OPTION FOR 90 MINUTES OF BATTERY BACKUP TIME, MINIMUM.
C 	LITHONIA LIGHTING	DSXW1-L3D 20C-1000-30K -120	(1) 40W LED	120V	SURFACE	LED EXTERIOR WALL LUMINAIRE.
	LITHONIA LIGHTING	LOM-5-W-3-R-120/277-ELN	EXIT - LED 0.171W	277	SURFACE WALL MOUNTED	LED EXIT SIGN WITH 90 MINUTES OF NICAD BATTERY BACKUP TIME. 8" RED LETTERS ON WHITE BACKGROUND. SURFACE MOUNTED WHITE CORROSION-PROOF THERMOPLASTIC HOUSING.

NOTES:

1.) VERIFY ALL FIXTURE CATALOG NUMBERS FOR INTENDED APPLICATIONS WITH REQUIRED ACCESSORIES.

2.) ALL BALLASTS AND DRIVERS IN FIXTURES LOCATED OUTDOORS SHALL BE ZERO DEGREE RATED STARTING TEMPERATURE. REFER TO DRAWINGS FOR LOCATION OF FIXTURES.

3.) LIGHT FIXTURES INDICATED AS EMERGENCY (EM) ON DRAWINGS SHALL CONTAIN AN EMERGENCY BACK-UP BATTERY WHERE POSSIBLE THE SHALL BE INTERNAL TO FIXTURE WITH A VISUAL INDICATING CHARGE LAMP AND TEST SWITCH. IF IT IS NOT POSSIBLE TO INSTALL THE EMERGENCY BATTERY IN THE FIXTURE, THE CONTRACTOR SHALL FURNISH & INSTALL A REMOTE EMERGENCY BATTERY. EACH BATTERY PACK SHALL BE CONNECTED SO THAT THE FIXTURE CAN BE SWITCHED UNDER NORMAL CONDITIONS AND IN THE EVENT OF A POWER OUTAGE, THE FIXTURE SHALL AUTOMATICALLY ILLUMINATE FOR 90 MINUTES WITH A 1200 LUMEN OUTPUT (TOTAL FROM FIXTURE), MINIMUM.

4.) ALL EXIT AND EMERGENCY FIXTURES SHALL BE FED FROM UNSWITCHED LEG OF ASSOCIATED LOCAL LIGHTING CIRCUITS.


5.) IN THE EVENT THE CONTRACTOR CHOOSES TO SUBSTITUTE LIGHT FIXTURES FOR THOSE THAT ARE SPECIFIED ON THE LIGHT FIXTURE SCHEDULE, THE CONTRACTOR SHALL SUBMIT POINT-TO-POINT PHOTOMETRIC CALCULATIONS FOR ALL AREAS WHERE THE SUBSTITUTED FIXTURES ARE INDICATED TO BE INSTALLED ON THE DRAWINGS. THESE CALCULATIONS SHALL BE SUBMITTED ALONG WITH THE LIGHT FIXTURE SHOP DRAWINGS.

MCC-1 MOTOR CONTROL CENTER SCHEDULE									
NAME: MCC-1		LOCATION: BOILER ROOM		KAIC RATING: 65KAIC		WIRE: 3			
MAIN RATING: 800A		MAIN CB: MLO		VOLTAGE: 480Y/277V		PHASE: 3			
CKT #	DESIGNATION	HP	FLA	CB SIZE/ POLE(S)	STARTER TYPE	WIRE	GROUND	CONDUIT	REMARKS
1	HOT WATER PRIMARY PUMP HWPP-1	5	7.6	3P-20A	VFD	3-#12	1-#12	3/4" C	-
2	HOT WATER PRIMARY PUMP HWPP-2	5	7.6	3P-20A	VFD	3-#12	1-#12	3/4" C	-
3	HOT WATER PRIMARY PUMP HWPP-3	5	7.6	3P-20A	VFD	3-#12	1-#12	3/4" C	-
4	HOT WATER PRIMARY PUMP HWPP-4	5	7.6	3P-20A	VFD	3-#12	1-#12	3/4" C	-
5	HOT WATER PRIMARY PUMP HWPP-5	5	7.6	3P-20A	VFD	3-#12	1-#12	3/4" C	-
6	HOT WATER PRIMARY PUMP HWPP-6	5	7.6	3P-20A	VFD	3-#12	1-#12	3/4" C	-
7	HOT WATER PRIMARY PUMP HWPP-7	5	7.6	3P-20A	VFD	3-#12	1-#12	3/4" C	-
8	HOT WATER PRIMARY PUMP HWPP-8	5	7.6	3P-20A	VFD	3-#12	1-#12	3/4" C	-
9	HOT WATER PRIMARY PUMP HWPP-9	5	7.6	3P-20A	VFD	3-#12	1-#12	3/4" C	-
10	CHILLED WATER PRIMARY PUMP CHWP-1	20	27	3P-70A	VFD	3-#8	1-#8	3/4" C	-
11	CHILLED WATER PRIMARY PUMP CHWP-2	20	27	3P-70A	VFD	3-#8	1-#8	3/4" C	-
12	CHILLED WATER PRIMARY PUMP CHWP-3	7.5	11	3P-30A	VFD	3-#12	1-#12	3/4" C	-
13	CONDENSER WATER PUMP CWP-1	75	96	3P-250A	VFD	3-#1	1-#4	1-1/4" C	-
14	CONDENSER WATER PUMP CWP-2	75	96	3P-250A	VFD	3-#1	1-#4	1-1/4" C	-
15	CONDENSER WATER PUMP CWP-3	75	96	3P-250A	VFD	3-#1	1-#4	1-1/4" C	-
16	PUMP P-F-1	15	21	3P-50A	VFD	3-#10	1-#10	3/4" C	-
17	PUMP P-F-2	15	21	3P-50A	VFD	3-#10	1-#10	3/4" C	-
18	PUMP P-F-FP	15	-	-	VFD	-	-	-	PROVISIONS FOR FUTURE PUMP.
19	PUMP P-JK-1	15	21	3P-50A	VFD	3-#10	1-#10	3/4" C	-
20	PUMP P-JK-2	15	21	3P-50A	VFD	3-#10	1-#10	3/4" C	-
21	PUMP P-JK-FP	15	-	-	VFD	-	-	-	PROVISIONS FOR FUTURE PUMP.
22	PUMP P-GH-1	7.5	11	3P-30A	VFD	3-#12	1-#12	3/4" C	-
23	PUMP P-GH-2	7.5	11	3P-30A	VFD	3-#12	1-#12	3/4" C	-
24	PUMP P-GH-FP	7.5	-	-	VFD	-	-	-	PROVISIONS FOR FUTURE PUMP.
25	PUMP P-UH-1	2	3.4	3P-15A	VFD	3-#12	1-#12	3/4" C	-
26	PUMP P-UH-2	2	3.4	3P-15A	VFD	3-#12	1-#12	3/4" C	-
27	PUMP P-UH-FP	2	-	-	VFD	-	-	-	PROVISIONS FOR FUTURE PUMP.
NOTES:									
1. BASED ON EATON WITH DH-1-TYPE VFDs, BACNET IP COMMUNICATIONS AND 24-PORT MANAGED ETHERNET SWITCH OR APPROVED EQUAL.									


MCC-2 MOTOR CONTROL CENTER SCHEDULE									
NAME: MCC-2		LOCATION: BOILER ROOM		KAIC RATING: 65KAIC		WIRE: 3			
MAIN RATING: 800A		MAIN CB: MLO		VOLTAGE: 480Y/277V		PHASE: 3			
CKT #	DESIGNATION	HP	FLA	CB SIZE/ POLE(S)	STARTER TYPE	WIRE	GROUND	CONDUIT	REMARKS
1	COOLING TOWER CT-1	25	34	3P-80A	VFD	3-#6	1-#8	3/4" C	-
2	COOLING TOWER CT-2	25	34	3P-80A	VFD	3-#6	1-#8	3/4" C	-
3	COOLING TOWER CT-3	25	34	3P-80A	VFD	3-#6	1-#8	3/4" C	-
4	PUMP P-AH-1	75	96	3P-250A	VFD	3-#1	1-#4	1-1/4" C	-
5	PUMP P-AH-FP	75	-	-	VFD	-	-	-	PROVISIONS FOR FUTURE PUMP.
6	PUMP P-FC-1	75	96	3P-250A	VFD	3-#1	1-#4	1-1/4" C	-
7	PUMP P-FC-2	75	96	3P-250A	VFD	3-#1	1-#4	1-1/4" C	-
8	PUMP P-L-1	30	40	3P-100A	VFD	3-#6	1-#8	3/4" C	-
9	PUMP P-L-2	30	40	3P-100A	VFD	3-#6	1-#8	3/4" C	-
10	PUMP P-L-FP	30	-	-	VFD	-	-	-	PROVISIONS FOR FUTURE PUMP.
11	PUMP P-C-1	30	40	3P-100A	VFD	3-#6	1-#8	3/4" C	-
12	PUMP P-C-2	30	40	3P-100A	VFD	3-#6	1-#8	3/4" C	-
13	PUMP P-C-FP	30	-	-	VFD	-	-	-	PROVISIONS FOR FUTURE PUMP.
14	PUMP P-D-1	30	40	3P-100A	VFD	3-#6	1-#8	3/4" C	-
15	PUMP P-D-2	30	40	3P-100A	VFD	3-#6	1-#8	3/4" C	-
16	PUMP P-D-FP	30	-	-	VFD	-	-	-	PROVISIONS FOR FUTURE PUMP.
17	GENERAL EXHAUST FAN GEF-1	1.5	3	3P-15A	VFD	3-#12	1-#12	3/4" C	-
18	GENERAL EXHAUST FAN GEF-2	1.5	3	3P-15A	VFD	3-#12	1-#12	3/4" C	-
19	GENERAL EXHAUST FAN GEF-3	1.5	3	3P-15A	VFD	3-#12	1-#12	3/4" C	-
20	REFRIGERANT EXHAUST FAN REF-1	1.5	3	3P-15A	VFD	3-#12	1-#12	3/4" C	-
NOTES:									
1. BASED ON EATON WITH DH-1-TYPE VFDs, BACNET IP COMMUNICATIONS AND 24-PORT MANAGED ETHERNET SWITCH OR APPROVED EQUAL.									

'LP1' PANEL SCHEDULE									
MAIN RATING: 200A		MAIN C.B.: 200A		KAIC RATING: 22KAIC					
VOLTAGE: 208Y/120V		PHASE: 3		WIRE: 4		MOUNTING: SURFACE			
CIRC. NO.	LOAD DESCRIPTION	BKR. AMPS	NO. OF POLES	NO. OF POLES	BKR. AMPS	LOAD DESCRIPTION	CIRC. NO.		
1	RECEPTACLES	20	1	1	15	UH-B	2		
3	GEF-4	15	1	1	15	UH-B	4		
5	ROOF RECEPTACLES	20	1	1	20	HVAC CONTROLS	6		
7	* - EX. LOAD	20	1	1	20	HVAC CONTROLS	8		
9	* - EX. LOAD	20	1	1	20	HVAC CONTROLS	10		
11	* - EX. LOAD	20	1	1	20	## - EX. LOAD	12		
13	* - EX. LOAD	20	1	1	20	## - EX. LOAD	14		
15				1	20	## - EX. LOAD	16		
17	** - EX. LOAD - WATER SOFTENER	20	3	1	20	## - EX. LOAD	18		
19				1	20	## - EX. LOAD	20		
21				1	20	## - EX. LOAD	22		
23	# - EX. LOAD - WELDER	60	3	1	20	## - EX. LOAD	24		
25				1	20	## - EX. LOAD	26		
27				1	20	## - EX. LOAD	28		
29	** - EX. LOAD - OUTSIDE ELECTRIC DOOR	20	3	1	20	## - EX. LOAD	30		
31				1	15	BOILER BREAKGLASS	32		
33	* - EX. LOAD	20	1	1	20	GENERATOR RECEPTACLE	34		
35	ROOF CONTROL VALVES	20	1	1	20	GENERATOR BATTERY CHARGER	36		
37	ROOF CONTROL VALVES	20	1	2	20	GENERATOR BLOCK HEATER	38		
39	MOTORIZED DAMPERS	20	1				40		
41	EX. UNIT HEATER	15	1	1	15	EX. UNIT HEATER	42		
43	FUEL OIL FILTRATION PANEL	20	1	1	20	SIDE STREAM SEPARATOR PANEL	44		
45				1	20	SPARE	46		
47	CHEMICAL PUMP/CABINET	15	3	1	20	FACP	48		
49				2	30	HEAT TRACE CONTROL PANEL	50		
51							52		
53	FILTRATION PUMP/CABINET	15	3	1	20	REC - ELEC. ROOMS	54		
55				1	15	LIGHTING CONTACTOR	56		
57				1	20	OVERFILL ALARM	58		
59	FUEL OIL TRANSFER PUMP	15	3	1	20		60		
61				-	-		62		
63	-	-	-	-	-		64		
65	-	-	-	-	-		66		
67	-	-	-	-	-		68		
69	SPARE	20	1	1	20	SPARE	70		
71	SPARE	20	1	1	20	SPARE	72		
73	SPARE	20	1	1	20	SPARE	74		
75	SPARE	20	1	1	20	SPARE	76		
77	SPARE	20	1	1	20	SPARE	78		
79	SPARE	20	1	1	20	SPARE	80		
81	SPARE	20	1	1	20	SPARE	82		
83	SPARE	20	1	1	20	SPARE	84		
LK - PROVIDE LOCKING TABS ON C.B.; GF - GFI TYPE C.B.; GP - GFF TYPE C.B.; AF - ARC FAULT TYPE C.B.; ST - SHUNT TRIP C.B.									
NOTES:									
1. * - EX. LOAD MIGRATED FROM DEMOLISHED PANELBOARD 'AP-BR'. CONTRACTOR SHALL INCLUDE 100' OF 2-#12 & 1-#12 GND IN 3/4" C FOR EXTENDING CIRCUIT.									
2. ** - EX. LOAD MIGRATED FROM DEMOLISHED PANELBOARD 'AP-BR'. CONTRACTOR SHALL INCLUDE 100' OF 3-#12 & 1-#12 GND IN 3/4" C FOR EXTENDING CIRCUIT.									
3. # - EX. LOAD MIGRATED FROM DEMOLISHED DIST. BOARD 'PPBR'. CONTRACTOR SHALL INCLUDE 100' OF 3-#12 & 1-#12 GND IN 3/4" C FOR EXTENDING CIRCUIT.									
4. ## - EX. LOAD MIGRATED FROM DEMOLISHED PANELBOARD 'LPEM'. CONTRACTOR SHALL INCLUDE 100' OF 2-12 & 1-#12 GND IN 3/4" C FOR EXTENDING CIRCUIT.									

'LP2' PANEL SCHEDULE									
MAIN RATING: 200A			MAIN C.B.: 200A			KAIC RATING: 22KAIC			
VOLTAGE: 208Y/120V			PHASE: 3		WIRE: 4		MOUNTING: SURFACE		
CIRC. NO.	LOAD DESCRIPTION	BKR. AMPS	NO. OF POLES	NO. OF POLES	BKR. AMPS	LOAD DESCRIPTION	CIRC. NO.		
1	LOAD CENTER	40	2	1	20	CONTROL VALVE	2		
3				1	20	ROOF RECEPTACLE	4		
5	RECEPTACLES	20	1	1	20	EX. HOT WATER HEATER	6		
7	DHWH-1	20	1	1	15	UH-B	8		
9	DHWH-2	20	1	1	15	UH-A	10		
11	HWCP-1	30	2	1	20	MOTORIZED DAMPERS	12		
13				1	20	MOTORIZED DAMPERS	14		
15	* - EX. LOAD	20	1	1	20	HVAC CONTROLS	16		
17	* - EX. LOAD	20	1	1	20	HVAC CONTROLS	18		
19	* - EX. LOAD	20	1	1	20	HVAC CONTROLS	20		
21	* - EX. LOAD	20	1	1	20	HVAC CONTROLS	22		
23	* - EX. LOAD	20	1	2	40	** - EX. LOAD - OVEN	24		
25	* - EX. LOAD	20	1				26		
27	* - EX. LOAD	20	1				28		
29	* - EX. LOAD	20	1	3	15	FUEL OIL TRANSFER PUMP	30		
31	* - EX. LOAD	20	1				32		
33	* - EX. LOAD	20	1	1	20	MOTORIZED DAMPERS	34		
35	DRAFT CONTROL PANEL	20	1	1	20	MOTORIZED DAMPERS	36		
37	SPARE	20	1	1	20	EX. MV ROOM LOAD	38		
39	SPARE	20	1	1	20	EX. MV ROOM LOAD	40		
41	SPARE	20	1	1	20	EX. MV ROOM LOAD	42		
43	FUEL OIL FILTRATION PANEL	20	1	1	20	SIDE STREAM SEPARATOR PANEL	44		
45	HWCP-2	30	2	1	20	LTG - MV ELEC. ROOM	46		
47				1	20	DRAFT CONTROL PANEL	48		
49	DRAFT CONTROL DAMPER	20	1	1	20	DRAFT CONTROL PANEL	50		
51	HOT WATER MIXING VALVE	20	1	1	20	DRAFT CONTROL DAMPER	52		
53	HOT WATER MIXING VALVE PNL	20	1	1	20	DRAFT CONTROL DAMPER	54		
55	SPARE	20	1	1	20	EX. MV ROOM LOAD	56		
57	SPARE	20	1	1	20	EX. MV ROOM LOAD	58		
59	SPARE	20	1	1	20	SPARE	60		
61	SPARE	20	1	1	20	SPARE	62		
63	SPARE	20	1	1	20	SPARE	64		
65	SPARE	20	1	1	20	SPARE	66		




CONDUIT SUPPORTED FROM STRUCTURAL STEEL
SCALE: NONE




- NOTES:**
- 1) CONNECTION TO WATER MAIN AND FIRE PROTECTION MAIN SHALL BE A MAXIMUM OF 5'-0" FROM WHERE THE PIPE ENTERS THE BUILDING AND BE PRIOR TO ANY METER, VALVE JOINT, ETC.
 - 2) ALL CONNECTIONS TO THE GROUND BAR SHALL BE MADE USING COMPRESSION LUGS SIZED TO ACCOMMODATE THE CONDUCTORS.


SERVICE GROUNDING DETAIL TYPICAL
SCALE: NONE



LIGHTING CONTROL CONTACTOR WIRING DIAGRAM
SCALE: NONE




TYPICAL CONDUIT SUPPORT ON MASONRY
SCALE: 1" = 1'-0"




TRENCHING DETAIL FOR CONDUIT
SCALE: NONE

MINIMUM COVER REQUIREMENT TABLE	
LOCATION	NONMETALLIC RACEWAYS LISTED FOR DIRECT BURIAL WITHOUT CONCRETE ENCASMENT OR OTHER APPROVED RACEWAYS
ALL LOCATION NOT SPECIFIED BELOW.	18"
IN TRENCH BELOW 2-IN. THICK CONCRETE OR EQUIVALENT.	12"
UNDER MINIMUM OF 4-IN. THICK CONCRETE EXTERIOR SLAB WITH NO VEHICULAR TRAFFIC AND THE SLAB EXTENDING NOT LESS THAN 6 IN. BEYOND THE UNDERGROUND INSTALLATION.	4" SEE NOTE #2.
UNDER STREETS, HIGHWAYS, ROADS, ALLEYS, DRIVEWAYS, AND PARKING LOTS.	24"


- NOTES:**
- 1) DETAIL SHOWN FOR INFORMATION PURPOSES. SAME CONCEPT SHALL ALSO APPLY FOR SINGLE CONDUITS.
 - 2) SAND MAY BE OMITTED FOR INSTALLATIONS WHERE COVER REQUIREMENTS ARE 6" OR LESS.
 - 3) CONDUIT AND WIRING FURNISHED AND INSTALLED BY ELECTRICAL CONTRACTOR.




TYPICAL INTERIOR MASONRY WALL CONDUIT PENETRATION DETAIL
SCALE: NONE




TYPICAL EXTERIOR MASONRY WALL BELOW GRADE CONDUIT PENETRATION DETAIL
SCALE: NONE




TRAPEZE SUPPORT DETAIL
SCALE: NONE



BOILER EMERGENCY SHUTDOWN WIRING DIAGRAM
SCALE: NONE




SWITCHED EMERGENCY FIXTURE WIRING DIAGRAM
SCALE: NONE




- NOTE:**
1. REFER TO TRENCHING DETAIL FOR TRENCH INFORMATION.


CONCRETE PAVEMENT REPLACEMENT DETAIL
SCALE: NONE




TYPICAL VERTICAL CONDUIT PENETRATION DETAIL
SCALE: NONE



TYPICAL CONDUIT SUPPORT ON MASONRY
SCALE: 1" = 1'-0"




TYPICAL EXTERIOR MASONRY WALL ABOVE GRADE CONDUIT PENETRATION DETAIL
SCALE: NONE



- NOTES:**
- 1) THICKNESS INDICATED REFERS TO COMPACTED MEASURE.
 - 2) ITEM NUMBERS REFER TO NEW YORK STATE DEPARTMENT OF TRANSPORTATION STANDARD SPECIFICATIONS.
 - 3) REFER TO TRENCHING DETAIL FOR TRENCH INFORMATION.

BITUMINOUS PAVEMENT REPLACEMENT DETAIL
SCALE: NONE



TYPICAL FIRE RATED GYPSUM WALL CONDUIT PENETRATION DETAIL
SCALE: NONE

Rockland County
Facilities Management
Robert H. Gruffi, P.E., LEED AP
Director Facilities Management
Dr. Robert L. Yeager Health Center
50 Sanatorium Road
Building A, 2nd Floor
Pomona, NY 10970

OLA Consulting Engineers
50 Broadway
Suite 501
Hawthorne, NY 10532
914.747.2800
8 West 38th Street,
Suite 501
New York, NY 10018
646.849.4110
olace.com

BROOKER ENGINEERING, PLLC
74 Lafayette Avenue, Suite 501
Suffern, NY 10901
945.357.4411
brookerengineering.com

QuES&T
Quality Environmental Solutions & Technologies, Inc.
1376 Route 9, Wappingers
Falls, NY 12590
845.298.6031
qualityenv.com

DACK CONSULTING SOLUTIONS, INC.
2 William St, suite 202
White Plains, NY 10601
914.686.7102
dackconsulting.com

KEYPLAN

CAMPUS - KEYPLAN

NO.	DESCRIPTION	DATE
2	RE-ISSUED FOR BID	07/24/2022
1	ISSUED FOR BID	11/01/2021

No use, reproduction or dissemination may be made of this drawing and the concepts set forth without the prior written consent of OLA Consulting Engineers, P.C. Copyright © 2021.

CAPITAL PROJECT 4466
BUILDING E UTILITY PLANT
RENOVATION & IMPROVEMENTS
DR. ROBERT L. YEAGER HEALTH CENTER
50 SANATORIUM ROAD,
POMONA, NY 10970

DRAWING TITLE

ELECTRICAL DETAILS

SCALE: NONE	DRAWN BY: VB	CHECKED BY: ML	DATE: 04-28-2020
PROJECT NO: NRC0016.00	DRAWING NO:	E7.1	

15 KV CABLE TESTING:

1. REFERENCES: ANSII/IEEE C2 - NATIONAL ELECTRICAL SAFETY CODE, ANSI/NFPA 70 - NATIONAL ELECTRICAL CODE, IEEE 48 - TEST PROCEDURES AND REQUIREMENTS FOR HIGH-VOLTAGE ALTERNATING-CURRENT CABLE TERMINATIONS.
2. SUBMITTALS: PROVIDE FOR CABLE, TERMINATIONS, ACCESSORIES & TEST REPORTS. MANUFACTURER'S INSTRUCTIONS: INDICATE APPLICATION CONDITIONS AND LIMITATIONS OF USE STIPULATED BY PRODUCT TESTING AGENCY SPECIFIED UNDER REGULATORY REQUIREMENTS.
3. PROJECT RECORD DOCUMENTS: ACCURATELY RECORD ACTUAL SIZES AND LOCATIONS OF CABLES.
4. OPERATION AND MAINTENANCE DATA: INCLUDE INSTRUCTIONS FOR TESTING AND CLEANING CABLE AND ACCESSORIES.
5. QUALIFICATIONS: MANUFACTURER, COMPANY SPECIALIZING IN MANUFACTURING PRODUCTS SPECIFIED IN THIS SECTION WITH MINIMUM THREE YEARS DOCUMENTED EXPERIENCE. INSTALLER, COMPANY SPECIALIZING IN INSTALLING PRODUCTS SPECIFIED IN THIS SECTION WITH MINIMUM THREE YEARS DOCUMENTED EXPERIENCE.
6. MANUFACTURERS: 1) OKONITE COMPANY, 2) KING WIRE INC. 3) KERITE.

7. FIELD QUALITY CONTROL: INSPECT EXPOSED CABLE SECTIONS FOR PHYSICAL DAMAGE, PROPER CONNECTIONS AS SHOWN ON DRAWINGS AND AS REQUIRED, GROUNDING, CABLE SUPPORTS, AND TERMINATIONS FOR PROPER INSTALLATION. PERFORM DC HIGH POTENTIAL TEST OF EACH CONDUCTOR IN ACCORDANCE WITH NEMA WC 8 AND THE FOLLOWING REQUIRED TESTS.

8. THE 15KV CABLE SHALL BE DC PROOF TESTED BY AN INDEPENDENT TESTING FIRM. THE ATTACHED DC PROOF TESTING FORM SHALL BE COMPLETED BY THE TESTING FIRM AND SUBMITTED FOR REVIEW.
9. TEST LEVELS: A DIRECT-CURRENT VOLTAGE TEST SHALL BE MADE FOR SOLID DIELECTRIC CABLE IN ACCORDANCE WITH THE FOLLOWING TABLE:

RATED CIRCUIT VOLTAGE PHASE TO PHASE KV	DC TEST VOLTAGE KV
15	40

- A. THE VOLTAGE SHALL BE APPLIED BETWEEN THE CONDUCTOR AND THE METALLIC SHEATH, SHIELD OR CONCENTRIC NEUTRAL WIRES.
- B. THE MAXIMUM APPLIED DIRECT-CURRENT VOLTAGE SHALL NOT BE GREATER THAN THREE (3) TIMES THE ALTERNATING CURRENT VOLTAGE RATING OF THE CABLE OR CABLE ACCESSORY.
- C. THE RATE OF INCREASE FROM THE INITIALLY APPLIED VOLTAGE TO THE SPECIFIED TEST VOLTAGE SHALL BE APPROXIMATELY UNIFORM AND SHALL NOT BE OVER 100 PERCENT IN 10 SECONDS OR LESS THAN 100 PERCENT IN 60 SECONDS.
- D. THE DURATION OF THE TEST SHALL BE 15 MINUTES AT FULL VOLTAGE AND THE LEAKAGE CURRENT SHALL NOT BE RECORDED UNTIL AT FULL VOLTAGE. THE CABLE MUST MAINTAIN THE SPECIFIED TEST VOLTAGE FOR THE DURATION OF THE TEST TO BE CONSIDERED ACCEPTABLE.

10. PREPARATION FOR TESTING: THE INDEPENDENT TESTING COMPANY PERSONNEL SHALL COMPLY WITH THE FOLLOWING MINIMUM REQUIREMENTS:

- A. SAFETY - (TO PRECLUDE ACCIDENTAL CONTACT WITH THE CABLE(S) BEING TESTED)
1. THE TEST AREA AND THE CABLE (S) UNDER TEST SHALL BE ROPED OFF.
 2. "DANGER-HIGH VOLTAGE" SIGNS SHALL BE DISPLAYED AROUND ALL ROPED OFF AREAS.
 3. TEST PERSONNEL SHALL BE STATIONED AT ALL EXPOSED CABLE TERMINATIONS.
- B. CLEARANCES - THE CABLE UNDER TEST MUST BE COMPLETELY ISOLATED FROM ALL EQUIPMENT.

1. TO REDUCE LEAKAGE CURRENT DURING TESTING, CLEAN THE TERMINATIONS AND COVER ANY EXPOSED METALLIC SURFACES WITH PLASTIC WRAP OR DUCT SEAL TO REDUCE CORONA EFFECTS.
2. MAINTAIN A CLEARANCE OF AT LEAST TWO FEET BETWEEN TEST POINT OR EXPOSED CABLE ENDS UNDER TEST AND ANY UNENERGIZED SURFACE AND AT LEAST TWO FEET BETWEEN TEST POINT OR EXPOSED CABLE ENDS AND ANY ENERGIZED SURFACE (BUS IN SWITCHGEAR, OTHER CIRCUITS OR CABLES, ETC.)

11. GROUNDING:

- A. THE METALLIC SHIELDS (CONCENTRIC NEUTRALS, COPPER OR ZINC TAPES, DRAIN WIRES) OR METALLIC SHEATHS OF SHIELDED CABLE MUST BE GROUNDED DURING THE TEST.
- B. CABLES NOT UNDER TEST MUST BE GROUNDED ON BOTH CONDUCTORS AND METALLIC SHEATHS.

- C. AFTER EACH CABLE TEST THE CABLE SHALL BE ALLOWED TO DISCHARGE TO 10KV OR BELOW BEFORE APPLYING A GROUND. AN APPROPRIATE GROUNDING STICK OR RUBBER GLOVE SHALL BE USED AND/OR WORN WHEN APPLYING THE GROUND. GROUND MUST REMAIN ON FOR AT LEAST 15 MINUTES TO DRAIN CHARGE FROM TESTING.

12. CONNECTIONS

- A. ALL BOLTED TERMINATIONS SWITCHES SHALL BE UNBOLTED AND PULLED INTO CLEARANCES AS NOTED ABOVE.
- B. ALL LEADS EXTENDING FROM THE TOP OF ANY TERMINATION TO OVERHEAD LINES MUST BE REMOVED AND THE TERMINATION LOWERED TO OBTAIN ADEQUATE CLEARANCE.

13. SAMPLE: REPORTING FORM - DC PROOF TESTING

REPORTING FORM - DC PROOF TESTING

TESTING COMPANY NAME _____
CUSTOMER _____
LOCATION _____
DATE OF TEST ____ TESTER'S NAME _____
HUMIDITY ____% TEMPERATURE _____
WEATHER: CLOUDY__ RAIN__ SNOW__
FOG__ SUNNY__

PHASE IDENTIFICATION			
KV TEST VOLTAGE			
MICROAMPERES	μ	μ	μ
TEST SET LEAKAGE			
15 SECONDS			
30 SECONDS			
45 SECONDS			
1 MINUTE			
2 MINUTES			
3 MINUTES			
4 MINUTES			
5 MINUTES			
6 MINUTES			
7 MINUTES			
8 MINUTES			
9 MINUTES			
10 MINUTES			
11 MINUTES			
12 MINUTES			
13 MINUTES			
14 MINUTES			
15 MINUTES			

CABLE MANUFACTURER: _____
CABLE RELATED VOLTAGE: _____
OPERATING VOLTAGE: _____
CONDUCTOR SIZE: _____
TYPE OF INSULATION: _____
NUMBER OF CONDUCTORS: _____
LENGTH: _____
AGE: _____
TYPE OF JACKET: _____
SEPARATE NEUTRAL: _____
OR
CONCENTRIC NEUTRAL WIRES: _____
TYPE OF TERMINATIONS AT TEST END: _____

TYPE OF TERMINATIONS AT OPPOSITE END: _____

REMARKS: _____

14. PROTECTION:
A. PROTECT INSTALLED CABLES FROM ENTRANCE OF MOISTURE.

NOTES:

1. FLOOR OR WALL ASSEMBLY - MIN 4-1/2 IN. THICK REINFORCED LIGHTWEIGHT OR NORMAL WEIGHT (100-150 PCF) CONCRETE. WALL MAY ALSO BE CONSTRUCTED OF ANY UL CLASSIFIED CONCRETE BLOCKS*. MAX DIAM OF OPENING IS 26 IN.
* SEE CONCRETE BLOCKS (CAZT) CATEGORY IN THE FIRE RESISTANCE DIRECTORY FOR NAMES OF MANUFACTURERS.

2. STEEL SLEEVE (OPTIONAL) - NOM 14 IN. DIAM (OR SMALLER) SCHEDULE 10 (OR HEAVIER) STEEL SLEEVE CAST OR GROUTED INTO FLOOR OR WALL ASSEMBLY.

3. THROUGH PENETRANTS - ONE METALLIC PIPE, CONDUIT OR TUBING INSTALLED EITHER CONCENTRICALLY OR ECCENTRICALLY WITHIN THE FIRESTOP SYSTEM, THE ANNULAR SPACE BETWEEN PIPE, CONDUIT OR TUBING AND PERIPHERY OF OPENING OR SLEEVE SHALL BE MIN 0 IN. (POINT CONTACT) TO MAX 2 IN. PIPE, CONDUIT OR TUBING TO BE RIGIDLY SUPPORTED ON BOTH SIDES OF WALL ASSEMBLY. THE FOLLOWING TYPES AND SIZES OF METALLIC PIPES, CONDUITS OR TUBING MAY BE USED:

- A. STEEL PIPE - NOM 24 IN. DIAM (OR SMALLER) SCHEDULE 10 (OR HEAVIER) STEEL PIPE.
B. IRON PIPE - NOM 24 IN. DIAM (OR SMALLER) SERVICE WEIGHT (OR HEAVIER) CAST IRON SOIL PIPE, NOM 24 IN DIAM (OR SMALLER) CLASS 50 (OR HEAVIER) DUCTILE IRON PRESSURE PIPE.
C. CONDUIT - NOM 6 IN. DIAM (OR SMALLER) STEEL CONDUIT OR NOM 4 IN. DIAM (OR SMALLER) STEEL ELECTRICAL METALLIC TUBING.
D. COPPER TUBING - NOM 6 IN. DIAM (OR SMALLER) TYPE L (OR HEAVIER) COPPER TUBING.
E. COPPER PIPE - NOM 6 IN. DIAM (OR SMALLER) REGULAR (OR HEAVIER) COPPER PIPE.

4. FIRESTOP SYSTEM - THE DETAILS OF THE FIRESTOP SYSTEM SHALL BE AS FOLLOWS:

- A. PACKING MATERIAL - MIN 4 IN. THICKNESS OF MIN 4 PCF MINERAL WOOL BATT INSULATION FIRMLY PACKED INTO OPENING AS A PERMANENT FORM. PACKING MATERIAL TO BE RECESSED FROM TOP SURFACE OF FLOOR OR FROM BOTH SURFACES OF WALL AS REQUIRED TO ACCOMMODATE THE REQUIRED THICKNESS OF FILL MATERIAL.
- B. FILL VOID OR CAVITY MATERIALS* - CAULK OR SEALANT - MIN 1/4 IN. THICKNESS OF FILL MATERIAL APPLIED WITHIN THE ANNULUS, FLUSH WITH TOP SURFACE OF FLOOR OR WITH BOTH SURFACES OF WALL. MIN 1/4 IN. DIAM BEAD OF CAULK APPLIED TO THE PENETRANT/CONCRETE OR PENETRANT/SLEEVE INTERFACE AT THE POINT CONTACT LOCATION ON THE TOP SURFACE OF FLOOR OR BOTH SURFACES OF WALL.

3M COMPANY - CP 25WB+ CAULK OR FB-3000 WT SEALANT.
(THE W RATING APPLIES ONLY WHEN FB-3000 WT IS USED.)

*BEARING THE UL CLASSIFICATION MARKING

6 UNINSULATED PIPE AND CONDUIT FIRE STOPPING DETAIL

SCALE: NONE

1. FLOOR OR WALL ASSEMBLY - MIN 4-1/2 IN. (114 MM) THICK REINFORCED LIGHTWEIGHT OR NORMAL WEIGHT (100-150 PCF OR 1600-2400 KG/M³) CONCRETE. FLOOR ASSEMBLY MAY ALSO BE CONSTRUCTED OF ANY MIN 6 IN. (152 MM) THICK UL CLASSIFIED HOLLOW-CORE PRECAST CONCRETE UNITS*. WALL MAY ALSO BE CONSTRUCTED OF ANY UL CLASSIFIED CONCRETE BLOCKS*. DIAM OF OPENING TO BE NOM 2 IN. (51 MM) (LARGER THAN OUTSIDE DIAM OF PIPE COVERING MATERIAL, ITEM 3). MAX DIAM OF OPENING 12 IN. (305 MM). MAX DIAM OF OPENING IN FLOORS CONSTRUCTED OF HOLLOW-CORE CONCRETE IS 7 IN. (178 MM).

SEE CONCRETE BLOCKS (CAZT) AND PRECAST CONCRETE UNITS (GFTV) CATEGORIES IN FIRE RESISTANCE DIRECTORY FOR NAMES OF MANUFACTURERS.

2. THROUGH PENETRANTS - ONE METALLIC PIPE OR TUBING TO BE INSTALLED CONCENTRICALLY OR ECCENTRICALLY WITHIN OPENING. PENETRANT TO BE RIGIDLY SUPPORTED ON BOTH SIDES OF FLOOR OR WALL ASSEMBLY. THE FOLLOWING TYPES AND SIZES OF METALLIC PIPES OR TUBES MAY BE USED:

- A. STEEL PIPE - NOM 4 IN. (102 MM) DIAM (OR SMALLER) SCHEDULE 10 (OR HEAVIER) STEEL PIPE.
B. IRON PIPE - NOM 4 IN. (102 MM) DIAM (OR SMALLER) CAST OR DUCTILE IRON PIPE.
C. COPPER TUBING - NOM 4 IN. (102 MM) DIAM (OR SMALLER) TYPE M (OR HEAVIER) COPPER TUBE.
D. COPPER PIPE - NOM 4 IN. (102 MM) DIAM (OR SMALLER) REGULAR (OR HEAVIER) COPPER PIPE.

3. PIPE COVERING - NOM 3 IN. (76 MM) THICK (OR LESS) HOLLOW CYLINDRICAL HEAVY DENSITY GLASS FIBER UNITS JACKETED ON THE OUTSIDE WITH AN ALL SERVICE JACKET. LONGITUDINAL JOINTS SEALED WITH METAL FASTENERS OR FACTORY-APPLIED SELF-SEALING LAP TAPE. TRANSVERSE JOINTS SECURED WITH METAL FASTENERS OR WITH BUTT TAPE SUPPLIED WITH PRODUCT. ANNULAR SPACE BETWEEN THE PIPE COVERING AND PERIPHERY OF OPENING OR SLEEVE SHALL BE MIN 3/8 IN. (10 MM) TO MAX 1-1/2 IN. (38 MM), WHEN PIPE COVERING MATERIAL THICKNESS IS LESS THAN 3 IN. (76 MM). T RATING IS 0 HR.

SEE PIPE AND EQUIPMENT COVERING - MATERIALS (BRGJ) CATEGORY IN THE BUILDING MATERIALS DIRECTORY FOR NAMES OF MANUFACTURERS. ANY PIPE COVERING MATERIALS MEETING THE ABOVE SPECIFICATIONS AND BEARING THE UL CLASSIFICATION MARKING WITH A FLAME SPREAD INDEX OF 25 OR LESS AND A SMOKE DEVELOPED INDEX OF 50 OR LESS MAY BE USED.

4. FIRESTOP SYSTEM - THE DETAILS OF THE FIRESTOP SYSTEM SHALL BE AS FOLLOWS:

- A. PACKING MATERIAL - (OPTIONAL, NOT SHOWN) - POLYETHYLENE BACKER ROD OR NOM 1 IN. (25 MM) THICKNESS OF TIGHTLY-PACKED MINERAL WOOL BATT OR GLASS FIBER INSULATION FIRMLY PACKED INTO OPENING AS A PERMANENT FORM. PACKING MATERIAL TO BE RECESSED FROM TOP SURFACE OF FLOOR OR FROM BOTH SURFACES OF WALL AS REQUIRED TO ACCOMMODATE THE REQUIRED THICKNESS OF FILL MATERIAL. IN FLOORS CONSTRUCTED OF HOLLOW-CORE CONCRETE, PACKING MATERIAL TO BE RECESSED FROM TOP AND BOTTOM SURFACES OF FLOOR OR SLEEVE AS REQUIRED TO ACCOMMODATE THE REQUIRED THICKNESS OF FILL MATERIAL.

- A1. FORMING MATERIAL* - AS AN ALTERNATE TO THE PACKING MATERIAL IN ITEM 5A, NOM 4 IN. (102 MM) WIDE STRIPS OF MIN 1/2 IN. (13 MM) THICK COMPRESSIBLE MAT FOLDED IN HALF LENGTHWISE AND STAPLED TO A THICKNESS GREATER THAN THE WIDTH OF THE ANNULAR SPACE AND COMPRESSED FIRST, TO FILL THE ANNULAR SPACE TO A MIN 2 IN. (51 MM) DEPTH. TOP OF FORMING MATERIAL TO BE RECESSED FROM TOP SURFACE OF FLOOR OR FROM BOTH SURFACES OF WALL AS NECESSARY TO ACCOMMODATE THE REQUIRED THICKNESS OF CAULK/FILL MATERIAL. IN FLOORS CONSTRUCTED OF HOLLOW-CORE CONCRETE, FORMING MATERIAL TO BE RECESSED FROM TOP AND BOTTOM SURFACES OF FLOOR OR SLEEVE AS REQUIRED TO ACCOMMODATE THE REQUIRED THICKNESS OF FILL MATERIAL.

- 3M COMPANY - FIRE BARRIER PACKING MATERIAL.

- B. FILL VOID OR CAVITY MATERIALS* - SEALANT - MIN 2 IN. (51 MM) THICKNESS OF SEALANT APPLIED WITHIN THE ANNULUS, FLUSH WITH TOP SURFACE OF FLOOR OR WITH BOTH SURFACES OF WALL. IN FLOORS CONSTRUCTED OF HOLLOW-CORE CONCRETE, MIN 2 IN. (51 MM) THICKNESS OF SEALANT APPLIED WITHIN THE ANNULUS, FLUSH WITH TOP AND BOTTOM SURFACES OF FLOOR OR SLEEVE.


3M COMPANY - FB-3000 WT

*BEARING THE UL CLASSIFICATION MARK


5 INSULATED PIPE FIRE STOPPING DETAIL

SCALE: NONE

SYSTEM NO. C-AJ-1274
AUGUST 23, 2004
JUNE 14, 2007
F RATING - 3 HR
T RATING - 0 HR
W RATING - CLASS I (SEE ITEM 4)



SYSTEM NO. C-AJ-5310
JUNE 14, 2007
T RATING - 0 AND 1 HR (SEE ITEM 3)
F RATING - 2 HR



SECTION A-A

SECTION A-A

SECTION A-A

SECTION A-A

SECTION A-A

SECTION A-A


SECTION A-A

SECTION A-A

SECTION A-A


SECTION A-A

SECTION A-A



PAD MOUNTED TRANSFORMER GROUNDING DETAIL

SCALE: NONE




TRANSFORMER CLEARANCE NOTES:

- 1.) AREA IN FRONT OF DOOR TO BE CLEAR OF ALL ROCKS, STUMPS AND OTHER OBSTRUCTIONS SO THAT THE OPERATOR HAS A SAFE WORKING AREA.
2.) UTILITY COMPANY SHALL HAVE THE RIGHT TO CUT BACK GROWING BUSHES TO WITHIN STATED CLEARANCES.

CLEARANCE FOR PLANTING AROUND TRANSFORMER PAD

SCALE: NONE



EDITOR'S NOTE:

2 TYPICAL BOLLARD ON GRADE DETAIL


SCALE: NONE

LEGEND:

- ① 4-#12 AWG. START CIRCUIT FROM AUTOMATIC TRANSFER SWITCH TO GENERATOR CONTROL PANEL.
② TWISTED SHIELDED PAIR - BELDEN #8841. COMMUNICATIONS CIRCUIT FROM GENERATOR CONTROL PANEL TO REMOTE ANNUNCIATOR.
③ 2-#12 AWG. POWER FROM GENERATOR SET BATTERY TO REMOTE ANNUNCIATOR.
④ POWER CONDUIT FOR BRANCH CIRCUITS TO GENERATOR SET. SEE CIRCUIT INFORMATION FOR ITEMS 5, 6 & 7 BELOW.
⑤ LP1-34
⑥ LP1-36
⑦ LP1-36,40

NOTES:

- 1.) WIRING ON THIS DETAIL SHOWN FOR INFORMATIONAL PURPOSES ONLY. COORDINATE EXACT SIZE, QUANTITY AND TYPE OF WIRING WITH MANUFACTURER'S SUGGESTION FOR EQUIPMENT PURCHASED.
2.) CONDUITS SHALL BE 1" U.O.N.
3.) SEE ONE-LINE DIAGRAM FOR POWER OUTPUT FEEDERS INFORMATION.
4.) SEE SITE PLAN FOR ADDITIONAL REQUIREMENTS.



1 GENERATOR CONTROL WIRING RISER DIAGRAM

SCALE: NONE



Facilities Management
Robert H. Gruffi, P.E., LEED AP
Director Facilities Management
Dr. Robert L. Yeager Health Center
50 Sanatorium Road
Building A, 2nd Floor
Pomona, NY 10970

MEP ENGINEER

OLA Consulting Engineers
50 Broadway
Hawthorne, NY 10532
914.747.2800
8 West 38th Street,
Suite 501
New York, NY 10018
646.849.4110
olace.com

STRUCTURAL ENGINEER

BROOKER ENGINEERING, PLLC
74 Lafayette Avenue, Suite 501
Suffern, NY 10901
945.357.4411
brookerengineering.com

ASBESTOS ABATEMENT

QuES&T
Quality Environmental Solutions & Technologies, Inc.
1376 Route 9, Wappingers
Falls, NY 12590
845.298.6031
qualityenv.com

ESTIMATING

DACK
CONSULTING SOLUTIONS, INC.
2 William St, suite 202
White Plains, NY 10601
914.686.7102
dackconsulting.com

KEYPLAN

CAMPS - KEYPLAN

NO.	DESCRIPTION	DATE
2	RE-ISSUED FOR BID	07/24/2022
1	ISSUED FOR BID	11/01/2021

PROJECT
CAPITAL PROJECT 4466
BUILDING E UTILITY PLANT
RENOVATION & IMPROVEMENTS
DR. ROBERT L. YEAGER HEALTH CENTER
50 SANATORIUM ROAD,
POMONA, NY 10970

DRAWING TITLE

ELECTRICAL DETAILS

SCALE NONE	PROJECT NO. NRCK0016.00
DRAWN BY VB	DRAWING NO.
CHECKED BY ML	E7.2
DATE 04-28-2020	