

BID SPECS: Removal and replacement of Boiler at Senior Center

- Disconnect, demo and remove the old cast iron boiler and remove from the premises
- Supply and install three (3) 262k BTU Dunkirk boilers OR APPROVED EQUAL
- Boilers will be installed in a modular-type fashion and will be able to operate individually or in unison depending on the heating demand
- Each boiler will be connected to a common supply and return manifold
- Each boiler will have its own spark ignition, aquastat relay and required safety controls
- Each boiler will be vented to a 12" common spoke pipe that will tie into the existing chimney
- Coordinate Electrician for 120 volt line to boiler and circulator pump.
- Upon completion of the installation we will start, fire and test the sequence of operation
- Warranty included

Pricing must be based on Rockland County prevailing wage.

Call to set up visit if needed: Location Address: 319 Haverstraw Road,
Suffern, NY