



1. PROVIDE EXHAUST GRILLE AT THE LOCATION SHOWN AND COORDINATE WITH ARCH. RCP. (TYP.)
2. ALL UNUSED DUCT OPENINGS SHALL BE CAP AND SEALED AIR TIGHT.
3. PROVIDE DOOR LOUVER OF 0.7 SQ FT WITH 100% FREE AREA.
4. PROVIDE DOOR LOUVER OF 0.9 SQ FT WITH 100% FREE AREA.
5. PROVIDE NEW WALL RECESSED CONNECTOR FOR CAPACITIES REFER TO DWG M-601.00. INSTALLATION AND CONTROLS TO MATCH BASE BUILDING STANDARDS. COORDINATE WITH BUILDING ENGINEER.

DOB Rev
M-103.00

