

## **SECTION 210518 - ESCUTCHEONS FOR FIRE-SUPPRESSION PIPING**

### **PART 1 - GENERAL**

#### **1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### **1.2 SUMMARY**

- A. Section Includes:
  - 1. Escutcheons.

#### **1.3 ACTION SUBMITTALS**

- A. Product Data: For each type of product.

### **PART 2 - PRODUCTS**

#### **2.1 ESCUTCHEONS**

- A. One-Piece, Steel Type: With polished, chrome-plated finish and setscrew fastener.

### **PART 3 - EXECUTION**

#### **3.1 INSTALLATION**

- A. Install escutcheons for piping penetrations of walls, ceilings, and finished floors.
- B. Install escutcheons with ID to closely fit around pipe, tube, and insulation of piping and with OD that completely covers opening.
  - 1. Escutcheons for New Piping:
    - a. Bare Piping at Wall and Floor Penetrations in Finished Spaces: One-piece steel with polished, chrome-plated finish.
- C. Install floor plates for piping penetrations of equipment-room floors.

#### **3.2 FIELD QUALITY CONTROL**

- A. Using new materials, replace broken and damaged escutcheons and floor plates.

END OF SECTION