



Date: December 9, 2022

To: Marcus Serrano
Village Administrator

From: Tietjen Venegas Consulting Engineers

Project: Buchanan Municipal Building-Boiler Replacement

Addendum #1

- Drawing M-1 - Provide NEMA 1 Variable Frequency Drive (VFD) for P#3 & P#4, 3 HP each and differential pressure controls
- Con Edison – Gas Service Request: Case No. MC-638382