



CITY OF YONKERS
Purchasing

One Larkin Center, 3rd Floor
Yonkers, New York 10701
(914) 377-6037
alex.schenck@YonkersNY.gov

Mike Spano, Mayor
Thomas E. Collich, Director

BID No. IFB-6871, ADDENDUM NO. 2

1 Page

FROM: Alex Schenck, Principal Buyer

DATE: October 3, 2022

The contents of this addendum alter and amend the original bid requirements and take precedence over the related items therein. This addendum forms a part of the contract documents. Bidders must acknowledge receipt of all addenda when submitting their bids. Failure to acknowledge receipt may render your bid as non-responsive and ineligible for award. Vendors are responsible for ensuring that they receive all addenda.

PROJECT NAME: BOILER REPLACEMENT AT HUDSON RIVER MUSEUM

This Addendum consists of the following information:

- 1. ADDITIONAL SITE VISIT OPPORTUNITY. Thursday, October 6, 2022 at 10:00am.**
Access will be provided to all contract areas during this time only. The Museum cannot accommodate other unscheduled visits.

Responses to written RFI's

- I am inquiring about the Boiler Replacement project at the Hudson River Museum. We are a BMS controls vendor and would like to find out if there is an existing BMS system in the building. We see the Div 23 specification calls for a Schneider EcoStructure system. We would like to confirm if Schnedier is indeed the existing BMS vendor and that the bid is not open to other controls companies. This will give us confirmation on whether [our company] should bid the job to mechanical contractors.*

RESPONSE: The existing automatic temperature controls system in the Hudson River Museum is largely pneumatic. Substitutions will be considered in accordance with provisions of the contract documents during the submittal review process.

END OF BID ADDENDUM NO. 2

The Bid due date remains 2:00 PM on October 14, 2022.

IFB-6871 ADDENDUM No. 2 ACKNOWLEDGEMENT

Please submit acknowledgements with your bid

Bidding Firm: _____

Address: _____

Bidder's Representative: _____ Title: _____

Signature: _____ Date: _____