



**CITY OF YONKERS**  
*Purchasing*

One Larkin Center, 3<sup>rd</sup> Floor  
Yonkers, New York 10701  
(914) 377-6037  
alex.schenck@YonkersNY.gov

Mike Spano, Mayor  
Thomas E. Collich, Director

**BID No. IFB-6871, ADDENDUM NO. 5**  
**FROM: Alex Schenck, Principal Buyer**

**1 Page**  
**DATE: October 12, 2022**

*The contents of this addendum alter and amend the original bid requirements and take precedence over the related items therein. This addendum forms a part of the contract documents. Bidders must acknowledge receipt of all addenda when submitting their bids. Failure to acknowledge receipt may render your bid as non-responsive and ineligible for award. Vendors are responsible for ensuring that they receive all addenda.*

**PROJECT NAME: BOILER REPLACEMENT AT HUDSON RIVER MUSEUM**

**RESPONSES TO WRITTEN RFI's**

1. Details of storefront/curtain wall frame on A-006 show the frame as a curtain wall system with a 2 ½" sightline & 6 or 7 ½" depth, depending on the detail. Part 2.3.A.1 of spec section 084112 Aluminum Framed Storefronts & Entrances says that storefront entrance framing should be Kawneer Trifab VG 451T which has a 2" sightline & 4 ½" depth. Please clarify if the frame shown on sheets A-005 & A-006 should be curtain wall framing as shown on the drawings or storefront framing as called for in the details. If it is to be curtain wall, please clarify the required system depth as the details show both 6" & 7 ½" depth.

**Response: Storefront framing should be Kawneer Trifab VG451T.**

2. Detail 3/A-006 says that the pair of doors in the aluminum frame shown in A-005 are hollow metal. Aluminum frame manufacturer does not recommend hanging hollow metal doors in aluminum frames. Aluminum frame manufacturer recommends using either aluminum flushline doors or aluminum storefront doors with a glazed metal panel if doors without vision lites are required for this location. Please advise.

**Response: An aluminum flushline door is acceptable in lieu of the hollow metal door.**

END OF BID ADDENDUM NO. 5

*The Bid due date remains 2:00 PM on October 14, 2022.*

**IFB-6871 ADDENDUM No. 5 ACKNOWLEDGEMENT**

Please submit acknowledgements with your bid

Bidding Firm: \_\_\_\_\_

Address: \_\_\_\_\_

Bidder's Representative: \_\_\_\_\_ Title: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_