



NOTES:

- UNLESS OTHERWISE SPECIFIED, PIPE FOR WATER SUPPLY AND DISTRIBUTION LINES SHALL BE POLYVINYL CHLORIDE PRESSURE PIPE (PVC), CLASS 235 PSI, OR 18, WITH PUSH-ON JOINTS IN ACCORDANCE WITH AWWA C-300 (BLUE BRUTE).
- WATER MAIN SHALL HAVE A MINIMUM 18" CLEARANCE TO SANITARY SEWER AND DRAINAGE PIPES AND A MINIMUM 12" CLEARANCE TO ALL OTHER UTILITIES.

PROFILES

VERTICAL SCALE: 1" = 10'

SCALE IN FEET

HORIZONTAL SCALE: 1" = 30'

SCALE IN FEET

10/14/2022 REV. FOR NYCDP SUBMISSION 03/25/2022 REV. PER TOWN COMMENTS 03/07/2022 REV. PER TOWN COMMENTS	3 2 1	Date Description No.	Revisions
WARNING: IT IS A VIOLATION OF THE NYS EDUCATION LAW ARTICLE 146 FOR ANY PERSON, UNLESS HE IS ACTING UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER, LAND SURVEYOR OR GEOLOGIST, TO ALTER THIS ITEM IN ANY WAY.			
		11/7/2022 Date Signature PROFESSIONAL ENGINEER	
		T: 914.323.7400 F: 914.323.7401 www.langan.com	
Project LINCOLN LOGISTICS BREWSTER		Drawing Title WATERLINE PROFILES (1 OF 9)	
Project No. 190065201		Drawing No. C-310	
Date 1/28/2022		Sheet 29 of 97	
Drawn By JMSK		Checked By CZMF	
Town of Southeast PUTNAM COUNTY NEW YORK			

82020 Langan