





1. UNLESS OTHERWISE SPECIFIED, PIPE FOR WATER SUPPLY AND DISTRIBUTION LINES SHALL BE POLYVINYL CHLORIDE PRESSURE PIPE (PVCP), CLASS 235 PSI, DR 18, WITH PUSH-ON JOINTS IN ACCORDANCE WITH AWWA C-900 (BLUE BRUTE).

2. WATER MAIN SHALL HAVE A MINIMUM 18" CLEARANCE TO SANITARY SEWER AND DRAINAGE PIPES AND A MINIMUM 12" CLEARANCE TO ALL OTHER UTILITIES.

Date: 10/17/2022 Time: 17:42 User: jmacalintal Style Table: Langan.stb Layout: C-316 Document Code: 190065201-0501-CU202-0107

PROFILES

VERTICAL SCALE: 1" = 10'

HORIZONTAL SCALE: 1" = 30'