



2900 NEWPARK DRIVE
BARBERTON, OHIO 44203
1-888-857-2817
330-706-3040 ext 258

August 24, 2023

Mr. Forrester,


The following revisions have been made to Lincoln Equites Southeast (Bldg A & B, NY-131 & NY-312 at Pugsley Rd, Brewster, NY 10509) per sch 10 pipe upgrade and manual air vents.

1.

Please see attached revised drawings and hydraulic calculations. Branch line piping has upgraded from scheduled 7 pipes to scheduled 10 pipes. Manual air vents have upgraded to automatic air vents.

We hope that this letter along with the revised drawings and Hydraulic Calculations submitted will provide you with all the information you need to approve this submittal. If you have any questions, please feel free to contact us.

Sincerely,



JR Fowler
SA Comunale, Inc.
Design

JR.Fowler@comunale.com
330-706-3040