

REBID
ADDENDUM NO. 2
TO
CONTRACT DOCUMENTS
AND
TECHNICAL SPECIFICATIONS
FOR
NEW KITCHEN DESIGN
AT
MAMARONECK AVENUE SCHOOL
(MECHANICAL, PLUMBING & ELECTRICAL ONLY)
NYSED #66-07-01-03-0-004-033
BID # 23/24-MUFSD-017

Mamaroneck Union Free School District
1000 West Boston Post Road
Mamaroneck, NY 10543

Telephone No. 914-220-3040

Contact: Ms. Sylvia Wallach
Assistant Superintendent for Business

LAN Job #4.1092.85
August 18, 2023

Michael J. McGovern, RA
NYS #022257

1.0 General: The original contract documents dated **August 2, 2023**, issued to the New York State Education Department (NYSED) for this project are hereby amended as noted in this NYSED addendum which shall become part of said contract documents, as if originally included therein. Bidders must acknowledge receipt of this NYSED addendum and all other addenda on the proposal form when submitting proposals. In case any bidder fails to acknowledge receipt of addenda, his proposal will nevertheless be construed as though it has been received, acknowledged, and the submission of his proposal shall constitute acknowledgment by the bidder of the receipt of same.

This is to advise all prospective bidders that this addendum has been issued to all bidders and that it contains a change in the contract documents.

2.0 Amendments to Specifications:

Section No.	Page No.	Addendum Requirements
N/A		

3.0 Amendments to Drawings:

Drawing No.	Addendum Requirements
E2.01	Drawing E2.01 has been revised to indicate that circuits 14, 15, 16, 17, & 18 (feeding the Convection Ovens, Range, and Steamers) in panel KPL0 are Shunt Trip and tied into the hood/ANUSL system and shall disconnect upon activation of the hood system. This drawing is not being reissued.

4.0 Requests for Information (RFIs):

No.	Comment/Response
N/A	

5.0 Clarifications:

No.
N/A

END OF ADDENDUM NO. 2