

**84 CHALET ROAD
KIAMESHA LAKE, NY 12751**

120 HUYSHOPE AVENUE
SUITE 400
HARTFORD, CT 06106
860.247.9226

© 2019 JCJ Architecture

MEP & FP ENGINEER

M/E ENGINEERING
60 LAKEFRONT BOULEVARD, SUITE 320
BUFFALO, NY 14202
716.845.5092

AKRF ENGINEERING
34 SOUTH BROADWAY, SUITE
WHITE PLAINS, NY 10601
914-949-7336

THE SIZES INDICATED ABOVE ARE BASED ON PRELIMINARY HYDRAULIC CALCULATIONS. THE FIRE PROTECTION CONTRACTOR SHALL PERFORM FINAL CALCULATIONS ON THE COORDINATED SYSTEM DESIGN TO VERIFY SIZES PRIOR TO COMMENCING WORK.

THE SIZES INDICATED ABOVE ARE BASED ON PRELIMINARY HYDRAULIC CALCULATIONS. THE FIRE PROTECTION CONTRACTOR SHALL PERFORM FINAL CALCULATIONS ON THE COORDINATED SYSTEM DESIGN TO VERIFY SIZES PRIOR TO COMMENCING WORK.

GENERAL NOTES

- A. CONTRACTOR SHALL COORDINATE PIPE ROUTINGS WITH STRUCTURE, DUCTWORK, PIPING LIGHTS, ETC. PIPING SHALL NOT BE INSTALLED ABOVE ELECTRICAL PANELS. INSTALL PIPING AS HIGH AS POSSIBLE.
- B. CONTRACTOR SHALL COORDINATE SPRINKLER LOCATIONS WITH STRUCTURE, DUCTWORK, DIFFUSERS, LIGHTS, REFLECTED CEILING PLANS, ETC.
- C. REFER TO ARCHITECTURAL DRAWINGS FOR ADDITIONAL INFORMATION REGARDING NEW WORK.
- D. CONTRACTOR SHALL DRAIN AND REFILL SYSTEM UPON COMPLETION OF WORK AND PERFORM ALL TESTING.



- A. REFER TO FLOOR PLANS FOR LOCATION OF FIRE PROTECTION SERVICE ENTRANCE.
- B. ALL COMPONENTS SHALL BE PROVIDED IN ACCORDANCE WITH NFPA 13. LOCAL AUTHORITIES HAVING JURISDICTION AND COMPONENTS MANUFACTURERS. CONTRACTOR FOR ELECTRICAL WORK WILL WIRE ALARM, TAMPER SWITCHES, PRESSURE AND FLOW SWITCHES. COORDINATE ELECTRICAL CHARACTERISTICS OF DEVICES WITH CONTRACTOR FOR ELECTRICAL WORK.
- C. PROVIDE PROPER PIPE SUPPORTS. PAINT WITH ONE (1) PRIMER AND TWO (2) FINISH COATS OF BLACK PAINT.



- A. NOT LESS THAN 4' OF EXPOSED TEST PIPE IN WARM ROOM BEYOND VALVE WHEN PIPE EXTENDS THRU WALL TO OUTSIDE



- A. ELECTRICAL EQUIPMENT INCLUDES PANELS, TRANSFORMERS, DISCONNECTS, STARTERS, MOTOR CONTROL CENTERS, SWITCHGEAR, ADJUSTABLE SPEED DRIVES, AND FUSED SWITCHES (THIS ALSO APPLIES TO ELECTRICAL GEAR MOUNTED DIRECTLY ON MECHANICAL EQUIPMENT).
- B. DEDICATED ELECTRICAL SPACE IS DEFINED BY NEC 110.
- C. NO PIPING OR DUCTWORK MAY BE INSTALLED IN DEDICATED ELECTRICAL SPACE OR WORKING SPACE.



PERMIT SET
09/30/2021



P.I.C. _____ L.D. _____
P.M. _____ P.A. _____

ISSUE 09/30/21

JOB H18064.14

DRAWN DMS2

SCALE NOT TO SCALE

REVISIONS:

DETAILS, SCHEDULES AND SYMBOL LISTS - FIRE PROTECTION

FP-002