



1. ALL AND ANY REFRIGERANT PIPING IN PUBLIC AREAS SHALL BE INSTALLED BEHIND A 2 HOUR RATED ENCLOSURE.

2. ALL REFRIGERANT PIPING SIZES ARE INDICATIVE. MECHANICAL CONTRACTOR TO CONFIRM FINAL PIPE DIAMETERS IN FIELD. ALL REFRIGERANT PIPING SHALL BE INSTALLED PER MANUFACTURER'S REQUIREMENTS AND RECOMMENDATIONS.

3. ALL REFRIGERANT AND CONDENSATE PIPING INCLUDING PIPE INSULATION SHALL BE PAINTED. MECHANICAL CONTRACTOR TO COORDINATE WITH ARCHITECT.

4. XXXXXXXXXXXXXXXX

Colliers COLLIERS ENGINEERING & DESIGN
555 Hudson Valley Ave, Ste 101
New Windsor, NY 12553

LEGACY ENGINEERS
498 Seventh Avenue, 17th Floor South
New York, NY 10018

[illegible]

M-300.00

ISSUE DATE: 9-27-23
SCALE: NTS
DWG BY: DWM
CHK BY: CHECK

23025-00