

- DRAWING NOTES:**
- REFER TO DRAWING E-000.00 FOR GENERAL NOTES, ABBREVIATIONS, SYMBOL LIST ETC.
 - FOR EXACT LOCATIONS OF ALL MECHANICAL EQUIPMENT, REFER TO HVAC, PLUMBING, AND SPRINKLER DRAWINGS.
 - FOR ALL MISCELLANEOUS ELECTRICAL CIRCUITS REFER TO EXISTING PANEL "EP12" (NORMAL) U.O.N. CIRCUIT NUMBERS ARE DIAGRAMMATIC. FIELD CONDITIONS PREVAIL. IT IS THE ELECTRICAL CONTRACTORS RESPONSIBILITY TO PROPERLY BALANCE ALL BRANCH CIRCUITS BETWEEN THE PHASES OF THE SYSTEM, REGARDLESS OF THE CIRCUITING INDICATED. PANEL EP12, = #X.
 - ALL WORK SHALL COMPLY WITH THE BASE BUILDING STANDARDS AND ELECTRICAL SPECIFICATIONS.
 - REFER TO AV CONSULTANT'S DRAWING FOR ALL EMPTY CONDUIT REQUIREMENTS, RECEPTACLE LOCATIONS AND EQUIPMENT REQUIRED FOR THE AV SYSTEM.
 - PROVIDE A MINIMUM 2#10-1#10G IN 3/4" EMT FOR ALL NEW CIRCUITS U.O.N. TYPE "MC" CABLE MAY BE USED FOR BRANCH CIRCUITS FOR LIGHTING, RECEPTACLES, AND MISCELLANEOUS LOADS. MULTI CIRCUIT HOMERUNS SHALL BE PROVIDED WITH #10AWG NEUTRAL CONDUCTORS U.O.N.
 - CONTRACTOR SHALL COMPLY WITH THE WIRING REQUIREMENTS OF THE 2011 NEW YORK CITY ELECTRICAL CODE, TABLE 310.15(B)(2)(a) FOR ADJUSTMENT FACTORS ASSOCIATED WITH MORE THAN THREE CURRENT CARRYING CONDUCTORS IN A RACEWAY.
 - COORDINATE EXACT LOCATIONS OF RECEPTACLES WITH ARCHITECT. SCALING OF ENGINEERING DRAWINGS FOR LOCATIONS OF DEVICES SHALL NOT BE PERMITTED.
 - INSTALL TELE/DATA BOXES AND AN EMPTY CONDUIT SYSTEM TELE/DATA CABLING BY OTHERS. INSTALL PULL DRAG WIRE IN EACH CONDUIT. REFER TO TELECOMMUNICATION SCOPE OF WORK DOCUMENT FOR ALL TELEPHONE/DATA CABLING REQUIREMENTS.
 - ELECTRICAL CONTRACTOR SHALL PROVIDE JUNCTION BOXES AND CONDUITS FOR ALL SECURITY SYSTEM DEVICES INCLUDING BUT NOT LIMITED TO CARD READER, PUSH PLATE AND CAMERAS. COORDINATE REQUIREMENTS WITH INSTALLING CONTRACTOR AND SECURITY DOCUMENTS.

- KEY NOTES:**
- ALL SECURITY SYSTEM DEVICES SHALL BE COORDINATED WITH SECURITY VENDOR REFER TO NOTE #10 ABOVE.
 - CONNECT MOTORIZED DAMPER TO ROOM LIGHTING CIRCUIT.

Berg+Moss Architects

BMA

BERG + MOSS ARCHITECTS PC
THE BEACON BUILDING
473 MAIN STREET No. 1
BEACON, NY 12508
T: 845 831 1318
INFO@BERGMOSS.COM

STRUCTURAL/ CIVIL ENGINEERS

Colliers

COLLIERS ENGINEERING & DESIGN

555 Hudson Valley Ave., Ste 101
New Windsor, NY 12553

MECHANICAL ENGINEERS


LEGACY ENGINEERS

LEGACY ENGINEERS

498 Seventh Avenue, 17th Floor South
New York, NY 10018

SPRING VALLEY VILLAGE

SPRING VALLEY
POLICE LOCKER
UPGRADES



DRAWING TITLE
ELECTRICAL 1ST FLOOR
PLAN - POWER

DRAWING NO.
E-300.00

SEAL & SIGNATURE

ISSUE DATE: 9-27-23
SCALE: NTS
DWG BY: DWN
CHK BY: CHECK

JOB NUMBER

23025-00