

11. Trough Drain Shown on P100 in the Laundry Room & on P500 Detail #8 - **Question:** Which contractor is responsible for furnishing and installing the steel grate & concrete pit? **Response:** The plumbing contractor is responsible for furnishing and installing the steel grate and concrete pit.
12. Plumbing Fixtures on P100 - **Question:** Equipment symbols KS-1 & S-1 are shown on P100 but are not shown on the Plumbing Equipment Schedule found on P601. Will the owner be providing these fixtures?
Response:
- SINK (KS-1)
JUST, MODEL #DLN-ADA-2133-A-GR
DROP-IN DOUBLE COMPARTMENT SINK, 18 GAUGE TYPE 304 STAINLESS STEEL, 3-HOLE, ADA ACCESSIBLE, 33" LONG x 21" WIDE, (2) BOWL 16" LONG x 14" WIDE x 6 1/2" DEEP BOWL, FULLY UNDERCOATED. DRAINS CENTERED. INSTALL IN ACCORDANCE WITH ANSI A117.1 AND ADA STANDARDS FOR HANDICAP ACCESSIBILITY.
 - FAUCET (KS-1)
JUST, MODEL #JPO-250
FAUCET, SINGLE LEVER HANDLE, PULL OUT SPRAY, ANGLE STOPS, CHROME FINISH, CERAMIC DISC CARTRIDGE, ADA COMPLIANT. QUARTER TURN BALL VALVE STOPS, BASKET STRAINERS. AND 17 GAUGE CHROME PLATED BRASS P-TRAP W/CLEANOUT.
 - SINK (S-1)
JUST, MODEL #DLN-ADA-2133-A-GR
DROP-IN DOUBLE COMPARTMENT SINK, 18 GAUGE TYPE 304 STAINLESS STEEL, 3-HOLE, ADA ACCESSIBLE, 33" LONG x 21" WIDE, (2) BOWL 16" LONG x 14" WIDE x 6 1/2" DEEP BOWL, FULLY UNDERCOATED. DRAINS CENTERED. INSTALL IN ACCORDANCE WITH ANSI A117.1 AND ADA STANDARDS FOR HANDICAP ACCESSIBILITY.
 - FAUCET (S-1)
JUST, MODEL #JPO-250
FAUCET, SINGLE LEVER HANDLE, PULL OUT SPRAY, ANGLE STOPS, CHROME FINISH, CERAMIC DISC CARTRIDGE, ADA COMPLIANT. QUARTER TURN BALL VALVE STOPS, BASKET STRAINERS. AND 17 GAUGE CHROME PLATED BRASS P-TRAP W/CLEANOUT.
13. Contract Add Alternate No. 5 has been reassigned to the GC. It will be the GC's responsibility to supply and install all 8-inch water line, valves, and fittings from the existing main located in the Dutchess Park Shopping Center and Office Park to the Rombout Fire District property as indicated on Drawing C14 and in the details included in the project plan set. See the revised attached Form for Bidding.
14. The GC is responsible for the installation of the gas main to 5' of the building. The HVAC Contractor is responsible for the gas main from inside the building to 5' of the exterior of the building.
15. The Pump Station is the responsibility of the GC, the oil and water separator is the responsibility of the GC, the Generator is installed by the Electrical contractor (Generator Purchase by Fire Department). Gas service piping to the Pump Station generator is the responsibility of the GC. The Gas meter and regulator is the responsibility of the HVAC Contractor.
16. Attached in this addendum is the Specification Section 08360 Overhead Doors and Section 08410 Metal Framed Storefront.

End of Addendum No. 1