

Addendum A

- A. The Bidding Documents for the above referenced project are hereby revised as noted in Addendum for USPS SDC Mid Hudson NY.
- B. This Addendum supersedes and takes precedence over information provided prior to the date of this Addendum.

Changes to Scope of Work

1. The scope of work includes all labor and materials necessary to complete the both the interior and exterior work identified. USPS provided, contractor installed equipment includes:
 - EV Charging Stations
2. Revise keynotes 1 and 2 on sheet E201.1
 - Provide 13 Power Poles (each power pole including 4 electrical outlets and 6 data ports)
 - Provide 24 single outlets (serving carrier cases)
 - Note:
 - USPS to provide exact locations via an Operations Systems Layout prior to construction
 - CAT 6 data lines shall not exceed 290' and shall be terminated at locations specified by USPS.

End of Addendum A