HVAC WORK COORDINATION

COORDINATE ALL HVAC WORK ASSOCIATED WITH THIS WORK WITH ON GOING HVAC UPGRADE PROJECT ENGINEER AND CONTRACTOR.

EXISTING HYDRONIC FINNED TUBE RADIATOR TO REMAIN.

**GENERAL NOTES** 

SPECIFICATIONS.

ELECTRICAL CONTRACTOR.

CONDITION SHALL APPLY.

PLAN KEYNOTES

OF FAN AND EXISTING DUCTWORK.

SEAL ALL PENETRATION WATERTIGHT.

ON PROJECT.

EQUIPMENT.

MATERIAL.

AND COORDINATE THE INSTALLATION OF MECHANICAL MATERIALS AND

PERIOD OF ONE (1) YEAR AFTER FINAL ACCEPTANCE OF INSTALLATION. CONTRACTOR SHALL UTILIZE SERVICES OF A PROFESSIONAL BALANCE

TO ACHIEVE THE AIRFLOWS INDICATED AND AS REQUIRED PER THE

WITH QUALITY CAULK SUBJECT TO THE APPROVAL OF THE ENGINEER.

ALL FIRE PROTECTION SIGNAL OR CONTROL WIRING SHALL BE BY FIRE

MUST BE CUT AND/OR REMOVED FOR INSTALLATION OF DUCTWORK OR

MECHANICAL EQUIPMENT WITH THE APPROVAL OF THE ENGINEER.

REPRESENTATIVE CONDITIONS OF THE ROOM.

STRUCTURAL ELEMENTS, AND ELECTRICAL CONDUITS.

**SPECIFICATIONS NOTE** 

RECENT USPS MPF SPECIFICATION.


ALL EQUIPMENT, MATERIALS AND INSTALLATION PRACTICES TO MEET THE REQUIREMENTS AND SPECIFICATIONS DETAILED IN THE MOST


8. ALL TEMPERATURE SENSORS SHALL BE LOCATED AWAY FROM LOCAL HEAT SOURCES, AIRFLOW FROM SUPPLY GRILLES, AND IN AN AREA WITH

OR IMPLIED ON MECHANICAL SHEETS EXCEPT AS NOTED.


## **DUCTWORK NOTE**


ALL DUCTWORK, GRILLES AND DIFFUSERS ARE EXISTING UNLESS OTHERWISE NOTED. THE ONLY NEW DUCTWORK TO BE INSTALLED IS ANY DUCTWORK REQUIRED TO TRANSITION TO NEW EXHAUST FAN. EXISTING DUCTWORK, GRILLES AND DIFFUSERS SHALL BE CLEANED AND ASSESSED. UPON ASSESSMENT IF ANY IS DAMAGED OR DEEMED BEYOND USUABLE LIFE CONTRACTOR SHALL REPLACE IN KIND.





MECHANICAL - ENLARGED PLAN C1 - NEW WORK





MECHANICAL - ENLARGED PLAN A3 - NEW WORK

— AREA OF WORK -SEE C1/M-101.1

01