

ICI No. 11

Filter Room Exhaust Fans

Description: Replace the existing 3 exhaust fans with all aluminum construction exhaust fans rated for the environment.

The exhaust fans shall be model XW manufactured by Loren Cook.

Location: Filter Room

Related

Improvements: Existing conduit and wire shall be extended as required for the installation. Provide supports as necessary.

ICI No. 12

Air Handling Unit 1 & 2

Description: Replace the existing air handling units in kind.

The air handlers shall be M series manufactured by Trane.

Location: HVAC Mezzanine Room

Related

Improvements: Existing conduit and wire shall be extended as required for the installation. Adjust associated duct as necessary.

ICI No. 13

Air Handling Unit 1 & 2

Description: Replace the existing ducted split system units in kind.

The air handlers shall be TWE manufactured by Trane.
The condensers shall be TTA manufactured by Trane.

Location: ACU-1: Blower Room
ACU-2: Filter Room

Related

Improvements: Existing conduit and wire shall be extended as required for the installation. Adjust associated duct as necessary. Provide new interconnecting refrigerant piping and piping insulation.

ICI No. 14

Chemical Storage Exhaust Fans

Description: Replace the existing exhaust fan with all aluminum construction exhaust fans rated for the environment.

The exhaust fans shall be model CV manufactured by Loren Cook.

Location: Chemical Storage Room

Related

Improvements: Existing conduit and wire shall be extended as required for the installation. Provide supports as necessary. Adjust associated duct as necessary.

ICI No. 15

Filter Room GUH Thermostats

Description: Replace the existing 6 thermostats with thermostats rated for the environment.
The thermostat shall be model EPETD8D manufactured by TPI Corporation.

Location: Filter Room

Related
Improvements: Existing conduit and wire shall be extended as required for the installation.

ICI No. 11 - SUB - HVAC

- **Description:** Replace the existing 3 exhaust fans with all aluminum construction exhaust fans rated for the environment. The exhaust fans shall be model XW manufactured by Loren Cook.
- **Related Improvements:** Existing conduit and wire shall be extended as required for the installation. Provide supports as necessary.




ICI No. 12 - SUB - HVAC

- **Description:** Replace the existing air handling units in kind. The air handlers shall be M series manufactured by Trane.
- **Related Improvements:** Existing conduit and wire shall be extended as required for the installation. Adjust associated duct as necessary.



ICI No. 13 - SUB - HVAC

- **Description:** Replace the existing ducted split system units in kind. The air handlers shall be TWE manufactured by Trane. The condensers shall be TTA manufactured by Trane.
 - ACU-1: Blower Room
 - ACU-2: Filter Room
- **Related Improvements:** Existing conduit and wire shall be extended as required for the installation. Adjust associated duct as necessary. Provide new interconnecting refrigerant piping and piping insulation.



ICI No. 14 - SUB - HVAC

- **Description:** Replace the existing exhaust fan with all aluminum construction exhaust fans rated for the environment. The exhaust fans shall be model CV manufactured by Loren Cook.
- **Related Improvements:** Existing conduit and wire shall be extended as required for the installation. Provide supports as necessary. Adjust associated duct as necessary.



ICI No. 15 - SUB - HVAC

- **Description:** Replace the existing 6 thermostats with thermostats rated for the environment. The thermostat shall be model EPETD8D manufactured by TPI Corporation.
- **Related Improvements:** Existing conduit and wire shall be extended as required for the installation.

