



GAS STORAGE WATER HEATER SCHEDULE																
DESIGNATION	NO. REQUIRED	SERVICE	MANUFACTURER AND MODEL NUMBER	STORAGE WATER TEMPERATURE (DEG.F)	VOL. OF STORAGE TANK (GALS.)	RECOVERY/HEATER (GPH)	TEMPERATURE RISE (DEG. F)	MAXIMUM WATER FLOW (G.P.M.)	W.W.P. (PSIG.)	TANK DIAMETER (INCHES)	TANK HEIGHT (INCHES)	VOLTAGE	PHASE	GAS INPUT (CFH)	REMARKS	DRAWING NO.
DWH	1	RESTROOMS/SHOWERS	AO SMITH CYCLONE HE POWER VENT	120°F	50	86	100	64	125	22	60	120	1	700	PROVIDE CONDENSATE ACID NEUTRALIZING KIT MOD Z-12	


[illegible]

PUMP SCHEDULE																												
DESIGNATION	NO. REQUIRED	SERVICE	LOCATION	FLOW RATE (GPM)	MAXIMUM TOTAL DYNAMIC HEAD (FT.)	MINIMUM TOTAL DYNAMIC HEAD (FT.)	CASING PRESSURE (PSIG)	MANUFACTURER MODEL NUMBER	STAGES	VERTICAL SPLIT	HORIZONTAL SPLIT	END SUCTION	IN LINE	VERTICAL TURBINE	SUBMERGIBLE	MOTOR					MANUAL CONTROL	AUTOMATIC CONTROL	PILOT LIGHT	PRESSURE GAUGE RANGE	ALARMS REQUIRED	EMERGENCY POWER REQUIRED	REMARKS	DRAWING NO.
																MINIMUM HP.	RPM	VOLTS	PHASE	CYCLES /HZ								
EJ-1	2	CELLAR	CELLAR - MECH. ROOM	25	15			WEIL MODEL NO. 2426							X	0.5	1750	208	3	60		X			X		PROVIDE WITH 8159 CONTROL PANEL, 8230 TETHERED CONTROLS, 8341 HIGH WATER REMOTE ALARM PANEL, 8805 ROUND COVER. INSTALL IN 36" DEEP, 36" DIA BASIN.	P-100
RC-1	1	HOT WATER RECIRCULATION	CELLAR - BOILER ROOM	2	10		140	CRUNDFOS UP15-29								1/8		115	1	60		X						P-300

PLUMBING FIXTURE SCHEDULE									
	DESCRIPTION			SERVICE CONNECTION					REMARKS
DESIGNATION	FIXTURE	MANUFACTURER	MODEL & NUMBER	S	W	V	CW	HW	
F-1A	WATER CLOSET	KOHLER	96057-0	4"	-	2"	1 1/4"	-	ADA COMPLIANT TOILET, FLOOR MOUNTED TOILET
	SEAT	KOHLER	4731-C-0						
	FLUSH VALVE	KOHLER	K-7531						
	-								
F-1B	WATER CLOSET	KOHLER	96053-0	4"	-	2"	1 1/4"	-	FLOOR MOUNTED TOILET
	SEAT	KOHLER	4731-C-0						
	FLUSH VALVE	KOHLER	K-7531						
	-								
F-2	URINAL	KOHLER	4991-ET-0	-	1 1/2"	1 1/2"	1/2"	1/2"	WALL HUNG HIGH EFFICIENCY URINAL
	FLUSH VALVE	KOHLER	B-38034						
	-								
	-								
F-3A	LAVATORY	KOHLER	K-2031	-	1 1/2"	1 1/2"	1/2"	1/2"	WALL-MOUNTED BATHROOM SINK, PROVIDES K-8998 P-TRAP
	FAUCET	KOHLER	K-97283-4						
	DRAIN / TRAP	KOHLER	K-7129-A-VS						
	-								
F-3B	LAVATORY	KOHLER	K-2882-95	-	2"	1 1/2"	1/2"	1/2"	UNDER-MOUNTED BATHROOM SINK
	FAUCET	KOHLER	K-97283-4						
	DRAIN / TRAP	KOHLER	K-7129-A-VS						
	-								
F-4	SINK	ELKAY	LRAD191885	-	2"	1 1/2"	1/2"	1/2"	SIZE: 19"x18"x5"-12"
	FAUCET	DELTA	1980-DST						
	-								
	-								
F-5	FOUNTAIN	ELKAY	LZWS-LRPBM26K	-	2"	1 1/2"	1/2"	1/2"	REFRIGERATED + FILTERED
	-								
	-								
	-								
F-6	SERVICE SINK	KOHLER	K-6710	-	3"	1 1/2"	3/4"	3/4"	FLOOR-MOUNTED SERVICE SINK
	FAUCET	KOHLER	K-8905						
	DRAIN / TRAP	KOHLER	K-8801						
	-								
F-7	SHOWER	FREEDOM	APF38.38BF 1P RRF, APFQ38.38BF1PRRF	-	2"	1 1/2"	1/2"	1/2"	ADA COMPLIANT SHOWER WITH PRESSURE BALANCE CARTRIDGE AND SHOWER BODY KIT
	CARTRIDGE	AMERICAN STANDARD	TU353502						
	SHOWER BODY	AMERICAN STANDARD	1662.601						
	BASE	AMERICAN STANDARD	4834.STTS						
	-		-						
F-8	HOSE BIBB	-	-	-	-	-	3/4"	-	
F-9	NON-FREEZE WALL HYDRANT	ZURN	Z1305	-	-	-	3/4"	-	

NOTE:
1. REFER TO ARCHITECTURAL DRAWINGS FOR FURTHER ACCESSORIES AND DETAILS REGARDING PLUMBING FIXTURES.

ISSUE NO.5	09/03/2024	ISSUED FOR BID
ISSUE NO.4	07/10/2024	UPDATED 100% CONSTRUCTION DOCUMENT SUBMISSION
ISSUE NO.3	06/06/2024	100% CD SUBMISSION
ISSUE NO.2	03/29/2024	90% CD SUBMISSION
ISSUE NO.1	12/14/2023	60% SUBMISSION
ISSUE NO.	ISSUE DATE	DESCRIPTION



CAPITAL PROJECT #1521
SHERIFF'S OPERATIONS
BUILDING

23 NEW HEMPSTEAD RD
NEW CITY, NY 10956

PLUMBING SCHEDULES

PROJECT NO.:	25097	SCALE:	AS NOTED
--------------	-------	--------	----------

DRAWING NO.:

P500.00