



Town of Mamaroneck
Engineering Department, Town Center
740 West Boston Post Road, Mamaroneck, NY 10543-3353

TEL: 914/381-7835
FAX: 914/381-8473

Robert P. Wasp, P.E., C.D.T.
Town Engineer

rwasp@townofmamaroneckNY.org

DATE: January 10, 2024
TO: All Plan Holders
FROM: Robert Wasp, PE, CDT, Town Engineer
SUBJECT: **Contract TA-24-02 – Addendum #3**
Hommocks Ice Rink HVAC Upgrades

Regarding the above-mentioned project, our office received an emailed Request for Information dated 01/10/2024. Responses to RFI questions are provided as form of addendum to the contract.

All contract provisions unaffected by the following addended information shall remain in full force and effect.

Response to RFI

- 1) Please advise if exposed ductwork in conditioned space is required to be painted or insulated?

Response: The exposed ductwork in conditioned space is not required to be painted or insulated.

END OF ADDENDUM #3