


3 Typical Mounting Heights  
12" = 1'-0"

DETECTOR LOCATION REQUIREMENTS (NFPA 72)			
d = DEPTH OF WALL SECTION ABOVE DOOR	DOOR FRAME MOUNTED (SMOKE DETECTOR LISTED FOR FRAME MOUNTING OR AS PART OF CLOSER ASSEMBLY)	CEILING MOUNTED (SMOKE DETECTOR)	
0-24" ON BOTH SIDES OF DOORWAY		A	B
over 24" ON ONE SIDE ONLY		C	D
over 24" ON BOTH SIDES		E	F
over 60"	MIGHT REQUIRE ADDITIONAL DETECTORS		


1 Smoke Detector Mounting Requirements  
12" = 1'-0"



2 Fire Alarm System Wiring Diagram  
12" = 1'-0"

S.E.D. Control No. 62-18-01-06-0-002-015

Rev. No.: Date: Description:



complex world | CLEAR SOLUTIONS

Tetra Tech Engineers, Architects & Landscape Architects, P.C.



Wallkill Central School District  
Wallkill, New York

Reconstruction to:  
John G. Borden Middle School

Details

Drawn By: Author: Date: 06/30/2023 Drawing Number: 17597-22002 Project No.: BE500