

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

A

B

C

D

E

F

G

H

I

J

K

L

M

N

LUMINAIRE SCHEDULE

TYPE	SYMBOL	DESCRIPTION	LAMPS			MANUFACTURERS (OR EQUAL)	
			WATTAGE	LUMENS	TYPE	NAME	MODEL OR SERIES
1 EM		4" WET LOCATION RECESSED DOWNLIGHT WITH INTEGRAL BATTERY	19.8	1500	LED	HE WILLIAMS	4DR-TL-L15-835-DIM1-EM7W-UNV-O-W-OF-CS-WET/CC-N- F1
2		2' x 2' FLAT PANEL (RECESSED IN GRID)	30	3393	LED	UTOPIA LIGHTING	ULP-2G-22-L30(3500)
2 EM		SAME AS TYPE 2 - WITH INTEGRAL BATTERY	30	3393	LED	UTOPIA LIGHTING	ULP-2G-22-L30-LM10(3500)
3		2' x 2' FOOD PROCESSING LUMINAIRE (RECESSED IN GRID)	45	4500	LED	KENALL LIGHTING	45LD-35K8-DIM1-DV-SF-4H
3 EM		SAME AS TYPE 3 - WITH INTEGRAL BATTERY	45	4500	LED	KENALL LIGHTING	45LD-35K8-DIM1-DV-SF-4H
4		2" GERMICIAL CONTINUOUS LINEAR (LUMINAIRE (RECESSED IN GRID) REFER TO PLANS FOR LENGTH	10 WATTS/ FOOT	1935	LED	AMERLUX	GRUV1.5-GRID-VYV-PL-16W-AL30-UNV-IND -10V
4 EM		SAME AS TYPE 4 - WITH INTEGRAL BATTERY	10 WATTS/ FOOT	1935	LED	AMERLUX	GRUV1.5-GRID-VYV-PL-16W-AL30-UNV-IND -10V-EMB
20		EXIT SIGN (SINGLE FACE/DBL FACE) CEILING MOUNT SEE PLANS FOR DIRECTIONAL INDICATORS	2.5		LED	HE WILLIAMS	EXIT/CA-R-WF-WHT-EM-D
* MANUFACTURER AND MODEL NUMBER ARE PROVIDED TO SHOW BASIS OF DESIGN ONLY.							

1
NTS

Luminaire Schedule

S.E.D. Control No. 62-18-01-06-0-002-015

1

11/14/23

SED ADD NO. 1

Rev. No.:Date:Description:

WALLKILL CENTRAL SCHOOL DISTRICT

complex world | CLEAR SOLUTIONS

Tetra Tech Engineers, Architects & Landscape Architects, P.C.

TETRA TECH ARCHITECTS & ENGINEERS

Wallkill Central School District
Wallkill, New York

Reconstruction to:
John G. Borden Middle School

Schedules

Drawn By:
CR/ded

Date:
06/30/2023

Project No.:
17597-22002

Drawing Number:
BE600

BID SET