



- NOTES:**
- REFER TO CONTRACT DRAWING E-701 FOR ELECTRICAL LEGEND, ABBREVIATIONS, GENERAL NOTES, AND DRAWING LIST.
 - ALL 277/480V AND 120/208V FEEDERS AND BRANCH CIRCUIT CONDUCTORS SHALL BE ALUMINUM. CONTRACTOR SHALL PERFORM VOLTAGE DROP CALCULATIONS FOR ALL BRANCH CIRCUITS AND APPROPRIATELY SIZE CONDUCTORS AND ASSOCIATED CONDUITS BASED ON THE 2017 NATIONAL ELECTRIC CODE.
 - ALUMINUM CONDUCTORS SHALL BE UL LISTED AND COMPLY WITH ASTM B800, ASTM B801, UL 486C, AND ANSI H35.2-2017. INSTALLATION OF ALUMINUM CONDUCTORS SHALL BE INSTALLED IN COMPLIANCE WITH ANSI/NECA/AA 104-2012.
 - ALL SPLICES, TERMINATIONS, TAPS, AND CONDUCTOR CONNECTORS SHALL BE COMPATIBLE WITH CONDUCTOR MATERIAL. USE OXIDE INHIBITOR IN EACH SPLICE, TERMINATION, AND TAP FOR ALUMINUM CONDUCTORS.

ARCHITECT
di Domenico + Partners LLP
 Architecture
 Landscape Architecture
 Planning
 3743 Crescent Street, 3rd Floor
 Long Island City, New York 11101
 Tel 212-337-0400
 Fax 212-337-3567

CIVIL PLANNING ENGINEER
JMC
 JMC Planning Engineering Landscape
 Architecture & Land Surveying, PLLC
 120 Bedford Road
 Armonk, New York 10504
 Tel 914-273-5225
 Fax 914-273-2102

MEP ENGINEER
Burns
 BURNS ENGINEERING, P.C.
 1261 Broadway, Suite 708
 New York, New York 10001
 Tel 212-687-3503

STRUCTURAL ENGINEER
GEI
 GEI50
 1385 Broadway, 20th FL
 New York, New York 10018
 Tel 212-687-8282

MANHATTAN BEER DISTRIBUTORS
 20 DUNNIGAN DRIVE
 SUFFERN, NEW YORK

KEY PLAN

REV	DESCRIPTION	DATE
	ISSUED FOR DOB SUBMISSION	09/10/2021
	ISSUED FOR BID	10/15/2021
	ISSUED FOR PROGRESS	01/18/2022
	ISSUED FOR CONSTRUCTION	08/30/2022

DRAWN BY: M.DIMATTIA
 CHECKED BY: B.NEMCHEK
 APPROVED BY: J.MIZRAHI
 DATE: 09/10/21
 SCALE: N.T.S.

DRAWING TITLE:
**ELECTRICAL ONE-LINE
 DIAGRAM - SHEET 2 OF 3**

DWG NUMBER:
E-702

TO THE BEST KNOWLEDGE, BELIEF AND PROFESSIONAL JUDGEMENT, THESE PLANS AND SPECIFICATIONS ARE IN COMPLIANCE WITH THE 2020 ENERGY CONSERVATION CONSTRUCTION CODE OF NEW YORK STATE.