

BUILDING ELEVATIONS:
 BASEMENT = -12'-0"
 FIRST FLOOR = 0'-0"
 SECOND FLOOR = 12'-0"
 ROOF = 23'-9 1/4"

CONDENSATE PITCHED AT 1/8" PER FOOT
 HWS/R CONNECTIONS TO UNIT VENTILATORS IS 1"

- ① UTILITY COMPARTMENT
- ② CONDENSATE PIPED TO EXTERIOR. DRAIN DOWN TO GRADE.
- ③ DROP TO PIPE ENCLOSURE & ROUTE TO UNIT
- ④ EXPANSION COMPENSATORS

REFERENCE DRAWINGS

TRADE	DESCRIPTION	DATE	REV
MECH	MECHANICAL SYSTEMS		
ELECTR	ELECTRICAL		
PLUMB	PLUMBING		
HVAC	HEATING, VENTILATION & AIR CONDITIONING		

RECORD OF TRADE COORDINATION

TRADE	COMPANY	DATE	AUTHORIZED SIGNATURE
MECH			
ELECTR			
PLUMB			
HVAC			

COORDINATION NOTE

ELITECAD DESIGNERS SHALL NOT BE RESPONSIBLE FOR INTERFERENCES OR CONFLICTS BETWEEN TRADES THAT MAY OCCUR DURING CONSTRUCTION OF THE PROJECT. THE CONTRACTOR SHALL BE RESPONSIBLE FOR VERIFYING THE ACCURACY OF ALL TRADE COORDINATION INFORMATION AND FOR RESOLVING ANY CONFLICTS THAT MAY OCCUR. THE CONTRACTOR SHALL BE RESPONSIBLE FOR NOTIFYING ELITECAD DESIGNERS OF ANY CONFLICTS THAT MAY OCCUR AS SOON AS POSSIBLE.

ARCHITECT / ENGINEER NOTES:

FOR APPROVAL

VERIFY THAT LINE ABOVE IS 1" LONG. PRINT MAY HAVE BEEN REDUCED.

REV	DATE	DESCRIPTION
1	12/14/2023	SUBMITTED FOR APPROVAL
1	01/10/2024	REVISED AS PER RETURN DRAWING

