

- 2. WHERE SPECIAL CONDITIONS PREVENT THE INSTALLATION OF DEVICES AT THE ABOVE HEIGHTS, THE EC SHALL VERIFY HEIGHTS ON SITE WITH THE ARCHITECT.
- 3. THE EC SHALL VERIFY FINAL WORKBENCH, COUNTER,, CABINET OR VANITY HEIGHTS INCLUDING BACK SPLASH, ON SITE WITH THE GC PRIOR TO THE INSTALLATION OF ANY BOXES.
- 4. WHERE DEVICES ARE INSTALLED ABOVE OR BELOW EACH OTHER ALL DEVICE BOXES SHALL ALIGN VERTICALLY.
- 5. WHERE DEVICES RE INSTALLED ON EACH SIDE OF A RATED WALL THE DEVICES SHALL BE OFFSET.

EQUIPMENT NAME XXX VOLTS, X PH, X WIRE FED FROM PANEL XXX CIRCUIT XX, XX, XX

1. EXAMPLE PLATE SHOWN. PROVIDE MINIMUM 1/4" HEIGHT WHITE LETTERING ON BLACK BACKGROUND. 3. ATTACH WITH WATERPROOF ADHESIVE.

L18 DEVICE MOUNTING DETAIL
N.T.S.

L12 LAMINATED IDENTIFICATION PLATE

PP-1 P2N P2S SECT 1 SECT 1 ACPP2 | 208Y/120V | 208Y/120V | 208Y/120V | 208Y/120V | 208Y/120V | 208Y/120V 125A 100A 100A 225A 225 MCB FTL 225A SECOND FLOOR LP-LVB LP-CP SECT 1 SECT 2 208Y/120V 208Y/120V 208Y/120V 208Y/120V 250A MCB 100A 250A FTL MCB MCB 100A 150A CP1 208Y/120V, 3P, 4W, 400A 208Y/120V STAGE PROJ 208Y/120V 208Y/120V P1N P1S 200A 120/240V 208Y/120V 208Y/120V 100A 225A 100A 100A ACPP1 208Y/120V 225A LOAD KIT-B 208Y/120V 200A ELEV KIT-B1 DP1 BSMT SECT 1 SECT 2 DP2 208Y/120V 125A 250A 1 208Y/120V 200A 208Y/120V 208Y/120V 208Y/120V 208Y/120V 250A 250A 250A 100A 208Y/120V FTL 200A 208Y/120V, 3P, 4W, 800A

A18 SINGLE LINE DIAGRAM

LOWER LEVEL

6/19/2024 11:11:54 AM

KEYED NOTES: 1 REPLACE PANEL

NEW YORK OKLAHOMA

ARCHITECT

KSQ Design 215 W 40th Street 15th Floor New York, NY 10018 646.435.0660 office www.ksq.design

Owner Nanuet Union Free School District

101 Church Street Nanuet, NY 10954 845.627.9880 www.nanuetsd.org

Structural Engineer Clapper Structural Engineering

160 Partition Street Saugerties, NY 12477 845.943.9601

www.clapperstructural.com MEP Engineer


Sage Engineering Associates, LLP 9 Columbia Circle Albany NY 12203 518.453.6091 WWW.sagellp.com
NYS CERTIFICATE AUTHORZIATION NUMBER 0018644

Environmental Engineer Quest Environmental Solutions 1376 Route 9 Wappingers Falls, NY 12590 845.298.6251

Construction Manager One Penn Plaza 24th Floor, Suite 2400 New York, NY 10119 646.908.6550

www.jacobs.com

www.qualityenv.com





■ SED#50-01-08-03-0-002-020 (HIGHVIEW ES) SED#50-01-08-03-7-007-002 (Maintenance) □ SED#50-01-08-03-7-012-004 (OEC) ☐ SED#50-01-08-03-0-001-026 (MILLER ES) SED#50-01-08-03-0-004-022 (BARR MS)

Highview Elementary School 24 Highview Ave Nanuet, NY 10954 OEC Building 135 Convent Rd Nanuet, NY 10954

Maintenance Building 103 Church St. Nanuet, NY 10954

Miller Elementary School 50 Blauvelt Rd Unit1 Nanuet, NY 10954 A MacArthur Barr Middle School

143 Church St Nanuet, NY 10954

)	l					
	_					
	-	REVIS	IONS			
		No. Descriptio				Date

ISSUED: BID SET

DATE: 06/21/2024 SCALE: AS NOTED

SHEET NAME: DETAILS AND DIAGRAMS

SHEET NUMBER: