

This figure contains several electrical panel schedules and a lighting fixture schedule.

Electrical Panel Schedules

- NAME: DP-1 REMOVE EXISTING PANEL**

MOUNTING	SURFACE	VOLTS	208Y120	PHASE	3	WIRE	4										
MAIN RATING	250 A	MCB	MLO	MIN AIC RATING	AMPS RMS SYM	OTHER	LOCATION: TEL ROOM										
NOTES:																	
CKT	DESCRIPTION	LOAD	WIRE	BKR	P	A	R	C	A	B	C	P	BKR	WIRE	LOAD	DESCRIPTION	CKT
1	OIL BURNER	--	--	100	3	0	0	0	1	29	-	--	SPARE	2			
3	--	--	--	0	0	0	0	0	1	29	-	--	SPARE	4			
5	--	--	--	0	0	0	0	0	1	29	-	--	SPARE	6			
7	AC PRINCIPAL OFFICE	--	--	20	2	0	0	0	3	29	-	--	ASSEMBLY VENT	8			
8	--	--	--	0	0	0	0	0	4	-	--	--	10				
11	AC COMPRESSORS	--	--	20	3	0	0	0	5	-	--	--	OLD SCHOOL	14			
13	--	--	--	0	0	0	0	0	3	29	-	--	16				
17	STOVE	--	--	20	1	0	0	0	6	-	--	--	18				
19	BOILER #2	--	--	20	3	0	0	0	3	69	-	--	BOILER #1	20			
21	--	--	--	0	0	0	0	0	6	-	--	--	22				
23	--	--	--	0	0	0	0	0	6	-	--	--	24				
25	VAC PUMPS	--	--	90	3	0	0	0	3	59	-	--	FIRE HORN ROOF	26			
27	--	--	--	0	0	0	0	0	6	-	--	--	28				
31	EXHAUST VENTS	--	--	30	3	0	0	0	2	29	-	--	30				
33	--	--	--	0	0	0	0	0	6	1	39	-	SPARE	34			
35	--	--	--	0	0	0	0	0	6	1	39	-	SPARE	36			
37	TBS CONTROLS	--	--	20	1	0	0	0	3	160	-	--	KIT B1 (KIT3 EN)	38			
39	KLN ROOM	--	--	50	2	0	0	0	6	-	--	--	40				
41	--	--	--	0	0	0	0	0	6	-	--	--	42				
- NAME: BLR REMOVE EXISTING PANEL**

MOUNTING	SURFACE	VOLTS	208Y120	PHASE	3	WIRE	4										
MAIN RATING	200 A	MCB	MLO	MIN AIC RATING	AMPS RMS SYM	OTHER	LOCATION: BOILER ROOM G6										
NOTES:																	
CKT	DESCRIPTION	LOAD	WIRE	BKR	P	A	R	C	A	B	C	P	BKR	WIRE	LOAD	DESCRIPTION	CKT
1	BOILER MOTOR #1	--	--	0	3	0	0	0	3	0	--	--	BOILER MOTOR #2	2			
3	--	--	--	0	0	0	0	0	0	0	0	--	SPARE	4			
5	--	--	--	0	0	0	0	0	0	0	0	--	SPARE	6			
7	OIL PUMP #1	--	--	0	3	0	0	0	3	0	--	--	OIL PUMP #2	8			
9	--	--	--	0	0	0	0	0	0	0	0	--	SPARE	10			
11	--	--	--	0	0	0	0	0	0	0	0	--	EXISTING LOAD	12			
13	EXISTING LOAD	--	--	20	1	0	0	0	1	20	-	--	EXISTING LOAD	14			
15	EXISTING LOAD	--	--	20	1	0	0	0	1	20	-	--	EXISTING LOAD	16			
17	EXHAUST UNIT	--	--	20	3	0	0	0	3	29	-	--	OIL PUMP #1	20			
19	INTAKE FAN	--	--	20	3	0	0	0	3	29	-	--	EXISTING LOAD	22			
21	--	--	--	0	0	0	0	0	0	0	0	--	SPARE	24			
23	--	--	--	0	0	0	0	0	0	0	0	--	SPARE	26			
25	FUEL PUMP 1 AND 2	--	--	20	2	0	0	0	3	29	-	--	OIL PUMP #2	28			
27	--	--	--	0	0	0	0	0	0	0	0	--	SPARE	30			
29	BOILER CONTROL	--	--	20	3	0	0	0	1	20	-	--	EXISTING LOAD	32			
31	--	--	--	0	0	0	0	0	1	20	-	--	SPARE	34			
33	--	--	--	0	0	0	0	0	1	20	-	--	SPARE	36			
35	--	--	--	0	0	0	0	0	1	20	-	--	SPARE	38			
37	--	--	--	0	0	0	0	0	1	20	-	--	SPARE	40			
39	--	--	--	0	0	0	0	0	1	20	-	--	SPARE	42			
- NAME: STAGE REMOVE EXISTING PANEL**

MOUNTING	SURFACE	VOLTS	208Y120	PHASE	3	WIRE	4										
MAIN RATING	200 A	MCB	MLO	MIN AIC RATING	AMPS RMS SYM	OTHER	LOCATION: PLATFORM										
NOTES:																	
CKT	DESCRIPTION	LOAD	WIRE	BKR	P	A	R	C	A	B	C	P	BKR	WIRE	LOAD	DESCRIPTION	CKT
1	LGT GYM-NORTH WEST	--	--	20	2	0	0	0	2	20	-	--	LGT GYM-SOUTH WEST	2			
3	--	--	--	0	0	0	0	0	0	0	0	--	SPARE	4			
5	LGT GYM-SOUTH MIDDLE	--	--	20	2	0	0	0	2	20	-	--	LGT GYM-NORTH MIDDLE	6			
7	--	--	--	0	0	0	0	0	0	0	0	--	SPARE	8			
9	--	--	--	0	0	0	0	0	0	0	0	--	SPARE	10			
11	LGT GYM-SOUTH EAST	--	--	20	2	0	0	0	2	20	-	--	LGT GYM-NORTH EAST	12			
13	LGT EXISTING OFFICE	--	--	20	1	0	0	0	1	20	-	--	STAGE 1 WALL SEATING AND NEVE SCREWS	14			
15	EXISTING LOAD	--	--	20	1	0	0	0	1	20	-	--	EXISTING LOAD	16			
17	EXISTING LOAD	--	--	20	1	0	0	0	1	20	-	--	LGT FRONT STAGE	18			
19	SPARE	--	--	20	1	0	0	0	1	20	-	--	LGT FRONT STAGE	20			
21	SPARE	--	--	20	1	0	0	0	1	20	-	--	LGT FRONT STAGE	22			
23	SPARE	--	--	20	1	0	0	0	1	20	-	--	LGT FRONT STAGE	24			
25	EXISTING LOAD	--	--	20	1	0	0	0	1	20	-	--	EXISTING LOAD	26			
27	LGT GYM SEATING	--	--	20	1	0	0	0	1	20	-	--	LGT GYM SEATING	28			
29	SPARE	--	--	20	1	0	0	0	1	20	-	--	SPARE	30			
31	EXISTING LOAD	--	--	20	1	0	0	0	1	20	-	--	RECEPT GYM STAGE	32			
33	LGT GYM EXITS	--	--	20	1	0	0	0	1	20	-	--	EXISTING LOAD	34			
35	SPARE	--	--	20	1	0	0	0	1	20	-	--	SPARE	36			
37	SPARE	--	--	20	1	0	0	0	1	20	-	--	SPARE	38			
39	SPARE	--	--	20	1	0	0	0	1	20	-	--	SPARE	40			
41	SPARE	--	--	20	1	0	0	0	1	20	-	--	SPARE	42			

Lighting Fixture Schedule

LIGHTING FIXTURE SCHEDULE										
NOTE										
TYPE	DESCRIPTION	MANUFACTURER		LAMP				Fixture Remarks		
		Type	Watts	Lumens	Color	Volts				
D2	6" RECESSED LED DOWNLIGHT, 1000 LUMENS, 0-10V DIMMING	COOPER LIGHTING	#HC010D010-HM6020583-61MDH	LED	10.4 W	1000 lm	3000 K	120/277	REFERENCE ARCHITECTURAL DRAWINGS	
D4	BRASS RECESSED LED SQUARE DOWNLIGHT	ALPHABET LIGHTING	#001MV-SW-1SLW-35K-80-NL-CO-CC-NC-UNV	LED	12.0 W	1350 lm	3500 K	120/277	REFERENCE ARCHITECTURAL DRAWINGS	
F10A	RECESSED 1X4 LED ILLUMINATED PANEL	LITHONIA	#CPX 1X4 AL08 80CRI 35K SVL MVOLT	LED	31.5 W	4093 lm	3500 K	120/277	REFERENCE ARCHITECTURAL DRAWINGS	
F10B	RECESSED 2X4 LED ILLUMINATED PANEL	LITHONIA	#CPX 2X4 AL07 80CRI 35K SVL MVOLT	LED	25.9 W	3539 lm	3500 K	120/277	REFERENCE ARCHITECTURAL DRAWINGS	
P1EM	12" ROUND LED HIGH BAY, 16" ACRYLIC CLEAR REFLECTOR, 20 WATT INTEGRAL BATTERY PACK, 3/4" PENDANT MOUNT, WHITE, WITH WIRE CAGE	ILP LIGHTING	#P94-14U12L2BL-U-CCTS-WHT-EMD-R84-PENWHT+AD4-GL	LED	198.0 W	2715 lm	3500 K</			



NUFSD BOND PROJECT PHASE 5 - HIGHVIEW

ED#50-01-08-03-0-002-020 (HIGHVIEW ES)
ED#50-01-08-03-7-007-002 (Maintenance)
ED#50-01-08-03-7-012-004 (OEC)
ED#50-01-08-03-0-001-026 (MILLER ES)
ED#50-01-08-03-0-004-022 (BARR MS)

Highview Elementary School

24 Highview Ave
Nanuet, NY 10954

OEC Building
135 Convent Rd

Nanuet, NY 10954

Maintenance Building
103 Church St.
Montgomery, N.Y. 12549-1

Nanuet, NY 10954

Miller Elementary School
50 Blauvelt Rd Unit1
 Nanuet NY 10954

A MacArthur Barr Middle School

143 Church St
Nanuet, NY 10954

KEY PLAN

10 of 10

1

A horizontal line with three rectangular notches cut out of it, creating a stepped profile. The notches are evenly spaced along the line.

10 of 10

VISIONS

No.	Description	Date
-----	-------------	------

1 SED ADD #1 11/06,

SCHED: RJD SET

ISSUED: BID SET

SCALE: AS NOTED

SHEET NAME:

PANEL AND FIXTURE SCHEDULES

MEET NUMBER:

SHEET NUMBER:

HE-E601

For more information about the study, please contact Dr. [REDACTED] at [REDACTED].