CONTROLS LEGEND

D	DIGITAL INPUT
D	DIGITAL OUTPUT
A	ANALOG INPUT
A	ANALOG OUTPUT
M	MOTOR OPERATOR / MOTORIZED DAMPER
DP	DIFFERENTIAL PRESSURE SENSOR
SP	STATIC PRESSURE SENSOR
S/S	START/STOP
NG	NATURAL GAS DETECTOR
T	SPACE DRY BULB TEMPERATURE SENSOR
T H	COMBINATION SPACE DRY BULB TEMPERATURE SENSOR WITH RELATIVE HUMIDITY SENSOR INCLUDED
C	FAN COIL UNIT REMOTE CONTROLLER
H	RELATIVE HUMIDITY SENSOR
H	WALL MOUNTED HUMIDITY SENSOR
CO2	CARBON DIOXIDE SENSOR
CO	CARBON MONOXIDE DETECTOR
M	MOTORIZED DAMPER
ST	STARTER
VFD	VARIABLE FREQUENCY DRIVE
ECM	ELECTRICALLY COMMUTATED MOTOR INTERFACE BOARD
AMS	AIR MEASURING STATION
CS	CURRENT SENSOR
ES	END SWITCH
OS	OCCUPANCY SENSOR
PS	PRESSURE SENSOR
SP	STATIC PRESSURE SENSOR
H	HUMIDITY
SD	SMOKE DETECTOR
R	RELAY
T	ELECTRIC THERMOSTAT DUCT MOUNTED
F	AIRFLOW SENSOR
A	ALARM
T	TREND
RT	RUN TIME

T	TEMPERATURE SENSOR SINGLE POINT
T	TEMPERATURE SENSOR AVERAGING SENSING ELEMENT
M	2-WAY CONTROL VALVE ELECTRIC ACTUATOR
M	3-WAY CONTROL VALVE ELECTRIC ACTUATOR

SINGLE LINE SYMBOLS LEGEND

HWS	HEATING WATER SUPPLY PIPING
HWR	HEATING WATER RETURN PIPING
COND	COOLING COIL CONDENSATE PIPING
RL	REFRIGERANT LIQUID PIPING
RS	REFRIGERANT SUCTION PIPING
	90 DEGREE PIPE ELBOW DOWN
	PIPE RISER UP SYMBOL
	MID-PIPE DOWN
	PIPE CAP
	PIPE BREAK
X	PIPE GUIDE
	UNION
	FLOW DIRECTION
	PIPING/DUCTWORK/EQUIPMENT REMOVALS
	CHECK VALVE
	SHUTOFF BALL VALVE
	2-WAY MODULATING CONTROL VALVE
	2-WAY CONTROL VALVE
	3-WAY MODULATING CONTROL VALVE
	GATE VALVE CIRCUIT SETTER BALANCING VALVE - 2-1/2" SIZE AND UP
	CALIBRATED BALANCE VALVE CIRCUIT SETTER BALANCING VALVE - 2" SIZE AND BELOW
	PRESSURE REDUCING VALVE
	3-WAY CONTROL VALVE
OR	BUTTERFLY VALVE
	RELIEF VALVE
	PRESSURE RELIEF VALVE
	AUTOMATIC AIR VENT
	PUMP
OR	PRESSURE GAGE
OR	STRAINER
OR	THERMOMETER
	POINT OF CONNECTION
	POINT OF DISCONNECTION
	EXPANSION COMPENSATOR

DOUBLE LINE SYMBOLS LEGEND

	SUPPLY DIFFUSER
	RETURN DIFFUSER
	SQUARE-THROATED ELBOW WITH TURNING VANES
DS-X	ELBOW STYLE DUCT SILENCER
DS-X	STRAIGHT DUCT STYLE DUCT SILENCER
R R	DUCTWORK RADIUS ELBOW
F/S	COMBINATION FIRE/SMOKE DAMPER
F	FIRE DAMPER
S	SMOKE DAMPER
M	MOTORIZED DAMPER
	FLEXIBLE SUPPLY AIR DUCTWORK MAXIMUM 3-FOOT LENGTH
	VOLUME DAMPER
	RETURN AIR RISE
	EXHAUST AIR RISE
	SUPPLY AIR RISE
X	KEYED NOTE DESIGNATION TAG
C	FCU CONTROLLER
T	SPACE TEMPERATURE SENSOR

ABBREVIATIONS LEGEND

AC	AIR CONDITIONER
ACCU	AIR COOLED CONDENSING UNIT
AD	ACCESS DOOR
AFF	ABOVE FINISHED FLOOR
AFG	ABOVE FINISHED GRADE
AH	AIR HANDLER
AHU	AIR HANDLING UNIT
APD	AIR PRESSURE DROP
AS	AIR SEPARATOR
ATS	AIR TRANSFER SLEEVE
AVG	AVERAGE SPACE TEMPERATURE
BHP	BRAKE HORSEPOWER
BM	BAILEY MIDDLE SCHOOL
BTM	BOTTOM
BTUH	BRITISH THERMAL UNITS/HOUR
BTU/H/LF	BRITISH THERMAL UNIT/HOUR/ LINEAR FOOT
CAP	CAPACITY
CFM	CUBIC FEET PER MINUTE
CI	CAST IRON
CO	CARBON MONOXIDE SENSOR
COND	CONDENSATE PIPING
CONT.	CONTINUATION
CP	STEAM CONDENSATE PUMP/RECEIVER SET
CUH	CABINET UNIT HEATER
CW	DOMESTIC COLD WATER
CV	CONVECTOR
cV	VALVE COEFFICIENT
D	DIFFUSER
DB	DRY BULB
dBA	A-WEIGHTED DECIBEL LEVEL
DCW	DOMESTIC COLD WATER
DDC	DIRECT DIGITAL CONTROL
DEG. F	DEGREES FAHRENHEIT
DHWR	DOMESTIC HOT WATER RETURN
DIA	DIAMETER
DN	DOWN
DS	DUCT SILENCER
DWDI	DUAL WIDTH, DUAL INLET
DWG	DRAWING
EA	EXHAUST AIR
EAT	ENTERING AIR TEMPERATURE
E.C.	EXPANSION COMPENSATOR
EDB	ENTERING DRY BULB
EER	ENERGY EFFICIENCY RATIO
E	EXHAUST FAN TAG
EF	EXHAUST FAN
EG	EXHAUST GRILLE
EHC	IN-DUCT ELECTRIC HEATING COIL
EL	EXPANSION LOOP
ER	EXHAUST REGISTER
ERV	STATIC PLATE ENERGY RECOVERY VENTILATOR
ESP	EXTERNAL STATIC PRESSURE
ET	EXPANSION TANK
EWT	ENTERING WATER TEMPERATURE
EX	EXISTING
F	FAN
°F	FAHRENHEIT
FAI	FRESH AIR INTAKE
FC	FORWARD CURVED
FD	FIRE DAMPER
FCU	FAN COIL UNIT
FLA	FULL LOAD AMPS
FLR	FLOOR
FO	FLAT OVAL
FPM	FEET PER MINUTE
FSD	FIRE SMOKE DAMPER
FT	FIN TUBE
FT. OR '	FEET
FTR	FIN TUBE RADIATION
G	GRILLE
gal/GAL	GALLON
GPH	GALLONS PER HOUR
GPM	GALLONS PER MINUTE
GV	GRAVITY RELIEF VENTILATOR
H	HOOD
HP	HORSEPOWER OR HEAT PUMP
HPSF	HEAT PUMP SEASONAL PERFORMANCE FACTOR
HS	HIGH SCHOOL
H&V	HEATING AND VENTILATION
HW	DOMESTIC HOT WATER
HWP	HOT WATER PUMP
HWR	HOT WATER RETURN
HWS	HOT WATER SUPPLY
HX	HEAT EXCHANGER
HZ	HERTZ
IEER	INTEGRATED ENERGY EFFICIENCY RATIO
IN OR "	INCHES
INT	INTERNAL
KEF	KITCHEN EXHAUST FAN
KW	KILOWATT
L	LENGTH
LAT	LEAVING AIR TEMPERATURE
LBS	POUNDS
LDB	LEAVING DRY BULB
LF	LINEAR FOOT
LMTD	LOGARITHMIC MEAN TEMPERATURE DIFFERENCE
LWT	LEAVING WATER TEMPERATURE
MAX	MAXIMUM
MBH	THOUSAND BTUH
MC	MOTOR CONTROLLER
MCA	MINIMUM CIRCUIT AMPACITY
MER	MECHANICAL EQUIPMENT ROOM
MH	MOUNTING HEIGHT
MD	MOTORIZED DAMPER
MIN	MINIMUM
MOP	MAXIMUM OVERCURRENT PROTECTION
N/A	NOT APPLICABLE
NC	NORMALLY CLOSED
MFG	MANUFACTURER
NG	NATURAL GAS DETECTOR
NO	NORMALLY OPEN
NOL	NON OVER LOADING
OA	OUTSIDE AIR
OAD	OUTSIDE AIR DAMPER
OED	OPEN END DUCT
OS&Y	OPEN STEM & YOKE
P	PUMP
PC	PLUMBING CONTRACTOR
PD	PRESSURE DROP
PG	PROPYLENE GLYCOL
PH	PHASE
PPM	PARTS PER MILLION
PRV	PRESSURE REDUCING VALVE
PSI	POUNDS PER SQUARE INCH
PSIG	POUNDS PER SQUARE INCH GAUGE
R	HEATING WATER RADIATION UNIT
RA	RETURN AIR
RD	RETURN DIFFUSER
REF	ROOF EXHAUST FAN
RF	RELIEF FAN
RH	RELATIVE HUMIDITY
RHG	REFRIGERANT HOT GAS
RL	REFRIGERANT LIQUID
RLA	RATED LOAD AMPS
RPM	REVOLUTIONS PER MINUTE
RP	HYDRONIC RADIANT HEAT PANEL
RPZ	REDUCED PRESSURE ZONE ASSEMBLY
RR	RETURN REGISTER
RS	REFRIGERANT SUCTION
RTU	ROOF TOP UNIT
S	INDOOR AIR HANDLING UNIT TAG
SA	SUPPLY AIR
SF	SQUARE FOOT
SD	SUPPLY DIFFUSER
SEER	SEASONAL ENERGY EFFICIENCY RATIO
SP	STATIC PRESSURE
SPS	STATIC PRESSURE SENSOR
SR	SHORT RADIUS
SS	STAINLESS STEEL
SWSI	SINGLE WIDTH SINGLE INLET
TEMP	TEMPERATURE
TG	TRANSFER GRILLE
TR	DUCTWORK TRANSITION
TSP	TOTAL STATIC PRESSURE
TYP	TYPICAL
UH	UNIT HEATER
VAV	VARIABLE AIR VOLUME
VEL	VELOCITY
VERT	VERTICAL
VFD	VARIABLE FREQUENCY DRIVE
VRF	VARIABLE REFRIGERANT FLOW
VRV	VARIABLE REFRIGERANT VOLUME
W	WIDTH
WB	WET BULB
WC	WATER COLUMN
WPD	WATER PRESSURE DROP
WH	WATER HEATER

ARCHITECT

ksqdesign

NEW YORK OKLAHOMA

KSQ Design
215 W 40th Street 15th Floor
New York, NY 10018
646.435.0660 office
www.ksq.design

Owner

Nanuet Union Free School District
101 Church Street
Nanuet, NY 10954
845.627.9880
www.nanuetsd.org

Structural Engineer

Clapper Structural Engineering
160 Partition Street
Saugerties, NY 12477
845.943.9601
www.clapperstructural.com

MEP Engineer

Sage Engineering Associates, LLP
9 Columbia Circle
Albany NY 12203
518.453.6091
www.sagellp.com
NYS CERTIFICATE AUTHORIZATION NUMBER 0915844

Environmental Engineer

Quest Environmental Solutions
1376 Route 9
Wappingers Falls, NY 12590
845.298.6251
www.qualityenv.com

Construction Manager

Jacobs
One Penn Plaza
24th Floor, Suite 2400
New York, NY 10119
646.908.6550
www.jacobs.com

STATE OF NEW YORK · JOHN VENDITTI · 089996A · LICENSED PROFESSIONAL ENGINEER

REGISTRATION EXPIRES: 11/30/2026

NUFSD BOND PROJECT PHASE 5 - HIGHVIEW

- ■ SED#50-01-08-03-0-002-020 (HIGHVIEW ES)
- ☐ SED#50-01-08-03-7-007-002 (Maintenance)
- ☐ SED#50-01-08-03-7-012-004 (OEC)
- ☐ SED#50-01-08-03-0-001-026 (MILLER ES)
- ☐ SED#50-01-08-03-0-004-022 (BARR MS)

Highview Elementary School
24 Highview Ave
Nanuet, NY 10954

OEC Building
135 Convent Rd
Nanuet, NY 10954

Maintenance Building
103 Church St.
Nanuet, NY 10954

Miller Elementary School
50 Blauvelt Rd Unit1
Nanuet, NY 10954

A MacArthur Barr Middle School
143 Church St
Nanuet, NY 10954

KEY PLAN



REVISIONS

No.	Description	Date

ISSUED: BID SET

DATE: 06/21/2024

SCALE: 12" = 1'-0"

SHEET NAME:
HVAC SYMBOLS, LEGENDS AND ABBREVIATIONS

SHEET NUMBER:
HE-M001

ISSUE FOR BID SET

DRAWN BY: Author
CHECKED BY: Checker
C:\Users\Sheet\Documents\1490_HIGHVIEW_MECH_R23_sheetqa0737.rvt

6/19/2024 2:58:51 PM

PROJECT NUMBER: 00000.00

COPYRIGHT © 2023 KSQ ARCHITECTS, PC