**ARCHITECT** DISCONNECT AND REMOVE EXHAUST FAN, INCLUDING ASSOCIATED MOTORIZED DAMPER AND ALL ASSOCIATED CONTROL WIRING. FAN ROOF CURB TO REMAIN IN PLACE. DISCONNECT EXHAUST AIR DUCT RISER FROM EXHAUST FAN WITHIN ROOF CURB AND PROVIDE TEMPORARY CAP OVER THE EXHAUST AIR DUCT RISER. 2) DISCONNECT AND REMOVE 16" ROUND EA ROOF PENETRATION AND ASSOCIATED TERMINATION CAP. NEW YORK OKLAHOMA KSQ Design 215 W 40th Street 15th Floor New York, NY 10018 646.435.0660 office www.ksq.design Owner 101 Church Street Nanuet, NY 10954 845.627.9880 www.nanuetsd.org Structural Engineer 160 Partition Street Saugerties, NY 12477 845.943.9601 www.clapperstructural.com MEP Engineer 518.453.6091 **Environmental Engineer** www.qualityenv.com Construction Manager One Penn Plaza 24<sup>th</sup> Floor, Suite 2400 New York, NY 10119 646.908.6550 www.jacobs.com Nanuet, NY 10954 Miller Elementary School 50 Blauvelt Rd Unit1 EXISTING AHU (IN ATTIC SPACE) A MacArthur Barr Middle School
143 Church St \_\_\_\_ EXISTING ROOF ACCESS HATCH Nanuet, NY 10954 — EXISTING AUDITORIUM EXHAUST OUTLET \_\_\_\_\_1/2" RS (IN ATTIC) \_\_1/4" RL (IN ATTIC) munimum / EXISTING AHU (IN ATTIC SPACE) — EXISTING ROOFTOP **ENERGY RECOVERY** VENTILATOR REVISIONS ISSUED: BID SET **DATE:** 06/21/2024 **SCALE**: 3/32" = 1'-0" SHEET NAME: A17 HVAC ROOF REMOVALS

3/32" = 1'-0" SHEET NUMBER: PROJECT NUMBER: 00000.00 COPYRIGHT © 2023 KSQ ARCHITECTS, PC 2/4/2025 8:42:15 AM

Nanuet Union Free School District

Clapper Structural Engineering

Sage Engineering Associates, LLP
9 Columbia Circle
Albany NY 12203

WWW.sagellp.com
NYS CERTIFICATE AUTHORZIATION NUMBER 0018644

Quest Environmental Solutions 1376 Route 9 Wappingers Falls, NY 12590 845.298.6251





## NUFSD BOND PROJECT PHASE 5 -HIGHVIEW

■ SED#50-01-08-03-0-002-020 (HIGHVIEW ES)

□ SED#50-01-08-03-7-007-002 (Maintenance)

□ SED#50-01-08-03-7-012-004 (OEC)


□ SED#50-01-08-03-0-001-026 (MILLER ES)

□ SED#50-01-08-03-0-004-022 (BARR MS)

Highview Elementary School 24 Highview Ave Nanuet, NY 10954 OEC Building 135 Convent Rd

> Maintenance Building 103 Church St. Nanuet, NY 10954

Nanuet, NY 10954



No. Description

1 BID ADDENDUM #4

HVAC ROOF REMOVALS

HE-MR103