



G18 FIRST FLOOR REMOVALS
1/4" = 1'-0"

- KEYED NOTES:**
- ① DISCONNECT AND REMOVE ELECTRIC BASEBOARD AT LOCATIONS SHOWN. DISCONNECT AND REMOVE ASSOCIATED BASEBOARD TEMPERATURE SENSORS. REPLACE BASEBOARD WITH HOT WATER HEATED FIN TUBE. EXTEND HOT WATER SUPPLY AND RETURN PIPING FROM VEHICLE BAY TO FIN TUBE IN OFFICE SPACES.
 - ② DISCONNECT AND REMOVE MULTI-SPLIT SYSTEM TO ITS ENTIRETY, INCLUDING BOTH INSIDE UNITS, OUTSIDE ACCU, REFRIGERANT PIPING AND ASSOCIATED CONTROLS. DISCONNECT CONDENSATE PIPING FOR INSIDE UNITS. CONDENSATE PIPING IS TO REMAIN AND BE REUSED FOR INSTALLATION WORK.

ARCHITECT
ksqdesign
NEW YORK OKLAHOMA
KSQ Design
215 W 40th Street 15th Floor
New York, NY 10018
646.435.0660 office
www.ksq.design

Owner
Nanuet Union Free School District
101 Church Street
Nanuet, NY 10954
845.627.9880
www.nanuetd.org

Structural Engineer
Clapper Structural Engineering
160 Partition Street
Saugerties, NY 12477
845.943.9811
www.clappersstructural.com

MEP Engineer
Sage Engineering Associates, LLP
9 Columbus Circle
Albany NY 12203
518.453.6091
www.sagegrp.com
www.enr.com/people/industry/sage-engineers

Environmental Engineer
Quest Environmental Solutions
1376 Route 9
Wappingers Falls, NY 12590
845.298.6251
www.qualityenv.com

Construction Manager
Jacobs
One Penn Plaza
24th Floor, Suite 2400
New York, NY 10119
646.906.6550
www.jacobs.com



NUFSD BOND PROJECT PHASE 5 - MAINTENANCE

- SED#50-01-08-03-0-002-020 (HIGHVIEW ES)
 - SED#50-01-08-03-0-003-002 (Maintenance)
 - SED#50-01-08-03-0-012-004 (OEC)
 - SED#50-01-08-03-0-001-028 (MILLER ES)
 - SED#50-01-08-03-0-004-022 (BARR MS)
- Highview Elementary School**
24 Highview Ave
Nanuet, NY 10954
- OEC Building**
135 Convent Rd
Nanuet, NY 10954
- Maintenance Building**
103 Church St.
Nanuet, NY 10954
- Miller Elementary School**
50 Blauvelt Rd Unit 1
Nanuet, NY 10954
- A MacArthur Barr Middle School**
143 Church St
Nanuet, NY 10954

KEY PLAN

REVISIONS

No.	Description	Date

ISSUED: BID SET
DATE: 06/21/2024
SCALE: 1/4" = 1'-0"
SHEET NAME:
FIRST FLOOR REMOVALS
SHEET NUMBER:

MB-MR101

ISSUE FOR BID SET