CONTROLS LEGEND

- D — DIGITAL INPUT
- D — DIGITAL OUTPUT
- A — ANALOG INPUT
- A — ANALOG OUTPUT
- M — MOTOR OPERATOR / MOTORIZED DAMPER
- DP — DIFFERENTIAL PRESSURE SENSOR
- SP — STATIC PRESSURE SENSOR
- S/S — START/STOP
- NG — NATURAL GAS DETECTOR
- T — SPACE DRY BULB TEMPERATURE SENSOR
- T/H — COMBINATION SPACE DRY BULB TEMPERATURE SENSOR WITH RELATIVE HUMIDITY SENSOR INCLUDED
- H — RELATIVE HUMIDITY SENSOR
- H — WALL MOUNTED HUMIDITY SENSOR
- CO2 — CARBON DIOXIDE SENSOR
- CO — CARBON MONOXIDE DETECTOR
- M — MOTORIZED DAMPER
- ST — STARTER
- VFD — VARIABLE FREQUENCY DRIVE
- ECM — ELECTRICALLY COMMUTATED MOTOR INTERFACE BOARD
- AMS — AIR MEASURING STATION
- CS — CURRENT SENSOR
- ES — END SWITCH
- OS — OCCUPANCY SENSOR
- PS — PRESSURE SENSOR
- SP — STATIC PRESSURE SENSOR
- H — HUMIDITY
- SD — SMOKE DETECTOR
- R — RELAY
- T — ELECTRIC THERMOSTAT DUCT MOUNTED
- F — AIRFLOW SENSOR
- A — ALARM
- T — TREND
- RT — RUN TIME
- T — TEMPERATURE SENSOR SINGLE POINT
- T — TEMPERATURE SENSOR AVERAGING SENSING ELEMENT
- M — 2-WAY CONTROL VALVE ELECTRIC ACTUATOR
- M — 3-WAY CONTROL VALVE ELECTRIC ACTUATOR

DOUBLE LINE SYMBOLS LEGEND

- SUPPLY DIFFUSER
- RETURN DIFFUSER
- SQUARE-THROATED ELBOW WITH TURNING VANES
- DS-X — ELBOW STYLE DUCT SILENCER
- DS-X — STRAIGHT DUCT STYLE DUCT SILENCER
- R / R — DUCTWORK RADIUS ELBOW
- F/S — COMBINATION FIRE/SMOKE DAMPER
- F — FIRE DAMPER
- M — MOTORIZED DAMPER
- FLEXIBLE SUPPLY AIR DUCTWORK MAXIMUM 3-FOOT LENGTH
- VOLUME DAMPER
- RETURN AIR RISE
- EXHAUST AIR RISE
- SUPPLY AIR RISE
- X — KEYED NOTE DESIGNATION TAG
- T — SPACE TEMPERATURE SENSOR

SINGLE LINE SYMBOLS LEGEND

- COND — COOLING COIL CONDENSATE PIPING
- HWS — HEATING HOT WATER SUPPLY PIPING (HWS)
- HWR — HEATING HOT WATER RETURN PIPING (HWR)
- 90 DEGREE PIPE ELBOW DOWN
- PIPE RISER UP SYMBOL
- MID-PIPE DOWN
- PIPE CAP
- PIPE BREAK
- X — PIPE GUIDE
- UNION
- FLOW DIRECTION
- PIPING/DUCTWORK/EQUIPMENT REMOVALS
- CHECK VALVE
- SHUTOFF BALL VALVE
- 2-WAY MODULATING CONTROL VALVE
- 2-WAY CONTROL VALVE
- 3-WAY MODULATING CONTROL VALVE
- GATE VALVE CIRCUIT SETTER BALANCING VALVE - 2-1/2" SIZE AND UP
- CALIBRATED BALANCE VALVE CIRCUIT SETTER BALANCING VALVE - 2" SIZE AND BELOW
- PRESSURE REDUCING VALVE
- 3-WAY CONTROL VALVE
- H — OR — BUTTERFLY VALVE
- RELIEF VALVE
- PRESSURE RELIEF VALVE
- AUTOMATIC AIR VENT
- PUMP
- OR — PRESSURE GAGE
- OR — STRAINER
- OR — THERMOMETER
- POINT OF CONNECTION
- POINT OF DISCONNECTION

ABBREVIATIONS LEGEND

AC	AIR CONDITIONER
ACCU	AIR COOLED CONDENSING UNIT
AD	ACCESS DOOR
AFF	ABOVE FINISHED FLOOR
AFG	ABOVE FINISHED GRADE
AHU	AIR HANDLER UNIT
APD	AIR PRESSURE DROP
AS	AIR SEPARATOR
ATS	AIR TRANSFER SLEEVE
AVG	AVERAGE SPACE TEMPERATURE
BHP	BRAKE HORSEPOWER
BTM	BOTTOM
BTUH	BRITISH THERMAL UNITS/HOUR
BTU/H/LF	BRITISH THERMAL UNIT/HOUR/ LINEAR FOOT
CAP	CAPACITY
CFM	CUBIC FEET PER MINUTE
CI	CAST IRON
CO	CARBON MONOXIDE SENSOR
COND.	CONDENSATE PIPING
CONT.	CONTINUATION
CP	CONDENSATE PUMP
CUH	CABINET UNIT HEATER
CW	DOMESTIC COLD WATER
CV	CONTROL VALVE
Cv	VALVE COEFFICIENT
D	DIFFUSER
DB	DRY BULB
DCW	DOMESTIC COLD WATER
DDC	DIRECT DIGITAL CONTROL
DEG. F	DEGREES FAHRENHEIT
DHWR	DOMESTIC HOT WATER RETURN
DIA	DIAMETER
DN	DOWN
DS	DUCT SILENCER
DWDI	DUAL WIDTH, DUAL INLET
DWG	DRAWING
EA	EXHAUST AIR
EAT	ENTERING AIR TEMPERATURE
E.C.	EXPANSION COMPENSATOR
EDB	ENTERING DRY BULB
EF	EXHAUST FAN
EG	EXHAUST GRILLE
EHC	IN-DUCT ELECTRIC HEATING COIL
EL	EXPANSION LOOP
ER	EXHAUST REGISTER
ERV	STATIC PLATE ENERGY RECOVERY VENTILATOR
ESP	EXTERNAL STATIC PRESSURE
ET	EXPANSION TANK
EWT	ENTERING WATER TEMPERATURE
EX	EXISTING
°F	FAHRENHEIT
FC	FORWARD CURVED
FD	FIRE DAMPER
FLA	FULL LOAD AMPS
FLR	FLOOR
FO	FLAT OVAL
FPM	FEET PER MINUTE
FSD	FIRE SMOKE DAMPER
FT	FIN TUBE
FT. OR '	FEET
F.T.R.	FIN TUBE RADIATION
G	NATURAL GAS PIPING
GAL	GALLON
GPM	GALLONS PER MINUTE
GRV	GRAVITY RELIEF VENTILATOR
H	HOOD
HEF	HOOD EXHAUST FAN
HEX	HEAT EXCHANGER
HP	HORSEPOWER
H&V	HEATING AND VENTILATION
HW	DOMESTIC HOT WATER
HWP	HOT WATER PUMP
HWR	HOT WATER RETURN
HWS	HOT WATER SUPPLY
HZ	HERTZ
IN OR "	INCHES
INT	INTERNAL
KEF	KITCHEN EXHAUST FAN
KW	KILOWATT
L	LENGTH
LAT	LEAVING AIR TEMPERATURE
LBS	POUNDS
LDB	LEAVING DRY BULB
LF	LINEAR FOOT
LMTD	LOGARITHMIC MEAN TEMPERATURE DIFFERENCE
LWT	LEAVING WATER TEMPERATURE
MAX	MAXIMUM
MBH	THOUSAND BTUH
MC	MOTOR CONTROLLER
MCA	MINIMUM CIRCUIT AMPACITY
ME	MILLER ELEMENTARY
MER	MECHANICAL EQUIPMENT ROOM
MH	MOUNTING HEIGHT
MD	MOTORIZED DAMPER
MIN	MINIMUM
MOP	MAXIMUM OVERCURRENT PROTECTION
N/A	NOT APPLICABLE
NC	NORMALLY CLOSED
MFG	MANUFACTURER
NG	NATURAL GAS DETECTOR
NO	NORMALLY OPEN
NOL	NON OVER LOADING
OA	OUTSIDE AIR
OAD	OUTSIDE AIR DAMPER
OED	OPEN END DUCT
OS&Y	OPEN STEM & YOKE
P	PUMP
PC	PLUMBING CONTRACTOR
PD	PRESSURE DROP
PG	PROPYLENE GLYCOL
PH	PHASE
PPM	PARTS PER MILLION
PRV	PRESSURE REDUCING VALVE
PSI	POUNDS PER SQUARE INCH
PSIG	POUNDS PER SQUARE INCH GAUGE
R	HEATING WATER RADIATION UNIT
RA	RETURN AIR
RD	RETURN DIFFUSER
RF	RELIEF FAN
RH	RELATIVE HUMIDITY
RHG	REFRIGERANT HOT GAS
RL	REFRIGERANT LIQUID
RPM	REVOLUTIONS PER MINUTE
RP	HYDRONIC RADIANT HEAT PANEL
RPZ	REDUCED PRESSURE ZONE ASSEMBLY
RR	RETURN REGISTER
RS	REFRIGERANT SUCTION
RTU	ROOF TOP UNIT
SA	SUPPLY AIR
SF	SQUARE FOOT
SD	SUPPLY DIFFUSER
SP	STATIC PRESSURE
SPS	STATIC PRESSURE SENSOR
SR	SHORT RADIUS
SS	STAINLESS STEEL
SWSI	SINGLE WIDTH SINGLE INLET
TEMP	TEMPERATURE
TG	TRANSFER GRILLE
TR	DUCTWORK TRANSITION
TSP	TOTAL STATIC PRESSURE
TYP	TYPICAL
UH	UNIT HEATER
UV	UNIT VENTILATOR
VAV	VARIABLE AIR VOLUME
VEL	VELOCITY
VERT	VERTICAL
VFD	VARIABLE FREQUENCY DRIVE
VRF	VARIABLE REFRIGERANT FLOW
W	WIDTH
WB	WET BULB
WC	WATER COLUMN
WPD	WATER PRESSURE DROP
WH	WATER HEATER

ARCHITECT

ksqdesign

NEW YORK OKLAHOMA

KSQ Design
215 W 40th Street 15th Floor
New York, NY 10018
646.435.0660 office
www.ksq.design

Owner

Nanuet Union Free School District
101 Church Street
Nanuet, NY 10954
845.627.9880
www.nanuetsd.org

Structural Engineer

Clapper Structural Engineering
160 Partition Street
Saugerties, NY 12477
845.943.9601
www.clapperstructural.com

MEP Engineer

Sage Engineering Associates, LLP
9 Columbia Circle
Albany NY 12203
518.453.6091
www.sagellp.com
NYS CERTIFICATE AUTHORIZATION NUMBER 0915844

Environmental Engineer

Quest Environmental Solutions
1376 Route 9
Wappingers Falls, NY 12590
845.298.6251
www.qualityenv.com

Construction Manager

Jacobs
One Penn Plaza
24th Floor, Suite 2400
New York, NY 10119
646.908.6550
www.jacobs.com

STATE OF NEW YORK — MARK VENDITTI — 083994 — LICENSED PROFESSIONAL ENGINEER

REGISTRATION EXPIRES: 11/30/2026

NANUET

NUFSD BOND PROJECTS PHASE 5 - MILLER ES

- ☐ SED#50-01-08-03-0-002-020 (HIGHVIEW ES)
- ☐ SED#50-01-08-03-7-007-002 (Maintenance)
- ☐ SED#50-01-08-03-7-012-004 (OEC)
- ■ SED#50-01-08-03-0-001-026 (MILLER ES)
- ☐ SED#50-01-08-03-0-004-022 (BARR MS)

Highview Elementary School
24 Highview Ave
Nanuet, NY 10954

OEC Building
135 Convent Rd
Nanuet, NY 10954

Maintenance Building
103 Church St.
Nanuet, NY 10954

Miller Elementary School
50 Blauvelt Rd Unit1
Nanuet, NY 10954

A MacArthur Barr Middle School
143 Church St
Nanuet, NY 10954

KEY PLAN

REVISIONS

No.	Description	Date

ISSUED: BID SET

DATE: 06/21/2024

SCALE: 12" = 1'-0"

SHEET NAME:
HVAC SYMBOLS, LEGENDS AND ABBREVIATIONS

SHEET NUMBER:
ME-M001

ISSUE FOR BID SET

DRAWN BY: Author
CHECKED BY: Checker
Checker2Sheet1Documents\1-NNJ_MILLER_MECH_PHS_Sheet2BTS1.rvt
6/19/2024 4:30:13 PM

COPYRIGHT © 2023 KSQ ARCHITECTS, PC