



Michael Tesik
Capital Facilities Regional Manager I
Telephone: 845-786-2701 x 225
Fax: 845-786-5367

ADDENDUM NO. 4

TO
CONTRACT DOCUMENTS
AND
SPECIFICATIONS

FOR

**CONTRACT NO. D005795
ZOO EXHIBITS RENOVATION
TRAILSIDE MUSEUM AND ZOO
BEAR MOUNTAIN, NY 10911**

Issued via email

DATE: APRIL 30, 2021

TO ALL HOLDERS OF THE CONTRACT DOCUMENTS:

This Addendum is hereby part of the Contract Documents:

REVISIONS TO THE CONTRACT DRAWINGS:

1. It has come to our attention that the Uponor Ecoflex PEX with heat trace is no longer available in 3/4" and is only available in 1-1/4". The documents and specifications shall be amended to change all 3/4" PEX to 1-1/4" PEX.
2. Sheet L3.10 Grading Plan:
Indicates (4) runs of 6" PVC drains. These pipes are to be Schedule 40 on a 4" stone cushion with a minimum of (1) foot of cover.

Att:

Total Number of Pages: 1 (including attachments).

NYS OPRHP – Palisades Region

Greg Askildsen
Park Engineer

******ACKNOWLEDGE RECEIPT OF THIS ADDENDA ON THE BID FORM**

END OF ADDENDUM NO. 4