



1. ALL BARS SHALL BE GALVANIZED STEEL.
2. REFER TO REINFORCED CONCRETE NOTES FOR MATERIAL SPECIFICATIONS FOR GALVANIZED STEEL BARS.
3. FOR SLABS ON GRADE, IT IS THE CONTRACTOR'S OPTION TO USE #4@12 EW INSTEAD OF WWF SHOWN ON THIS DRAWING. THE SELECTED REINFORCEMENT SHALL BE SHOWN ON THE SHOP DRAWINGS SUBMITTED FOR REVIEW

[illegible]

HARTSDALE STATION

*SHEET* 60 *OF* 99