





1. ALL BARS SHALL BE GALVANIZED.

ELEV PIT WALL

REINF. SEE

1/S-802

1 1/2"=1'-0"

2. REFER TO REINFORCED CONCRETE NOTES FOR MATERIAL SPECIFICATIONS FOR GALVANIZED REINFORCING BARS.

3. FOR SLABS ON GRADE, IT IS THE CONTRACTOR'S OPTION TO USE #4@12 EW INSTEAD OF WWF SHOWN ON THIS DRAWING. THE SELECTED REINFORCEMENT SHALL BE SHOWN ON THE SHOP DRAWINGS SUBMITTED FOR REVIEW.

100% RFC SUBMISSION

ELEV PIT

WALL

DESIGNED SD

DRAWN SD

CHECKED RA

APPROVED MM

REVISION

CONFORMED

CONFORME





HARTSDALE AND SCARSDALE STATION IMPROVEMENTS

HARTSDALE STATION

FOUNDATION SECTIONS & DETAILS II

DRAWING NO.

HTD-S-802

SHEET 61 OF 99

1000106733

AS NOTED 08/03/2021