



1	03-19-2021	ISSUED FOR BID
ISSUE NO.	ISSUE DATE	DESCRIPTION



SECOND FLOOR FAMILY  
ROOMS  
LIGHTING, POWER & FIRE  
ALARM PLANS

DRAWING NO.

E-201



- ① EXISTING SWITCHES TO BE DISCONNECTED, REMOVED, RELOCATED & REINSTALLED IN LOCATION SHOWN; MODIFY WIRING & CONDUIT AS REQUIRED TO ACCOMMODATE RELOCATION
- ② POWER NEW LIGHT FIXTURES VIA EXISTING LIGHTING CIRCUIT & WIRING

- NOTES:**
1. ALL SWITCHES & RECEPTACLES & DEVICE BOXES ARE TO BE RECESSED UNLESS OTHERWISE NOTED
  2. ROUTE SURFACE WIRING IN WIREMOLD OR EQUAL AS SHOWN
  3. POWER ALL LIGHTING & RECEPTACLES VIA EXISTING LIGHTING & RECEPTACLE CIRCUITS
  4. REVIEW PLACEMENT & ROUTING WITH ARCHITECT & ENGINEER BEFORE PROCEEDING

