



- FRAMING NOTES:
1. PROVIDE ADEQUATE SHORING DURING ENTIRE CONSTRUCTION PERIOD.
 2. LVL BEAM IS 3 PLY 5-1/4" WIDE BY 9-1/4" DEEP, 2.0E-2900Fb LOCATED AT EXISTING BEARING WALL CENTERLINE.
 3. VERIFY ADEQUATE SECOND FLOOR JOIST BEARING W/ON LVL.
 4. WOOD CONNECTORS ARE BY SIMPSON STRONG TIE OR APPROVED EQUAL.
 5. 5"x5" POSTS LOCATED WITHIN EXISTING WALL FRAMING ARE ACTUAL DIMENSIONS AND TO BE COORDINATED WITH CONNECTOR HARDWARE.
 6. ADHESIVE ANCHORS SHALL BE INSTALLED IN STRICT ACCORDANCE WITH MANUFACTURERS PUBLISHED LITERATURES.
 7. BEAR NEW WOOD HEADERS 8" MINIMUM INTO SOLID MASONRY.

[illegible]

Drawn By: <i>RAD</i>	Seal and Signature
Design By: <i>GJM</i>	
Checked By: <i>MCF</i>	
Approved By: <i>MCF</i>	
Date: <i>5/28/2021</i>	

<p>Sheet Title:</p> <p>COTTAGE FRAMING PLANS</p>	<p>Drawing Number:</p> <p>S103</p>
<p>Bid Documents</p> <p>Project Number:</p> <p><i>1299.029.001</i></p>	<p>Sheet:</p>