

REFRIGERATION MACHINE SCHEDULE

"McQUAY" AS STANDARD
OR APPROVED EQUAL

UNIT NO.	LOCATION	TYPE	CAPACITY TONS	EER	REF.	NO. UNLOADING STEPS	EVAPORATOR					ELECTRICAL DATA				UNIT WEIGHT LBS	MODEL NO.	REMARKS
							FLUID	GPM	EWT (°F)	LWT (°F)	P.D. (V)	VOLTS/ PHASE	ELECT. INPUT (KW)	MOCP	MCA			
CH-1	BASEMENT MER	SCROLL	74.5	11	R-410a	4	PLAIN WATER	170	54	44	10.5	460/3	313	150	131	2,787	WGZ-080DA	1-4
CH-2	BASEMENT MER	SCROLL	74.5	11	R-410a	4	PLAIN WATER	170	54	44	10.5	460/3	313	150	131	2,787	WGZ-080DA	1-4

NOTES:

1. FURNISH WITH WYE-DELTA START OPTION.
2. CONTROL TRANSFORMER SHALL BE FURNISHED WITH THE CHILLER.
3. VIBRATION ISOLATORS PROVIDED BY MANUFACTURER AND INSTALLED BY HVAC CONTRACTOR.
4. FLOW SWITCH PROVIDED BY MANUFACTURER AND INSTALLED BY HVAC CONTRACTOR.

FELLENZER 
ENGINEERING LLP

www.fellp.com

22 Mulberry St., Suite 2A,
Middletown, NY 10940
t 845-343-1481 fx 855-320-8735

181 Church St., Suite 100,
Poughkeepsie, NY 12601
t 845-454-9704; fx 855-320-8735

PROJECT TITLE:

Montebello Realty, GP LLC
Braemar at Montebello Assisted
Living Residence

FE PROJECT No:
15-345

SCALE:
NTS

DESIGNED BY:
PMC

DRAWN BY:
AH

CHECKED BY:
EDF

REF. DWG.:

H8.1

SKETCH TITLE:

GENERAL REVISION

REF. DWG. TITLE:

**HVAC:
SCHEDULES**

SKETCH No:

SKH8.1.2

ISSUE DATE:

2-11-20