

CIRCUIT DEVICES ON THIS SIDE TO PANEL 'P1-1' UNLESS OTHERWISE NOTED

CIRCUIT DEVICES ON THIS SIDE TO PANEL 'P1-2' UNLESS OTHERWISE NOTED

**GENERAL NOTES:**

- A. UNLESS OTHERWISE NOTED, ALL BRANCH CIRCUIT WIRING SHALL BE  $\times 2 \times 12$  WITH (1)  $\times 12$ G, TYPE MC CABLE CIRCUITED TO PANEL INDICATED ON PLAN VIEW.
- B. REFER TO ONE-LINE DIAGRAM, SCHEDULES AND DETAILS FOR ADDITIONAL INFORMATION AND REQUIREMENTS.
- C. ALL EXTERIOR BUILDING MOUNTED LIGHT FIXTURES SHALL BE CIRCUITED TO PANEL XXX AND CONNECTED TO TIME CLOCK CONTROLS.

**DRAWING NOTES:**

- ① PROVIDE LIGHTING CONTACTOR ABOVE CEILING TO CONTROL SWITCH LEG C & D THROUGHOUT THE CORRIDOR AS SHOWN.


CIRCUIT DEVICES ON THIS SIDE TO PANEL 'P1-2' UNLESS OTHERWISE NOTED

CIRCUIT DEVICES ON THIS SIDE TO PANEL 'P1-3' UNLESS OTHERWISE NOTED

CIRCUIT DEVICES ON THIS SIDE TO PANEL 'P1-1' UNLESS OTHERWISE NOTED

CIRCUIT DEVICES ON THIS SIDE TO PANEL 'P1-3' UNLESS OTHERWISE NOTED

**FIRST FLOOR PLAN**  
SCALE: 1/8"=1'-0"



DATE: 9/18/2020  
REVISION: 10/29/2020  
ADDENDUM 1

PROJECT NO. 202095  
DESIGNED BY: CUE  
DRAWN BY: CUE  
CHECKED BY: RSA  
SCALE: AS NOTED  
NOTES:

**FIRST FLOOR  
ELECTRICAL LIGHTING PLAN**

**HARRIS A. SANDERS  
ARCHITECTS, P.C.**  
252 WASHINGTON AVENUE, ALBANY, NEW YORK 12210  
**L'DOR ADULT CARE FACILITY**  
156 WEST CLARKSTOWN ROAD  
NEW CITY, N.Y. 10956

SET NO.  
**E202**