


- GENERAL NOTES:**
- ALL PIPING IS ABOVE THE CEILING UNLESS OTHERWISE INDICATED.
 - EXISTING PIPING SHOWN HAS BEEN TAKEN FROM AVAILABLE REFERENCE DRAWINGS AND LIMITED SITE VISITS. CONTRACTOR IS ADVISED TO VISIT SITE BEFORE BIDDING, STARTING WORK, OR ORDERING MATERIALS.
 - ALL PIPING SHALL BE INSTALLED CONCEALED UNLESS OTHERWISE INDICATED.
 - COORDINATE ALL WORK WITH OTHER TRADES PRIOR TO BEGINNING WORK.
 - ALL SANITARY PIPING SHALL SLOPE AT MINIMUM 1%.
 - ALL STORM PIPING SHALL SLOPE AT MINIMUM 2% UNLESS OTHERWISE NOTED.
 - PROVIDE LINK SEAL SEALING SLEEVES AT ALL LOCATIONS WHERE PIPING PENETRATES EXTERIOR WALLS AND FLOOR SLABS ON GRADE.

- DRAWING NOTES:**
- 2" P-TRAP UP TO SHOWER.
 - 2" WET VENT UP.
 - 2" WASTE DOWN, 2" WET VENT UP, 1-1/2" CONN. TO VANITY SINK.
 - 4" WALL CLEANOUT, OFFSET IN WALL TO AVOID VANITY.
 - 3" SANITARY UP TO TOILET.
 - 3" WET VENT UP.
 - 4" DECK PLATE CLEANOUT.
 - 3" SANITARY UP TO 2ND FLOOR.
 - 3" P-TRAP UP TO MOP SINK.
 - 2" VENT UP.
 - 3" WALL CLEANOUT.
 - 2" P-TRAP TO WASHING MACHINE BOX, 2" WASTE DOWN, 2" VENT UP. SEE 3/P602 FOR DETAIL.
 - 4" STANDPIPE FOR ELEVATOR SUMP PUMP DISCHARGE, SEE 1/P601.
 - 2" WASTE UP TO SINK.
 - 2" WASTE DOWN, 2" VENT UP, 1-1/2" TO SINK.
 - 3" P-TRAP UP TO FLOOR DRAIN ON 2ND FL.
 - 3" STANDPIPE FOR COOLER AND FREEZER CONDENSATE.
 - 2" VENT UP FROM GREASE TRAP, ADD VENT LIMITER IN VERTICAL.
 - 2" VENT UP, 2" WASTE DOWN, 1-1/2" TO GARBAGE DISPOSAL.
 - 2" INDIRECT WASTE FROM SINKS TO FLOOR SINK.
 - 2" INDIRECT WASTE FROM DISHWASHER TO FLOOR SINK.
 - 3/4" DRAIN FROM VEGETABLE STEAMER TO FLOOR SINK.
 - 3/4" DRAIN FROM ICE MACHINE TO FLOOR DRAIN.
 - 4" HUB DRAIN TO RECEIVE CONDENSATE WASTE, PROVIDE ACCESS DOOR, OPEN 4" HUB AT 24" ABOVE FLOOR, 4" P-TRAP BELOW GRADE SEE DWG. P101.



DATE: 9/18/2020	REVISIONS: 10/21/2020
PROJECT NO: 2020095	DESIGNED BY: MUC
	DRAWN BY: MUC
	CHECKED BY: RSA
	SCALE: AS NOTED
	NOTES:

**FIRST FLOOR
SANITARY PLAN**

HARRIS A. SANDERS ARCHITECTS, P.C.
 252 WASHINGTON AVENUE, ALBANY, NEW YORK 12210
 L'DOR ADULT CARE FACILITY
 156 WEST CLARKSTOWN ROAD
 NEW CITY, N.Y. 10956

1 FIRST FLOOR PLAN
 SCALE: 1/8"=1'-0"
 NORTH

SET NO
P102